





- Locating the feed tray - Parametric study
[not truly variable]

- constants - physical properties



$$Q = m_1 C_p (T_{i,1} - T_{0,1}) = m_2 C_p (T_{i,2} - T_{0,2}) \dots \text{① Science}$$

Cost of a shell & tube exchanger

$$= k_1 (A)^{0.7}$$


dictates the cost of the equipment

$$\rightarrow Q = UA (\Delta MTD) \dots \text{②}$$

Area - Engg.

S.S model




driving force changes along the length
[not const]



constants - physical properties

Math Eqn

- Algebraic
- ODE
- PDE



$$Q = m_1 C_p_1 (T_{i,1} - T_{o,1}) = m_2 C_p_2 (T_{i,2} - T_{o,2}) \dots \textcircled{1} \text{ Science}$$

Cost of a shell & tube exchanger

$$= k_1 (A)^{0.7}$$



dictates the cost of the equipment

$$Q = UA (\Delta MTD) \dots \textcircled{2}$$

Area - Engg.

S.S model

driving force changes along the length
[not const]



- here, we do not use LMTD to calculate the temp diff.
- we proceed by guessing one variable & the converging the other variable
- Two initial guess - w time (?)
- IFD - information flow diagram
- the system requires some time to achieve steady state after one of the variable is changed.
- Dynamic Analysis - changes w.r.t time [we require a ODE] : $\frac{d(T_{0,2})}{dt}, \frac{d(T_{0,1})}{dt}$ at the end points. [Lumped Parameter]
- Distributed space analysis - changes along the exchanger

$$\text{PDE} : \frac{d(T_{0,2})}{dt}, \frac{d(T_{0,1})}{dt}, \frac{\partial(T_{0,2})}{\partial t}, \frac{\partial(T_{0,2})}{\partial x}$$

Distributed parameter system : changes distributed over space & time

- Mathematical Eqⁿ

↳ Analytical

↳ Numerical

- Discretization


$$\frac{dx}{dt} = \frac{x^{n+1} - x^n}{\Delta t} + E$$

↓
 derivative ↓
 algebraic ↓
 error.

↳ can propagate with time

- Stability should of the solution should be considered

- After getting the numerical values we plot colorful contours of the solution
 conversion of ODE \Rightarrow IFD





T.P.P. [Thermal Power Plant]
 as W.F - Steam - Turbine
 Thermodynamics
 HT + Work

Superheated steam
 do not heat the turbine
 & steam does not condense.

Latent heat transfer occurs if steam condenses
 giving out large amount of heat to the system

Heat pump
 Heat engine




Assumptions : ① uniform mixing
 ② No heat loss

dynamic study : $F_1 - F_2 = \frac{dV}{dt} \dots ①$

[overall mass balance]

$$F_1 C_p T_1 - F_2 C_p T_2 + \frac{Q}{P} = \frac{d}{dt} (V C_p T_2) \dots ②$$

[overall heat balance]




$$T_s = f(P_s) \dots \textcircled{3} \quad [\text{steam table}]$$

$$Q = (UA) [T_s - T_2] \dots \textcircled{4} \quad [\text{heat transfer across the jacket}]$$

Algorithm to solve the eqⁿ ?? → **IFD**


□ → represents the eq



yp


$$\frac{V^{n+1} - V^n}{\Delta t} = F_1^n - F_2^n$$

$$V^{n+1} = V^n + \Delta t (F_1^n - F_2^n) \quad (\text{explicit})$$







[n - time step]

- Real time system



$$\textcircled{3} \quad P_s \rightarrow \textcircled{3} \rightarrow T_s$$






Implicit eqn: $ax^3 + bx^2 + cx + d = 0$



$$x = -\frac{ax^3 + bx^2 + d}{c}$$

$$x = f(x)$$

→ to close
the gap b/w
Q_{actual} & Q_{base}



Binary Distillation Column





① Tray hydrodynamics

$$\tau \frac{dL_n}{dt} = L_{n+1} - L_n$$

$[\tau = 5\tau$ gives steady state (almost) $\sim 99.9\%$].

τ act as time constant



② Mass balance of nth tray


$$\frac{d}{dt} (H_V y_n + H_L x_n) = L_{n-1} x_{n-1} + V_{n+1} y_{n+1} - L_n x_n - V_n y_n$$

Assumption $H_V \ll H_L$


$$\frac{d}{dt} (H_L x_n) = L_{n+1} x_{n+1} + V_{n+1} y_{n+1} - L_n x_n - V_n y_n$$

③ E_n^m curve

$$y_n = f(x_n)$$





IFD



here, we can guess x_n then can calculate y_n & more further

15th Jan 19
Tuesday
lecture 4




All calculations are inside the boundary but F f x_F are from outside & connect the system to other equipments. Reflux ratio is also from outside.

$$L_n - L_{n-1} = \tau \frac{dL_n}{dt} \quad (\text{explicit}) \quad [\text{Lumped parameter model}]$$



$$L_n^k - L_{n-1}^k = \tau \frac{L_n^{k+1} - L_n^k}{\Delta t} \quad (\text{discretization})$$

$$L_n^{k+1} = \frac{(L_n^k - L_{n-1}^k) \Delta t}{\tau} + L_n^k$$



Sensitivity analysis
We need to identify the most sensitive var as small variations in its value can cause large fluctuation so we need to control it more.

optimization



Since, it is a total condenser $x_1 = y_2 \dots \text{eq}(1)$

$$f \quad L + D = V \dots \text{eq}(2)$$

\uparrow
R (input)

$$\Rightarrow R = \frac{L_1}{D} \dots \text{eq}(3)$$


So we are supplying R (reflux ratio) from outside

- Lumped Parameter Model (ODE - $\frac{d}{dt}$)

- Distributed Parameter Model [PDE]


acc. for spatial changes as well.

$$\left(\frac{\partial}{\partial t}, \frac{\partial}{\partial x}, \frac{\partial}{\partial y}, \frac{\partial}{\partial z} \right)$$



Outside time loop.

There are nested convergence blocks & are solved step by step. After solving for $(k+1)^{\text{th}}$ step then we can solve for $(k+2)^{\text{th}}$ step and so on.




$$① \frac{d}{dt}(H_B) = L_{N-1} - L_N - V$$

$$② \frac{d}{dt}(H_B, x_N) = L_{N-1} x_{N-1} - L_N x_N - V y_N$$


$$③ y_N = f(x_N)$$

$$④ V = \frac{Q}{\lambda}$$

There's no total heat balance, just for the vapourization part.



Double Pipe Heat Exchanger



$$(v \cdot A_p) C_p (T_x - T_{x+\Delta x}) = \frac{\partial}{\partial t} (A \cdot \Delta x \cdot \rho \cdot C_p \cdot T) + h(A_s \cdot \Delta x) (T_s - T_x)$$

$$\Rightarrow (v \cdot A_p) C_p \frac{\partial T}{\partial x} + h(A_s) (T_s - T) = \frac{\partial}{\partial t} (A_p C_p T)$$

→ Split value Boundary value Problem [SBVP]

PINCH TECHNOLOGY

MER - Maximum Heat Recovery

$$\text{Stream } mC_p = CP \quad \begin{cases} \text{hot} & T_i > T_f \\ \text{cold} & T_f > T_i \end{cases}$$

heat exchanger (stream + stream)


cooler (hot stream + external cold utility)

heater (cold stream + external hot utility)

$$\text{utility} \quad \begin{cases} \text{hot} \\ \text{cold} \end{cases}$$

Crude pre-heat train CDU

A typical flow is as follows -




→ Consider 2 streams

	IN	OUT	
I	400	440	
II	100	20	

$$\begin{cases} CP = 2 \\ CP = 1 \end{cases}$$

can stream I cool stream II

No, because the quality of stream is different. Such a heat exchange is non-spontaneous and violates the second law of thermodynamics.




ΔH - heat duty

→ Grid representation of the heat exchanger network


	(°C) T_i	(°C) T_f	(kW/°C) CP	(MW) ΔH
HI	100	40	200	+12
CI	40	100	100	-12

→ Stream table

$$\Delta T_{\min} = 10^\circ\text{C}$$




Approach temp - The temp (closest) b/w HS & CS in a heat exchanger




The temperatures have been scratched out to honour the ΔT_{\min} (the minimum approach temp)

*Note Lesser the min approach temp, greater the area of HE network. Capital cost increases due to increase in area.

Extreme Conditions :




No heat exchanger



No utility - only H.E.

Cost of HE is a trade-off b/w the quality of heat exchanger and its extent (ΔT_{min}) and the area. As ΔT_{min} increases, quality \downarrow and area \downarrow and cost \downarrow . Optimisation from graph theory & Euler's network theory.



$f(x)$ such that PE is minimum

Q.

	T_i	T_f	CP	ΔH
H1	180	80	1.0	+100
C1	30	120	1.8	-162
H2	130	40	2.0	+180
C2	60	100	4.0	-160

Deficit
-42


$$g_f \text{ HU.} = 42 + x$$

$$c_u = x$$

Case (i) : Extreme condition - No. HE.

$$c_u = 280$$

$$h_u = 322$$



Stream Table ①

St.no.	T_i	T_f	C_p	$\Delta H = C_p \times \Delta T$
C1	30	120	1.8	-162
H1	130	40	2.0	$(162 + 18) = +180$
C2	60	100	4.0	$(100 + 60) = -160$
H2	180	80	1.0	$+100$ -42

$$\begin{aligned}
 (+180) + (+100) &= +280 \\
 -(162 + 160) &= -322 \\
 x &\leftarrow \text{Endothermic process} \\
 c_u &\leftarrow +42 \\
 E_{NW} &+ x \\
 H.U. &
 \end{aligned}$$



We need to supply heat to the process.

- Here we need to optimize x with Pinch Technology.

We will remove the existing i.e. & re-design the process but we cannot change values in the stream table, changing stream table values will change the process.

$$\Delta T_{min} = 10$$

Difference b/w cold stream & hot stream should be greater than or equal to ΔT_{min}



ΔT_{min} is a trade-off b/w energy and capital. Cos as we use ΔT_{min} the area ↑ & so does the cost.

Stream Table ②

	CP	T _i	T _f	ΔH
C1	2	20	135	-230
H1	3	170	60	330
C2	4	80	140	-240
H2	1.5	150	30	180

Exothermic process

$$+510 - 470 = +40$$

We need to supply C.V.

$$C.U. = -(40 + x)$$

$$\Delta T_{min} = 10$$

* Hot Stream Temp - $\frac{\Delta T_{min}}{2}$

* Cold Stream Temp + $\frac{\Delta T_{min}}{2}$

Temp : 20, 135, 170, 60, 80, 140, 150, 30 \leftarrow Original
 (\pm) 25, 140, 165, 55, 85, 145, 145, 25 \leftarrow Modified

- We are changing the quality of stream but difference b/w T_i & T_f remains same

Sort : 165, 145, 145, 140, 85, 55, 25, 25 \leftarrow Descending

165, 145, 140, 85, 55, 25 \leftarrow Repeated no.s are removed

Problem Table Method


$$\Delta T_i$$

Surplus
of heat

- Deficient
of heat

Cumulative
heat
is zero.

↓
T_{pinch}




$$H_i, V = CP \times \Delta T$$

$$\Delta H_i = \sum CP_i \times \Delta T_i$$

$$\sum CP_i = \sum CP_H - \sum CP_C$$

$$\begin{aligned}
 & 20 \times 3.0 = 60 \\
 & 5 \times (3.0 + 1.5 - 4.0) = 2.5 \rightarrow 62.5 \rightarrow 82.5 + x \\
 & 55 \times (3.0 + 1.5 - 2.0 - 4.0) = -82.5 \rightarrow -20 \rightarrow 0 + x \\
 & 30 \times (3.0 + 1.5 - 2.0) = 75 \rightarrow 55 \rightarrow 75 + x \\
 & 30 \times (1.5 - 2.0) = -15 \rightarrow 40 \rightarrow 60 + x \\
 & C.U. = 40
 \end{aligned}$$



Here, we have only a single -ve enthalpy term so we can $+20$ at the top & now take a cumulative sum. \Rightarrow cumulative cascading



- if surplus is at higher temp then we **DONOT** need any utility as it is sufficient to provide the deficit.
 - But here surplus is at lower temp so we need utilities.
 - if we add x amt of heat it gets add to every cumulatively heat which means we can optimize the process further.
 - If there ≥ 1 -ve cum heat flow then we need to add the highest -ve cum heat flow.

Pinch Temp = 85
Min. HV = 20
Min. CU = 60

- Alternative method is Composite curve method



• CP Criteria

we have 4 possibilities

According to CP criteria the ΔT at the unknown end should be 10° or more than 10° for above.

for above
 If C_p s & ΔH are equal for both CS & HS then
 ΔT will also be equal so we get a temp
 profile in ① ②


$$CP_H \cdot \Delta T_H = CP_C \cdot \Delta T_C$$

$$CP_H \downarrow \cdot \Delta T_H \uparrow = CP_c \uparrow \Delta T_c \downarrow$$

We have one end known to be $\Delta T_{\min} = 10$

so we search for highest CP_1 and then

find $C_P c$ higher than this $C_P \eta$ & join these



streams

Mention the smaller enthalpy value in heat duty box b/w the 2 streams.

C1 gets 90 (heat) so the temp rise by 45°

$$\Delta T = \frac{90}{2} = 45^\circ$$

$$80 \xrightarrow{+45^\circ} 125$$

We require 20 HU to rise temp from 125° to 135°

Now for below pinch

$$CP_H \geq CP_C$$

If we join H2 & C1, then HS temp will be lower than the CS temp & HS can no longer supply any heat to CS
[violation of CP criteria]


So we join H1 & C1, here H1 supply C1 with +90 heat at a temp of 35 we have arrived at after this we can join H2 & C1 as the temp range does not give HS temps lower than CS temp

$$\Delta T_{H1, C1} = 135 - 35$$

$$\Delta T_{H2, C1} = 135 - 125$$

	T_i	T_f	CP	ΔH
H1	500	300	3	+600
C1	180	480	1	-300
C2	160	460	1	-300

$$\Delta T_{min} = 20^\circ C$$



Tempo : 500, 300, 180, 480, 160, 460 (x-8)
 490 290 190 490 170 470

Ent : 490, 470, 290, 190, 170



490

470

290

190


170



08-02-2019

Stream splitting strategy

x - splitting ratio



$$\Delta H = CP \times \Delta T$$

$$\Delta T_{min} = 20^\circ C$$

$$C = R \cdot (A(m^2))^{0.6}$$

$$Q = UA (\Delta T_{min})$$

$$\Delta T_{min} = \frac{(500 - 460) - \left[(500 - \frac{300}{x}) - 160 \right]}{\ln \left(\frac{40}{340 - \frac{300}{x}} \right)}$$

$$(UA)_1 = \frac{300}{(\Delta T_{min})_1}$$

$$(UA)_2 = \frac{300}{(\Delta T_{min})_2}$$

$$\frac{\partial}{\partial x} (\Sigma A) = 0$$

[area minimisation]

$$\Sigma C = \alpha [A_1^{0.6} + A_2^{0.6}]$$

$$\frac{\partial}{\partial x} (\Sigma C) \neq 0$$

[cost minimisation]

~~constraint~~

$$500 - \frac{300}{x} \geq 160 + 20$$


[$\Delta T_{min} = 20^\circ C$]

$$500 - \frac{300}{3-x} \geq 180 + 20$$


So from here we can find range of x


CP criteria

$$CP_H \leq CP_C \text{ (above)}$$



Since, we do not have any cold stream having CP greater than 5.0 (CP of H_1), we need to split H_1 .






Here, we will split C_1 as there will no stream to compensate for H_1 .

- A single stream can be split and can be combined later but we **CANNOT** combine two different streams.

Above Pinch cases : [Algorithm]




we need $N_H \leq N_C$ as we cannot use a cold utility above the pinch

Above pinch $\sum CP_H \leq \sum CP_C$ [always true]

So even if split a CS and CP_c goes down we will still have a solution


LOOP & PATH



So we same two streams exchanging heat in two steps but here desire to reduce cost by reducing the no. of heat exchangers & letting them exchange heat in a single step.

$(A_1 + A_2)^{0.6} < A_1^{0.6} + A_2^{0.6}$ so 1 bigger h.e is better than 2 smaller h.e]


E.g.





A, B, C, D are heat duties
 knowing the least between among them & putting x equal to ~~equal~~ it.

Suppose if D is the smallest then $x = -D$

So the heat duties will be $(A+D)$, $(B+D)$, $(C-D)$ & 0



for our
ques -



cooling water requirement

60 MW

8000 hr/yr

$$m_{cw} C_{P,cw} (10) = (60 \times 10^6) \frac{J}{s} \times 8000 \times 60 \times 60$$

$$m_{\text{cw}} (\text{kg}) =$$

$$\text{Total Cost (₹)} = m_{cw}(\text{kg}) \times r (\text{₹/kg})$$