


$$G_c = \frac{E_d}{a_p} \quad G_{sp} = \frac{1}{G_d}$$

Ex 1: $G_p = \frac{K_p}{\tau_p s + 1} \quad G_d = \frac{K_d}{\tau_d s + 1}$

Remarks: 1) $FFC = FFC_p$
 $FBc: Q = Q_s + K_{ce}$

* Closed loop block diagram for FFC



from.

$$m = \frac{G_d}{G_{sp}} \left[\frac{1}{G_d} y_{sp} - d \right]$$

21.10.19

FFC

$$G_c = \frac{G_d}{G_p}$$

Eq


$$G_p = \frac{K_p}{\tau_p s + 1}$$

$$G_d = \frac{K_d}{\tau_d s + 1}$$

Substituting, $G_c = \frac{G_d}{G_p} = \frac{K_d (\tau_p s + 1)}{(\tau_d s + 1) K_p}$

* $G_c = \frac{K_d}{K_p} \cdot \frac{(\tau_p s + 1)}{(\tau_d s + 1)} = \text{lead-lag system}$

$\tau_p > \tau_d$: lead system
 $\tau_p < \tau_d$: lag system.



1st order lead-lag system.

* If $\tau_p = \tau_d$, $G_c = \frac{K_d}{K_p} = K$: Proportional controller (PBC)

or $G_c = K =$ Static PFC {no S term}

or Zero Pole Cancellation {No Zero, No Pole}

Ex. $G_p = \frac{K_p e^{-\theta_p s}}{\tau_p s + 1}$ $G_d = \frac{K_d e^{-\theta_d s}}{\tau_d s + 1}$

$$G_c = \frac{K_d}{K_p} \cdot \frac{(\tau_p s + 1)}{(\tau_d s + 1)} \cdot e^{-s(\theta_d - \theta_p)}$$

Is it physically realizable? Condition: $\theta_d > \theta_p$

Ex. $G_p = \frac{K_p}{(\tau_1 s + 1)(\tau_2 s + 1)}$ $G_d = \frac{K_d}{(\tau_d s + 1)}$

Modify controller eqⁿ to make it implementable

$$G_c = \frac{K_d}{K_p} \cdot \frac{(\tau_1 s + 1)(\tau_2 s + 1)}{(\tau_d s + 1)}$$

→ For a particular process, we have 1 load variable, measured cont. → FFC preferred.

→ We have 2 LV @ 1 - measured. → Combined scheme
2 - Unmeasured. FF + FB
↓
Measured Unmeasured

or FFC depends on process model which is inaccurate.
leads to control variable ^{being affected} which is taken care of by FBC

Advantages : 1) No instability problem.
2) Takes action before effect of disturbance has been felt by process.
3) good for slow process. (FBC Disadv.)


Disadvantages : 1) Involves process model which is not accurately known ∴ performance degraded.
2) Need to determine the parameters [parameter identification technique involved]
3) Not applicable for unmeasured/minor disturbances.
(FBC Adv.)

* Ratio Control

→ 1 measured, 1 manipulated variable.

→ Special type of FFC.

→ Obj: To maintain R $\left\{ R = \frac{MV}{LV} = \frac{u}{d} \right\}$
d = Wild stream



Eg. → Combustion Chamber
Fuel / air ratio

→ PH reactor : Acid / Base

→ Distillation col: Reflux Ratio

You FFC, LV measured. Same thing on RC ∴ Inference FFC
But actually FBC.

