



NOTES


1. ALL DIMENSIONS ARE IN mm. UNLESS OTHERWISE NOTED.
2. PRIOR TO INSTALLATION, EXACT LOCATION AND DIMENSIONS SHOULD BE CHECKED AND ADJUSTED BY FIELD.
3. THE CLEARANCE(GAP) SHALL BE KEEP AS SHOWN ON THIS DRAWING
4. PROVIDE FILLET WELD W/100% STRENGTH.
5. ALL PLATES AND STRUCTURAL SHAPES SHALL BE ASTM A-36 OR EQUIV. UNLESS OTHERWISE NOTED.
6. FOR GENERAL SUPPORT INFORMATION, SEE LINE-000-GA-4-0305, SPECIFICATION FOR PIPING HANGING AND SUPPORT.
7. FOR FILLET WELD, THE THROAT THICKNESS SHOULD BE MIN. 6mm

REFERENCE

NO	DWG NO	DESCRIPTION

**HEIN**  
GLOBAL UTAMA


**HEIN**  
GLOBAL UTAMA

**PT. KOKOH SEMESTA**  
ENGINEERING-MANUFACTURING-CONSTRUCTION

00	I F A	07/11/2023	SAEPUL	SALEH	ADI. Y	Mr. Jeon
ISSUE	DESCRIPTION	DATE	DRN	CHKD	APVD	

REVISION

101-SS-04  
PIPE SPECIAL SUPPORT FOR 101 AREA

	UNIT NO	PROJ. NO	SCALE	SHEET
	-	-	NTS	1
KS-HEIN-N7010				REV 00

101-SS-04	STD SS-101	N7010	PIPE SPECIAL SUPPORT FOR 101 AREA															1	208.82	1.42
101-SS-04	STD SS-101	N7010	PIPE SPECIAL SUPPORT FOR 101 AREA																	
101-SS-04	STD SS-101A-1	N7010	PIPE SPECIAL SUPPORT FOR 101 AREA	H BEAM	CS					100	x	100	x	6	x	8	x	50	L	2
101-SS-04	STD SS-101B-1	N7010	PIPE SPECIAL SUPPORT FOR 101 AREA	PIPE	A335-P22					31.75	x	219.1	"		SCH	31.75	x	1198	L	1
101-SS-04	STD SS-101C-1	N7010	PIPE SPECIAL SUPPORT FOR 101 AREA	PLATE	CS					16	x	500					x	500	L	1