




**Tackling the problem of constraint group construction
to reduce wind energy waste and defend against cascading outages**

Team 6


Wind Availability vs Metered Generation



Irish Wind Farms: Average Dispatch-Down Over Entire Dataset



Irish Wind Farms: Average Dispatch-Down with PyPSA Transmission Network



1 The shift factor, as it is used today

For a branch e and a generator at node n :

$$\text{SF}_{e,n} = \frac{\Delta f_e}{\Delta P_n}. \quad (1)$$

Two properties define how it is used:

It is transmission-line specific. One number describes one branch against one generator. A constraint group is built by computing a column of these for a single congested circuit.

It is empirical. [WDT] (Appendix 2, p. 71) obtains it by perturbation: move one generator by a fixed amount, re-run the load flow, read the change in branch current. One solve per number.

2 Sensitivity: a new way of looking at it

$$S_{e,n} = \text{PTDF}_{e,n} \cdot \text{sign}(f_e). \quad (2)$$

The same physical quantity as (1), with the sign re-pointed along each branch's real direction of flow, so that **positive always means relief**.

Without the correction a positive entry means “flow increases in the branch's stored **bus0**→**bus1** direction”, which is overload on one branch and relief on another. With it, one row may be ranked, and two rows may be added.

It is **dimensionless**, MW off the branch per MW curtailed at the node, so entries from different branches are directly comparable.

3 How to get to S : K , B , L

K , **incidence**, 754×980 . Topology only. Column e has exactly two non-zeros: $+1$ at the branch's **bus0**, -1 at its **bus1**.

$$K_{ie} = \begin{cases} +1 & i = \text{bus0}(e) \\ -1 & i = \text{bus1}(e) \\ 0 & \text{otherwise.} \end{cases}$$

B , **susceptance**, 980×980 **diagonal**. Electrical strength only: $B_{ee} = b_e = 1/x_e$, from the per-unit reactance.

$L = KBK^\top$, **the weighted Laplacian**, 754×754 . Topology and strength combined, and the matrix that must be inverted:


$$L\theta = p. \tag{3}$$

Why any of this is linear. The AC equations are not. The DC approximation holds bus voltages at 1 p.u., takes $r \ll x$ so losses vanish, and takes angle differences small so $\sin(\theta_i - \theta_j) \approx \theta_i - \theta_j$. Flow is then exactly linear in the angle difference, $f_e = b_e(\theta_i - \theta_j)$. That is the whole reason a closed-form sensitivity exists at all.

4 The matrices themselves


K — the full 754×980 incidence matrix

Exactly two non-zeros per column: +1 at bus0, -1 at bus1. 1,960 non-zeros, 0.27% dense.




$L = KBK^T$ — the full 754×754 Laplacian

2,621 non-zeros (0.46% dense). The structure is the grid's own topology.



L^+ — the full 754×754 pseudoinverse

99.2% dense. Inversion destroys sparsity: every bus is now coupled to every other.




5 The PTDF

$$\text{PTDF} = BK^{\top}L^{+}, \quad 980 \times 754, \quad 738,920 \text{ entries.} \quad (4)$$

$\text{PTDF}_{e,n}$ is the flow appearing on branch e when 1 MW is injected at bus n and withdrawn across the slack.

PTDF = $BK^{\top}L^{+}$ — all $980 \times 754 = 738,920$ entries

Every branch against every bus. No numeric form of this is readable, so it is shown whole as an image.




6 The sensitivity matrix

Only one quantity in the pipeline moves hour to hour: the direction of flow.

$$p_{\text{eff}} = p + KB\varphi, \quad f = \text{PTDF} \cdot p_{\text{eff}} - B\varphi, \quad S_{e,:} = \text{PTDF}_{e,:} \cdot \text{sign}(f_e). \quad (5)$$

Sensitivity — 980 × 157, signed along real flow

PTDF re-pointed by $\text{sign}(f_e)$. Positive means curtailing there unloads the branch.



positive	curtailing at that wind node unloads the branch
negative	curtailing at that wind node loads it further


φ holds the phase shifts of the 2 phase-shifting transformers. Dropping the $-B\varphi$ term puts the flow, and therefore the sign, and therefore every entry of S , wrong on those branches.

7 In practice, only a small set of lines is congested

Of 980 branches, only a handful reach their rating at any hour of the week, and several of those are transformers, which a lines-only model would miss entirely.

Every congested branch against every wind node

All 10 x 157 signed shift factors at once. Blue means curtailing there unloads the branch, red means it loads it further. Nodes are ordered by which branch feels them most strongly, so each block is roughly one constraint group.



Every constraint question in the rest of this document is a question about these rows. The remaining rows exist, are exact, and are never needed until the network changes, which is what an outage is.

8 Net sensitivity: a constraint group that cannot break what it did not look at

The group, as it is drawn today

$$\text{group}(e) = \{ n : S_{e,n} \geq \tau \}, \quad \tau = 0.05. \quad (6)$$

Sensitivities add. Net sensitivity is nothing more than that.

If several branches are over their rating at once, a node's total usefulness is its sensitivities to each of them, summed:

$$S_{\text{net}}(n) = \sum_{e \in \text{Over}} S_{e,n}, \quad \text{Over} = \{ e : |f_e| > s_e \}. \quad (7)$$

The critical principle


No dispatch down of a node may cause an overload on any other branch.

Reach and net relief, on the ground

Left: how many of the ten congested branches each wind node reaches. Right: its net weighted relief, which is what breadth is worth once the signs are counted. A node can be dark on the left and pale on the right — broad, but pulling in both directions at once.


Reach

Red edges are the ten congested branches.



Net relief

Red edges are the ten congested branches.



Left: how many congested branches each wind node reaches. Right: its net weighted relief, (7). A node dark on the left and pale on the right is broad but pulling both ways at once, which counting rows cannot distinguish and summing them can.

9 Doing this for every N–1 contingency

The groups are fixed. Membership is read off S , which is topology and reactance only, so it does not move with the hour or the weather. The group for every single-branch outage is built once, offline, and looked up: 432 outages, 58 distinct circuits ever at risk, 1,308 lookup rows.

Most of the fleet is almost never in one. Across all 20,203 events, 119 of 157 nodes, 65.9% of installed capacity, are dispatched down in under 1% of them. The median node keeps 99.61% of everything it offers, and over the whole study only 0.85% of all wind offered is curtailed.

For those generators a constraint group binds on a handful of hours a year. It is not a standing limit on output, and they run at full power essentially all the time.

And a few of these outages do not stop at one circuit.

10 Another application: stopping cascading outages

Most single-branch outages are absorbed. Flows redistribute and nothing else reaches its rating. A small number are not: the first trip pushes other elements over their limits, those trip in turn, and the failure propagates.

This is where the two constraint groups separate. A group drawn from one row can relieve the congested circuit while pushing a healthy one over, which starts the next link in the chain. A group built under the critical principle cannot.


Shift factor constraint groups

LINE OUTAGES

2

WIND CUT

744 MW · 14%




Net sensitivity constraint groups

LINE OUTAGES

0

WIND CUT

16 MW · 0%



Spectral Clustering of the Irish Transmission Grid

Where the grid comes apart

Oleksandr — Team 6, Electrical Grid Hackathon 2026

Networks: WP2024 and WP2033, all-island


Method

1. Grid as a weighted graph: buses and generators are nodes.
2. Normalised Laplacian $L_{\text{sym}} = I - D^{-1/2} A D^{-1/2}$.
3. Its k smallest eigenvectors as coordinates per node.
4. k -means on those coordinates.

Edge weights

susceptance	$1/x_e$ — static network
headroom	$s_{\text{nom}} - F_e $ — one hour of dispatch


WP2024 — where the grid is loaded




Branches at $\geq 50\%$ of rating over one week.
57 of 848 branches.

WP2024 — clustering, $k = 6$: headroom and susceptance


WP2024_all-island +generators — sym, headroom, $k = 6$, 2030-01-20 17:00:00
643/643 buses placed, 40/1097 drawn corridors cut



TYTFS2024_WP2024_V35_transmission +generators — sym, susceptance, $k = 6$
643/643 buses placed, 35/895 drawn corridors cut




WP2024 — the north-east cluster




171 nodes, linked to the rest through a few corridors.

WP2024 — the week: how close the grid is to splitting




λ_2 dips whenever the maximum branch loading peaks.

WP2024 — the week: does the partition move?



No node changes cluster over the 168 hours.


WP2024 — the eigenvalues: how many clusters?



No gap at $k = 6$; the largest gap is after 33.


WP2024 — susceptance clustering, $k = 33$

TYTFS2024_WP2024_V35_transmission +generators — sym, susceptance, k = 33
643/643 buses placed, 103/895 drawn corridors cut



k taken from the eigengap.


WP2033 — where the grid is loaded




Branches at $\geq 70\%$ of rating over one week.
66 of 980 branches.

WP2033 — clustering, $k = 6$: headroom and susceptance


WP2033_all-island +generators — sym, headroom, $k = 6$, 2030-01-20 17:00:00
751/751 buses placed, 42/1858 drawn corridors cut



TYTFS2024_WP2033_V35_transmission +generators — sym, susceptance, $k = 6$
746/751 buses placed, 35/1637 drawn corridors cut



WP2033 — generators grouped by shift factor, $k = 9$



k -means on each generator's shift factors across all 980 branches.

NEXT

