

GENERAL NOTES:

- Glazing will be selected and installed in accordance with AS1288–2006 for internal glazing and AS2047 for external glazing.
- The parapets will be provided with a metal capping extending down 50mm each side and provided with sarking in accordance with clause 3.5.4.8 of the BCA.
- External balcony is to be provided with a waterproof membrane in accordance with AS4654.1 & 2 including the following:
 - 50mm step down to the balcony or a flush transition is to be provided as per below.
 - Location of drainage floor waste connected into the stormwater drainage system.
- Sarking type materials used in the roof is to achieve a flammability index not greater than 5.
- Waterproofing of wet areas will be in accordance with AS3740–2010 and BCA–Table 3.8.1.1.
- Smoke alarms complying with AS3786 –2014 and connected to the consumer mains power, where there is more than one smoke alarm to confirm they are interconnected.
- The W/C door will be provided with lift–off hinges.
- The following condensation management provisions for the proposed development:
 - Sarking is to comply and to be installed in accordance with AS/NZS4200.1 & 2.
 - Mechanical exhaust fans must achieve flow rates of 25L/s in a bathroom and sanitary compartment, 40L/s in a kitchen and laundry.
 - The mechanical exhaust fan is to discharge directly via shaft or duct to outdoor air.
- Stairway is to be provided demonstrating the following details:
 - Riser and going heights (Check 2R + G).
 - Maximum opening of 125mm to risers.
 - Treads are to be provided with a nosing strip with a slip–resistance classification not less than that listed in Table 3.9.1.3 when tested in accordance with AS4586.
 - Stair balustrade and balustrade connection construction details and calculations confirming the capacity of the balustrade to resist AS1170.1 or AS/NZS 1170.1 loads.
- The window opening is less than 1.7m above the floor the window must be protected with the following:
 - Provided with a device capable of restricting window opening not to permit a 125mm sphere to pass through; or
 - A screen with secure fittings capable of resisting an outward horizontal action of 250N against the window restrained by device or screen protecting the opening; and
 - Have a child resistant release mechanism if the screen or device is removable, unlocked or overridden.
- Eaves gutters will be provided with continuous overflow provisions in accordance with BCA–Table 3.5.3.4a and box gutters with dedicated overflow provisions in accordance with BCA–Table 3.5.3.4b or provide details of the overflow provisions to the downpipe and gutter system in accordance with clause 3.5.3.4
 - Box gutter size (Minimum 75mm x 200mm).

	SITE ADDRESS	LOT NO 1422,WHITEWOOD AVENUE			FRONT SET BACK PORCH: 3.26 METER FRONT SET BACK GARAGE: 5.35 METER SIDE SET BACK GARAGE SIDE: 1.05 METER SIDE SET BACK OTHER SIDE: 1.05 METER REAR SET BACK 5.09 METER	PLAN NO V2 VERSION 1 DATE 24/06/25
	CLIENT NAME	MONIKA MODI & KOMAL CHOUDHARY	LOT LENGTH	32.00METER		
	CONTACT NO		LOT WIDTH	12.50 METER		
	EMAIL ADDRESS		HOUSE LENGTH	23.65METER		
			HOUSE WIDTH	11.25 METER		
This is a concept/draft plan based on general set-backs. Plan is subject to approval of Private Certifier / Council by-laws and rules. It may require alteration to meet the guidelines. Plan is copyright of Fenix Homes Pty Ltd. Any use of plan without the written consent of Fenix Homes Pty Ltd may result in penalties.						