27-KA50
EXPORT BOOSTER COMPRESSOR

DISCHARGE/SUCTION PRESS: 54/13.5 barg
DISCHARGE/SUCTION TEMP: 143 deg.C/18 deg.C
SHAFT POWER: 4.4 MW at 1.0 MSm3/d

A4

27 PT 4803
27 PIC 4803 SP=14.5 barg
0.75" 27-4542PV
27-4541PV 0.75"
27-4510PV
27-4511PV
27-4512PV 0.75"
6"x8"
27 PY 4803
A/S
27 PV 4803
FC
8"
7 8
NOTE 7,19
27 XY 4814
27 XV 4814
27 HS 4814
PSD
27 ZS 4814 H L
27 ZL 4814 H L
8"-VF-434601-AS200-7
TO HP COLD VENT.
W-HO43-P-*F-001
8" ED200 AS200 8 7
10"-PV-274506-ED200-8
10"
27-4453PV
NOTE 16
SI 4208
KEY INTERLOCK
10"-PV-274507-ED200-7
TO WET GAS COOLERS
W-HO24-P-*E-001
MODULE PLATFORM
ANTI-SURGE CONTROL
27 HS 4811
PSD
A/S
27 FY 4811A
27 FY 4811B
27 FY 4811C
27 FV 4811
FO
6"x10"
6"
8"x6"
NOTE 12,15
BASIS: BLOCKED OUTLET
SET+150 barg
27 PSV 4809
BS200 AS200
43-4505VF
12"-VF-434602-AS200-7
TO HP COLD VENT.
W-HO43-P-*F-001
BS200 ED200
6"x12"
12"
NOTE 14
6"x4"
SI 4206
SI 4207
KEY INTERLOCK
43-4516VF 0.75"
SET+150 barg
27 PSV 4810
KEY INTERLOCK
BS200 AS200
43-4506VF
TO HP COLD VENT.
W-HO43-P-*F-001
27-4502PV
6"
27-4514PV 0.75"
12"-VF-434603-AS200-7
NOTE 14
27-4501PV
6"
27-4503PV 27-4504PV
6"-PV-274511-ED200-7
27-4515PV 0.75"
SEAL GAS TO COMPRESSOR
1"-PV-274512-ED200-4
HO27-P-*E-003
NOTE 10
27 ZL 4813 H L
27 HS 4813
27 XY 4813
AS
S
PSD
27 ZS 4813 H L
27 XV 4813
FC
10"
NOTE 6
TO AFTERCOOLER
10"-PV-274502-ED200-8
HO27-P-*E-002
27-4500PV
SI 4203
NOTE 1,3
FROM WET GAS SCRUBBER
W-HO24-P-*E-002
10"-PV-274500-ED200-7
NOTE 13
27 FE 4801
10"x14"
10"-PV-274501-ED200-7
0,75"
6"-PV-274508-ED200-7
27 FI 4801
27 FT 4801
0.75" 27-4520PV
27-4521PV 0.75" CSO
27-4522PV 0.75" CSO
27 PI 4823
27 PT 4823
0.75" 27-4523PV 0.75" CSO
27-4524PV 0.75" CSO
27-4525PV 0.75" CSO
NOTE 21
27 PI 4804
HH+ 36 barg
H+ 20 barg
L+ 13 barg
LL+ 10 barg
TO UCP
27 PT 4804
0.75" 27-4526PV 0.75" CSO
27-4527PV 0.75" CSO
27 PDI 4812
HH+1.0 bar
H+0.9 bar
27 PDT 4812
0.75" 27-4528PV 0.75" CSO
27-4529PV 0.75" CSO
0.75" 27-4530PV 0.75" CSO
27-4531PV 0.75" CSO
NOTE 20
NOTE 5
NOTE 4,8,9
NOTE 4,8
NOTE 5
NOTE 18
27 PI 4805
HH+135 barg
H+ 75 barg
L+ 50 barg
LL+ 40 barg
27 PT 4805
0.75" 27-4532PV 0.75" CSO
27-4533PV 0.75" CSO
NOTE 2
27 TI 4806
HH+190 deg C
H+ 185 deg C
27 TT 4806
1.5"
27 PI 4807
27 PT 4807
0.75" 27-4534PV 0.75" CSO
27-4535PV 0.75" CSO
NOTE 11
8"-PV-274505-ED200-8
4"
SI 4202
PSD
27 HS 4826
S
NOTE 17
27 XY 4826
A/S
27 ZL 4826 H L
27 ZS 4826 H L
FC 2"-PL-274513-ED200-4
2"-PL-274514-ED200-4
27 XV 4826
2"
INS
NO INS
27 HS 4828
27 XY 4828
NOTE 18
27 ZS 4828 H L
27 ZL 4828 H L
27 FO 4827
27 FO 4829
27-4536PL 0.75"
274513 574515
27-4454PL
2" CSO
2"-DC-574515-ED200-0
NO POCKETS
TO CLOSED DRAIN
W-HO57-P-*F-001
TO 20PV2201
HO27-P-*E-001
MODULE PLATFORM
0.75" 27-4538PV
27-4540PV 0.75"
27 PT 4825
27 PIC 4825A 4825B 4825C
A4
SP=13.5 barg
NOTE 22
PLATFORM MODULE
FROM 27-PSE4255 FSH
FROM 27-PSE4254 FSH
FROM 27-PT4252A/B
FROM 27-PT4250A/B
TO UCP
FROM UCP
GAS TURBINE/ GENERATOR
EL. 40.360
27-KA50 COMPRESSOR
DETAIL DRW.: C025-V-H027-P-*E-003-01
N1100
N1103
FD20A ED200
NOTE 17
TO UCP
NOTE 21

NOTES:

1. NON SLAM CHECK VALVE MOUNTED ON HIGH POINT.
2. PALL ON COMPRESSOR OUTLET EQUIPPED WITH 15 MIN TIME-DELAY AT COMPRESSOR START-UP. WHEN COMPRESSOR IS IN NORMAL OPERATION, PALL SHALL NOT BE TIME-DELAYED.
3. LOCATED AS CLOSE TO COMPRESSOR DISCHARGE AS POSSIBLE.
4. SPOOL PIECE FOR MAINTENANCE.
5. LOW POINT.
6. LOCATED CLOSE TO CHECK VALVE TO MINIMIZE TRAPPED VOLUME.
7. 27-PV4803 TO BE USED DURING START-UP OF COMPRESSOR AS SPILL-OFF VALVE.
8. INLET/OUTLET MAIN NOZZLES LOCATED BELOW COMPRESSOR, DIRECTED DOWNWARDS.
9. COMPRESSOR SUCTION PIPE SHALL BE STRAIGHT AND WITHOUT ANY CHANGE IN CROSS SECTION FOR A MINIMUM OF 1500mm FROM SUCTION NOZZLE.
10. UNINTENSIONAL CLOSING OF 27-XV4813 OPENS 27-FV4811 WHEN XV LEAVES HIGH POSITION ON LIMIT SWITCH.
11. FUTURE TIE-IN TO FUEL GAS SKID.
12. ANTI-SURGE VALVE WILL OPERATE AS CONTROL VALVE WHEN FLOW DECREASES BELOW THE SURGE CONTROL LINE. RESTRICTIONS IN MIN. VALVE OPENING (5%) WHEN OPEN SHALL BE IMPLEMENTED IN ANTI-SURGE CONTROL LOGIC.
13. MIN. 10 D AND 5 D STRAIGHT LENGHT UPSTREAM AND DOWSTREAM FLOW ELEMENT.
14. ANY REINFORCEMENT PLATE OR ATTACHMENT PLATE SHOULD ENVELOPE THE FULL CIRCUMFERENCE OF THE PIPE.
15. MIN 5D AND 10D STRAIGHT LENGTH UPSTREAM AND DOWNSTREAM CONTROL VALVE.
16. KEY INTERLOCK INCLUDES VALVES 27-4452PV AND 27-4453PV. TO PREVENT THAT 27-4453PV IS CLOSED WHILE 27-4452PV IS OPEN.
17. LOW PRESSURE PERMISSIVE SET AT 33 BARG TO ALLOW FOR OPENING OF DRAIN VALVE 27-XV4826.
18. LOW PRESSURE PERMISSIVE SET AT 33 BARG TO ALLOW FOR OPENING OF DRAIN VALVE 27-XV4828.
19. CONTROL VALVE EQUIPPED WITH TRAVEL STOP TO LIMIT FLOW RATE TO COLD VENT SYSTEM. TRAVEL STOP SET AT 55% VALVE OPENING (EQUALS 1.25 MSm3/d). 48% VALVE OPENING EQUALS 1.0 MSm3/d AT 30 BARG INLET PRESSURE.
20. BOLT CATCHER TO BE REMOVED 1 MONTH AFTER COMPRESSOR START-UP.
21. ANTI-SURGE MINIMUM SUCTION PRESSURE CONTROL SET POINT IS (12.5 BARG). A4
22. PRESSURE UPSTREAM COMPRESSOR CAN BE CONTROLLED EITHER BY DISCHARGE THROTTLING, 27-PIC4825A/B OR BY VARYING COMPRESSOR SPEED, 27-PIC4825C.

DRG. NO.	REFERENCE DRAWINGS	REV.	REASON FOR ISSUE	DATE	DRN.	CHK.	DISC. SUP.	DDB
		A4	AS-BUILT NW 969718/NOT 41306043	19.06. 2013	JTB	TV	MJR	
		A3	AS BUILT NW. 969264/NOT. 40887133	03.10. 2011	FF	AMØ	FF	
		A2	AS BUILT NOT. 41058365	02.02. 2010	KM	EDF	TSE	LLY
		A1	AS BUILT HHP-PROJECT	17.07. 2007	MC	SVL	SVL	RSB

SYSTEM NO.: 27
WORK PACK NO.:

STATOIL
vetco

Huldra Haleproduksjon

TITLE:
PIPING AND INSTRUMENT DIAGRAM
EXPORT BOOSTER COMPRESSOR

SCALE: N.T.S.
PROJECTION:

DRAWING NO.: C025-V-H027-P-*E-001-01 A4

PROJECT NO.	CONTR.	AREA/SYS	DISC.	TYPE	NUMBER	SHT.NO	REV.

PEGS REF: 1311 010 020 A004 08 HALA11
Statoil UBT - MicroStation - A1 PROJ / AREA / DISC / SHEET / ISSUE / PROJNR