45-XW50
FUEL GAS GENERATOR
CAPASITY: 6000 Kg/h NOTE 13

DESIGN TEMP. INLET:- 46/60 °C
DESIGN PRESSURE INLET: 150 barg
DESIGN TEMP. OUTLET:- 46/100 °C
DESIGN PRESSURE OUTLET: 45 barg

45-XJ50
GAS METERING PACKAGE
CAPASITY: 6000 Kg/h

DESIGN TEMPERATURE:- 46/100 °C
DESIGN PRESSURE : 45 barg

NOTES:

1. FROM LIQUID OUTLET ON SCRUBBER AND FILTER/COALESCER.
2. FUTURE CONNECTION TO FUEL GAS GENERATOR. IF FUEL GAS DEMAND EXCEEDS 3545kg/H, THE COMPRESSOR OUTLET HAS TO BE CONNECTED TO FUEL GAS GENERATOR.
3. VENT CONNECTION AT HIGH POINT
4. INLET 45-PV4831 CAPASITY=3545 Kg/HR (15MW FOR TURBINE)
5. FREE ISSUE ITEMS. DELIVERED BY DRESSER RAND.
6. FUEL GAS GENERATOR PSD. SEE C&E 480403-BZ-001.
7. CALIBRATION GAS FOR FUEL GAS CALORIMETER.
8. MANUAL VALVES, PSV AND KEY INTERLOCK DELIVERED BY VETCO GT, AS LOOSE ITEMS. PIPING AND INSTALLATIONS BY VETCO AIBEL.
9. DELETED
10. PRE-FILLING OF LIQUID IN SCRUBBER.
11. CONNECTION FOR SAMPLING.
12. CONNECTION FOR PORTABLE METHANOL PUMP.

TO HP VENT COLLECTION HEADER W-H043-P-×F-001
8"-VF-434620-AS200-7
DEW POINT TEMPERATURE TO GAS TURBINE CONTROL SYSTEM 4500912746-AS-003
TO HP VENT COLLECTION HEADER W-H043-P-×F-001
4"-VF-434609-AS200-0
TO GENERATOR AND COMPRESSOR PACKAGE H027-P-×E-003
CSC 45-4520GF
1"-VA-434629-AS200-0
VENT TO SAFE LOCATION H027-P-×E-003
1"-VA-434630-AS200-0
VENT TO SAFE LOCATION H027-P-×E-003
1"-VA-434624-AS200-0
VENT TO SAFE LOCATION H027-P-×E-003
TO HAZARDOUS OPEN DRAIN H027-P-×E-003
2"-DO-564686-AS200-0
TO CLOSED DRAIN HEADER W-H057-P-×F-001
2"-DC-574689-BD200-0

BASIS: BLOCKED OUTLET
45 PSV 4832 SET AT 45 BARG
45 PSV 4833 SET AT 45 BARG
8"-VF-434621-AS200-7
43-4293VF
43-4297VF
AS200 BS200
6"x8" 8" FB FB 8" 8"x6"
43-4292VF 0,75"
43-4296VF 0,75"
6"x4"
45-4291GF 0,75"
45-4295GF 0,75"
45-4290GF FB 6"
45-4294GF FB 6"
SI 4480
KEY INTERLOCK
NOTE 8
6"-GF-454535-BS200-4
NOTE 10 0.75" 45-4210GF
NOTE 6 PSD
6"-GF-454534-BS200-4
6"
4"
CONTRACTOR VENDOR
NOTE 6 PSD
N006
N003
1"-VF-434619-AS200-0
AS200 BD200
1"
CONTRACTOR VENDOR
N3
45-XJ50
GAS METERING PACKAGE
SEE DWG. 480421-AS-001
NOTE 11 0.75" 45-4551GF
2"x0.75"
N002
4"-GF-454530-BD200-4
4" 4"
N1
N2
4"-GF-454531-BD200-4
45 PT 4831
45-4501GF 0.75"
AS
45 XY 4806B
45 XY 4806A
45 U C P XY 4806
FO
PSD
S
45 ZS 4806
45 ZL 4806 H L
FC
4"
45 XV 4806
NOTE 3
NOTE 2
N010
45-XW50
FUEL GAS GENERATOR
SEE DWG. 480403-AS-001/002
EL. 42500
1"-GF-454532-BD200-4
1"-GF-454533-BD200-4
1"-GF-454628-BD200-4
PSD
45 HS 4804
45 HS 4805
45 XY 4804
45 XY 4805
45 XV 4804
45 XV 4805
S
1"
FC
A/S
45-4504GF 0.75"
45-4506GF 0.75"
45 ZS 4804
45 ZL 4804 H L
45 ZS 4805
45 ZL 4805 H L
45-4505GF
45-4507GF
0.25"x1"
NOTE 12
27-4455PV
27-4456PV 0.75"
27-4457PV
FROM EXPORT BOOSTER COMPRESSOR AFTERCOOLER H027-P-×E-002
NO POCKETS
NOTE 4
N001
4"-PV-274509-ED200-4 4"
4"-PV-274599-ED200-4
A3
INST. AIR
N007
45 FI 4810
45 PI 4810B
45 TI 4810B
45 PI 4810A
45 TI 4810A
NOTE 1
N008
N004
N009
N005
2" 0.75" 2"
EL.:+42500
BS200
AS200
1"x0.75
1"-DC-574727-BD200-0
2"-DC-574687-BD200-0
1"-DC-574692-BD200-0
57-4552DC
NOTE 11 0.75" 0.75"x2"
45 PCV 4103
45 PCV 4113
SP* 2 barg
SP=1,5 barg
NOTE 4,5
SEE DWG.: 4500912746-AS-001
EL. 42500
PSD
6MM TUBING
CONTRACTOR VENDOR
FROM 45-PT4804
FROM 45-PT4805
N052
N062
45-XX50
FUEL GAS CALORIMETER
SEE DWG. 4500912746-AS-001
INST. AIR
N071
N072
N057
N067
NOTE 7
N054
N064
NOTE 5
1"x0.25"

REV.	REASON FOR ISSUE	DATE	DRN.	CHK.	DISC. SUP.	DDB
A3	AS BUILT NW 969718/NOT 41306043	19.06.13	JTB	TV	MJR	
A2	AS BUILT ACC. TO M5: 40783125	18.11.08	LM	MSH	KV	KV
A1	AS BUILT HHP-PROJECT	17.07.07	MC	SVL	SVL	RSB

DRG. NO. | REFERENCE DRAWINGS

SYSTEM NO: 45
WORK PACK NO:

STATOIL
vetco
SCALE: N.T.S
PROJECTION:

Huldra Haleproduksjon
TITLE: PIPING AND INSTRUMENT DIAGRAM
FUEL GAS SYSTEM

DRAWING NO.: C025- V - H045-P-×F-001 - 01 | A3
PROJECT NO. | CONTR. | AREA | DISC. | NUMBER | SHT.NO | REV.

StatoilUBT - MicroStation - A1