## **V/Line – Completion Report**



**Project:** 2631 - V/Line ELC North & Northwest 2025

**Customer:** V/Line

PO / LOE:

**Location:** Bendigo, Victoria (KP – )

Status: Completed

Date Completed: 2025-08-05

• Project Name: 2631 - V/Line ELC North & Northwest 2025

• Customer: V/Line

Location: Bendigo, VictoriaDate of Works: 2025-08-05

• Status: Completed

## **Summary**

The inspection and completion record for the V/Line ELC North & Northwest 2025 project was conducted at 253 King Street, Bendigo, Victoria. The project status is Completed, with the inspection completed on 2025-08-05. The team inspected the insulated service Asset ID 'Bendigo 25' along the Sydenham–Bendigo corridor (Northern). Clearance to conductors measured 0.3 m, with no vegetation present at the time of inspection. All relevant data was captured, including span and track numbers, address verification, and photographic evidence.

## **Key Findings**

- Inspection completed at 253 King Street, Bendigo, Victoria.
- Clearance measured at 0.3 metres for insulated service asset.
- No vegetation present at the time of inspection.
- Photographic evidence provided (3 after photos).
- Record status: Completed; corridor: Northern; region: HBRA.

Media

**Before** 

**During** 

**After** 







After – 2631\_After\_2.jpg



After – 2631\_After\_3.jpg

## Generated by Systems @ TMC enviro

www.tmcenviro.com.au

Email: systems@tmcenviro.com.au | Phone: +61 458 922 033