

Flow

Totally Integrated Automation Portal																																																																																																
<div>Table of contents</div> <div>Flow</div> <table><tr><td>PLC_1 [CPU 314C-2 PN/DP]</td><td>4 - 1</td></tr><tr><td>Program blocks</td><td></td></tr><tr><td> Main [OB1]</td><td>5 - 1</td></tr><tr><td> Analog In [FC1]</td><td>6 - 1</td></tr><tr><td> Anolog Out [FC2]</td><td>7 - 1</td></tr><tr><td> PID [FC3]</td><td>8 - 1</td></tr><tr><td> Data_block_1 [DB1]</td><td>9 - 1</td></tr><tr><td> CYC_INT5 [OB35]</td><td>10 - 1</td></tr><tr><td> I/O_FLT1 [OB82]</td><td>11 - 1</td></tr><tr><td> I/O_FLT2 [OB83]</td><td>12 - 1</td></tr><tr><td> RACK_FLT [OB86]</td><td>13 - 1</td></tr><tr><td> OBNL_FLT [OB85]</td><td>14 - 1</td></tr><tr><td>System blocks</td><td></td></tr><tr><td> Program resources</td><td>15 - 1</td></tr><tr><td> System diagnostics</td><td></td></tr><tr><td> RSE_DIAGNOSTIC_STATUS_DB [DB127]</td><td>16 - 1</td></tr><tr><td> RSE_FB [FB49]</td><td>17 - 1</td></tr><tr><td> RSE_FC [FC49]</td><td>18 - 1</td></tr><tr><td>Technology objects</td><td>19 - 1</td></tr><tr><td> PLC tags</td><td>20 - 1</td></tr><tr><td> Default tag table [31]</td><td>21 - 1</td></tr><tr><td> PLC data types</td><td>22 - 1</td></tr><tr><td> Watch and force tables</td><td></td></tr><tr><td> Force table</td><td>23 - 1</td></tr><tr><td> Watch table_1</td><td>24 - 1</td></tr><tr><td> PLC supervisions & alarms</td><td></td></tr><tr><td> PLC alarms</td><td>25 - 1</td></tr><tr><td> User diagnostics alarms</td><td>26 - 1</td></tr><tr><td> System alarms</td><td>27 - 1</td></tr><tr><td> PLC alarm text lists</td><td>28 - 1</td></tr><tr><td>Local modules</td><td></td></tr><tr><td> PS 307 2A_1</td><td>29 - 1</td></tr><tr><td> PLC_1 [CPU 314C-2 PN/DP]</td><td>30 - 1</td></tr><tr><td> AI 2x12BIT_1</td><td>31 - 1</td></tr><tr><td> AO 2x12BIT_1</td><td>32 - 1</td></tr><tr><td>Ungrouped devices</td><td>33 - 1</td></tr><tr><td>Security settings</td><td>34 - 1</td></tr><tr><td>Cross-device functions</td><td></td></tr><tr><td> Project traces</td><td></td></tr><tr><td> Measurements</td><td>35 - 1</td></tr><tr><td>Common data</td><td></td></tr><tr><td> Alarm classes</td><td>36 - 1</td></tr><tr><td> Logs</td><td>37 - 1</td></tr><tr><td>Languages & resources</td><td></td></tr><tr><td> Project languages</td><td>38 - 1</td></tr><tr><td> Project texts</td><td></td></tr><tr><td> Project texts</td><td>39 - 1</td></tr></table>			PLC_1 [CPU 314C-2 PN/DP]	4 - 1	Program blocks		Main [OB1]	5 - 1	Analog In [FC1]	6 - 1	Anolog Out [FC2]	7 - 1	PID [FC3]	8 - 1	Data_block_1 [DB1]	9 - 1	CYC_INT5 [OB35]	10 - 1	I/O_FLT1 [OB82]	11 - 1	I/O_FLT2 [OB83]	12 - 1	RACK_FLT [OB86]	13 - 1	OBNL_FLT [OB85]	14 - 1	System blocks		Program resources	15 - 1	System diagnostics		RSE_DIAGNOSTIC_STATUS_DB [DB127]	16 - 1	RSE_FB [FB49]	17 - 1	RSE_FC [FC49]	18 - 1	Technology objects	19 - 1	PLC tags	20 - 1	Default tag table [31]	21 - 1	PLC data types	22 - 1	Watch and force tables		Force table	23 - 1	Watch table_1	24 - 1	PLC supervisions & alarms		PLC alarms	25 - 1	User diagnostics alarms	26 - 1	System alarms	27 - 1	PLC alarm text lists	28 - 1	Local modules		PS 307 2A_1	29 - 1	PLC_1 [CPU 314C-2 PN/DP]	30 - 1	AI 2x12BIT_1	31 - 1	AO 2x12BIT_1	32 - 1	Ungrouped devices	33 - 1	Security settings	34 - 1	Cross-device functions		Project traces		Measurements	35 - 1	Common data		Alarm classes	36 - 1	Logs	37 - 1	Languages & resources		Project languages	38 - 1	Project texts		Project texts	39 - 1
PLC_1 [CPU 314C-2 PN/DP]	4 - 1																																																																																															
Program blocks																																																																																																
Main [OB1]	5 - 1																																																																																															
Analog In [FC1]	6 - 1																																																																																															
Anolog Out [FC2]	7 - 1																																																																																															
PID [FC3]	8 - 1																																																																																															
Data_block_1 [DB1]	9 - 1																																																																																															
CYC_INT5 [OB35]	10 - 1																																																																																															
I/O_FLT1 [OB82]	11 - 1																																																																																															
I/O_FLT2 [OB83]	12 - 1																																																																																															
RACK_FLT [OB86]	13 - 1																																																																																															
OBNL_FLT [OB85]	14 - 1																																																																																															
System blocks																																																																																																
Program resources	15 - 1																																																																																															
System diagnostics																																																																																																
RSE_DIAGNOSTIC_STATUS_DB [DB127]	16 - 1																																																																																															
RSE_FB [FB49]	17 - 1																																																																																															
RSE_FC [FC49]	18 - 1																																																																																															
Technology objects	19 - 1																																																																																															
PLC tags	20 - 1																																																																																															
Default tag table [31]	21 - 1																																																																																															
PLC data types	22 - 1																																																																																															
Watch and force tables																																																																																																
Force table	23 - 1																																																																																															
Watch table_1	24 - 1																																																																																															
PLC supervisions & alarms																																																																																																
PLC alarms	25 - 1																																																																																															
User diagnostics alarms	26 - 1																																																																																															
System alarms	27 - 1																																																																																															
PLC alarm text lists	28 - 1																																																																																															
Local modules																																																																																																
PS 307 2A_1	29 - 1																																																																																															
PLC_1 [CPU 314C-2 PN/DP]	30 - 1																																																																																															
AI 2x12BIT_1	31 - 1																																																																																															
AO 2x12BIT_1	32 - 1																																																																																															
Ungrouped devices	33 - 1																																																																																															
Security settings	34 - 1																																																																																															
Cross-device functions																																																																																																
Project traces																																																																																																
Measurements	35 - 1																																																																																															
Common data																																																																																																
Alarm classes	36 - 1																																																																																															
Logs	37 - 1																																																																																															
Languages & resources																																																																																																
Project languages	38 - 1																																																																																															
Project texts																																																																																																
Project texts	39 - 1																																																																																															

Totally Integrated Automation Portal

Flow

Project

Name:	Flow	Creation time:	6/9/2021 1:44:20 AM	Last change	12/3/2022 10:40:53 AM	Author:	home
Last modified by:	daveb	Version:					
Comment:							

Operating system

Name	Description
Operating system	Microsoft Windows 11 Home Single Language
Version of the operating system	6.3.9600.0
Operating system service pack	
Version of the Internet Explorer	11.1.22621.0
Computer name	VU_THACH
User name	VU_THACH\daveb
Installation path of the TIA Portal	C:\Program Files\Siemens\Automation\Portal V16

Components

Name	Version	Release
TIA Portal Project Server V16 - TIA Portal Project Server Single SetupPackage V16.0 (MUSERVERV16)	V16.0	V16.00.00.00_31.02.00.01
Siemens Totally Integrated Automation Portal V16 - SIMATIC S7-PLCSIM V16.0 (S7_PLCSIM_V16)	V16.0	V16.00.00.00_31.00.13.01
TIA Administrator - AWB Licensing Module V1.0 + SP2 (TIAADMIN)	V1.0 + SP2	V01.00.02.00_01.10.00.01
TIA Administrator - AWB Software Management V1.0 + SP2 (TIAADMIN)	V1.0 + SP2	V01.00.02.00_01.10.00.01
TIA Administrator - TIA UMC Agent Configurator Module V1.0 + SP2 (TIAADMIN)	V1.0 + SP2	V01.00.02.00_01.10.00.01
TIA Administrator - TIA Administrator V1.0 SP2 (TIAADMIN)	V1.0 + SP2	V01.00.02.00_01.10.00.01
Siemens Totally Integrated Automation Portal V16 - HM All Editions Single SetupPackage V16.0 (TIAP16)	V16.0	V16.00.00.00_31.02.00.01
Siemens Totally Integrated Automation Portal V16 - HM NoBasic Single SetupPackage V16.0 (TIAP16)	V16.0	V16.00.00.00_31.02.00.01
Siemens Totally Integrated Automation Portal V16 - Hardware Support Base Package 0 V16.0 (TIAP16)	V16.0	V16.00.00.00_27.01.00.01
Siemens Totally Integrated Automation Portal V16 - Multiuser Client Single SetupPackage V16.0 (TIAP16)	V16.0	V16.00.00.00_31.02.00.01
Siemens Totally Integrated Automation Portal V16 - Version Control Interface SetupPackage V16.0 (TIAP16)	V16.0	V16.00.00.00_31.02.00.01
Siemens Totally Integrated Automation Portal V16 - STEP 7 Safety Single SetupPackage V16.0 (TIAP16)	V16.0	V16.00.00.00_31.02.00.01
Siemens Totally Integrated Automation Portal V16 - STEP 7 Single SetupPackage V16.0 (TIAP16)	V16.0	V16.00.00.00_31.02.00.01
Siemens Totally Integrated Automation Portal V16 - Hardware Support Base Package 02 V16.0 (TIAP16)	V16.0	V16.00.00.00_27.01.00.01
Siemens Totally Integrated Automation Portal V16 - Hardware Support Base Package 03 V16.0 (TIAP16)	V16.0	V16.00.00.00_27.01.00.01
Siemens Totally Integrated Automation Portal V16 - Hardware Support Base Package 04 V16.0 (TIAP16)	V16.0	V16.00.00.00_27.01.00.01
Siemens Totally Integrated Automation Portal V16 - Support Base Package TO-01 V16.0 (TIAP16)	V16.0	V16.00.00.00_27.01.00.01
Siemens Totally Integrated Automation Portal V16 - Support Base Package TO-02 V16.0 (TIAP16)	V16.0	V16.00.00.00_27.01.00.01
Siemens Totally Integrated Automation Portal V16 - Hardware Support Base Package WCF-01 V16.0 (TIAP16)	V16.0	V16.00.00.00_27.01.00.01
Siemens Totally Integrated Automation Portal V16 - TIACOMP CHECK Single SetupPackage V16.0 (TIAP16)	V16.0	V16.00.00.00_31.02.00.01
Siemens Totally Integrated Automation Portal V16 - Simatic Single SetupPackage V16.0 (TIAP16)	V16.0	V16.00.00.00_31.02.00.01
Siemens Totally Integrated Automation Portal V16 - WinCC Single SetupPackage V16.0 (TIAP16)	V16.0	V16.00.00.00_31.02.00.01
Siemens Totally Integrated Automation Portal V16 - Openness SetupPackage V16.0 (TIAP16)	V16.0	V16.00.00.00_31.02.00.01
Siemens Totally Integrated Automation Portal V16 - WinCC Transfer Mandatory Single SetupPackage V16.0 (TIAP16)	V16.0	V16.00.00.00_31.02.00.01
User Management Component - UserManagementComponentx64 V2.7 (UMC64)	V2.7	V02.07.00.00_04.06.00.07
WinCC Runtime Advanced V16.0 - HMIRTM Tagging Package 01 Single SetupPackage V16.0 (HMIRTM_V11)	V16.0	V16.00.00.00_31.02.00.01
Siemens Totally Integrated Automation Portal V16 - Simatic Single SetupPackage 32 Bit V16.0 (TIAP16)	V16.0	V16.00.00.00_31.02.00.01
Siemens Totally Integrated Automation Portal V16 - WinCC Single SetupPackage 32 Bit V16.0 (TIAP16)	V16.0	V16.00.00.00_31.02.00.01
SIMATIC HMI License Manager Panel Plugin (x64)	16.0.0.0	V16.00.00.00_31.02.00.01
SIMATIC WinCC Runtime Advanced Driver (x64)	16.0.0.0	V16.00.00.00_31.02.00.01
ETWEventCollector	16.0.0.0	V16.00.00.00_31.02.00.01
SIMATIC NCM FWL 64	5.6.0.3	K5.6.0.3_1.1.0.2
NCM GPRS 64	01.02.00.00	V1.2.0.0_2.1.0.1
SIMATIC PLCSIM 64	16.00.00	16.00.00.00_01.00.02.01
SIMATIC Device Drivers	9.2	09.02.04.00_01.04.00.05
TelemetryConnector	1.0.2.57	V01.00.02.57_01.00.00.01
Automation Software Updater	02.05.0300	V02.05.03.00_01.01.00.29
SIMATIC HMIProvider	7.0	K07.00.03.01_01.01.00.01
SIEMENS OPC	3.9	03.09.10.00_01.04.00.08
SIMATIC WinCC OPC Alarm & Events Server	3.9	03.09.09.00_01.09.00.01
SIMATIC WinCC OPC Data Access Server	3.9	03.09.09.00_01.09.00.01
SIMATIC WinCC OPC Historical Data Access Server	3.9	03.09.09.00_01.09.00.01
SIMATIC WinCC OPC XML Client	3.9	03.09.09.00_01.09.00.01

Totally Integrated Automation Portal																																																																																																					
<table><tr><th>Name</th><th>Version</th><th>Release</th></tr><tr><td>PCS7 Common Classes</td><td>9.0</td><td>09.00.01.00_00.03.00.07</td></tr><tr><td>SIMATIC HMI ProSave</td><td>16.0.0.0</td><td>V16.00.00.00_31.02.00.01</td></tr><tr><td>SIMATIC HMI Symbol Library</td><td>16.0.0.0</td><td>V16.00.00.00_31.02.00.01</td></tr><tr><td>SIMATIC HMI Touch Input</td><td>16.0.0.0</td><td>V16.00.00.00_31.02.00.01</td></tr><tr><td>SIMATIC Runtime Interfaces</td><td>2.1</td><td>K02.01.00.03_01.01.00.01</td></tr><tr><td>SIMATIC Version View</td><td>1.7.10.0</td><td>K1.7.10.0_1.1.0.1</td></tr><tr><td>SIMATIC Device Drivers WoW</td><td>29.2</td><td>29.02.04.00_01.04.00.05</td></tr><tr><td>SIMATIC Event Database</td><td>5.6</td><td>05.06.02.00_01.01.00.01</td></tr><tr><td>SeCon</td><td>2.6</td><td>V02.06.01.00_01.08.00.01</td></tr><tr><td>SIMATIC Station Observer</td><td>K7.3.1.0</td><td>V07.03.01.00_01.01.00.14</td></tr><tr><td>SIMATIC SCS</td><td>K7.5.2.0</td><td>V07.05.02.00_01.21.00.02</td></tr><tr><td>SIMATIC WinCC Common Archiving</td><td>V7.5.0.0</td><td>V07.05.00.00_01.39.00.03</td></tr><tr><td>WinCC Runtime Advanced Simulator</td><td>16.0.0.0</td><td>V16.00.00.00_31.02.00.01</td></tr></table> <table><tr><th colspan="3">Products</th></tr><tr><th>Name</th><th>Version</th><th>Release</th></tr><tr><td>TIA Portal Project Server</td><td>V16.0</td><td>V16.00.00.00_31.02.00.01</td></tr><tr><td>SIMATIC S7-PLCSIM</td><td>V16.0</td><td>V16.00.00.00_31.00.13.01</td></tr><tr><td>TIA Administrator</td><td>V1.0</td><td>01.00.02.00_01.10.00.01</td></tr><tr><td>SIMATIC STEP 7 Prof - STEP 7 Safety - WinCC Adv</td><td>V16.0</td><td>V16.00.00.00_31.02.00.01</td></tr><tr><td>User Management Component</td><td>V2.7</td><td>V02.07.00.00_00.00.00.00</td></tr><tr><td>SIMATIC WinCC Runtime Advanced Simulation</td><td>V16.0</td><td>V16.00.00.00_31.02.00.01</td></tr><tr><td>Automation License Manager</td><td>V6.0 + SP5 + Upd1</td><td>06.00.05.01_02.01.00.05</td></tr><tr><td>FORDM</td><td></td><td></td></tr><tr><td>S7-PLCSIM</td><td>V5.4 + SP8</td><td>V05.04.08.01_01.24.00.01</td></tr><tr><td>SIMATIC ProSave</td><td>V16.0</td><td>V16.00.00.00_31.02.00.01</td></tr><tr><td>S7-PCT</td><td>V3.5 + SP1</td><td>K3.5.1.0_1.19.0.1</td></tr><tr><td>WinCC Runtime</td><td>V7.5</td><td>V07.05.00.00_01.39.00.03</td></tr><tr><td>WinCC Configuration</td><td>V7.5</td><td>V07.05.00.00_01.39.00.03</td></tr><tr><td>WinCC OPC Server</td><td>V3.9 + SP9</td><td>03.09.09.00_01.09.00.01</td></tr><tr><td>WinCC OPC-UA Client</td><td>V1.1</td><td>01.01.00.00_01.28.00.01</td></tr><tr><td>WinCC OPC-UA Server</td><td>V1.0 + SP7</td><td>01.00.07.00_01.14.00.01</td></tr><tr><td>SIMATIC WinCC Smart Tools</td><td>V7.5</td><td>V07.05.00.00_01.39.00.03</td></tr></table>			Name	Version	Release	PCS7 Common Classes	9.0	09.00.01.00_00.03.00.07	SIMATIC HMI ProSave	16.0.0.0	V16.00.00.00_31.02.00.01	SIMATIC HMI Symbol Library	16.0.0.0	V16.00.00.00_31.02.00.01	SIMATIC HMI Touch Input	16.0.0.0	V16.00.00.00_31.02.00.01	SIMATIC Runtime Interfaces	2.1	K02.01.00.03_01.01.00.01	SIMATIC Version View	1.7.10.0	K1.7.10.0_1.1.0.1	SIMATIC Device Drivers WoW	29.2	29.02.04.00_01.04.00.05	SIMATIC Event Database	5.6	05.06.02.00_01.01.00.01	SeCon	2.6	V02.06.01.00_01.08.00.01	SIMATIC Station Observer	K7.3.1.0	V07.03.01.00_01.01.00.14	SIMATIC SCS	K7.5.2.0	V07.05.02.00_01.21.00.02	SIMATIC WinCC Common Archiving	V7.5.0.0	V07.05.00.00_01.39.00.03	WinCC Runtime Advanced Simulator	16.0.0.0	V16.00.00.00_31.02.00.01	Products			Name	Version	Release	TIA Portal Project Server	V16.0	V16.00.00.00_31.02.00.01	SIMATIC S7-PLCSIM	V16.0	V16.00.00.00_31.00.13.01	TIA Administrator	V1.0	01.00.02.00_01.10.00.01	SIMATIC STEP 7 Prof - STEP 7 Safety - WinCC Adv	V16.0	V16.00.00.00_31.02.00.01	User Management Component	V2.7	V02.07.00.00_00.00.00.00	SIMATIC WinCC Runtime Advanced Simulation	V16.0	V16.00.00.00_31.02.00.01	Automation License Manager	V6.0 + SP5 + Upd1	06.00.05.01_02.01.00.05	FORDM			S7-PLCSIM	V5.4 + SP8	V05.04.08.01_01.24.00.01	SIMATIC ProSave	V16.0	V16.00.00.00_31.02.00.01	S7-PCT	V3.5 + SP1	K3.5.1.0_1.19.0.1	WinCC Runtime	V7.5	V07.05.00.00_01.39.00.03	WinCC Configuration	V7.5	V07.05.00.00_01.39.00.03	WinCC OPC Server	V3.9 + SP9	03.09.09.00_01.09.00.01	WinCC OPC-UA Client	V1.1	01.01.00.00_01.28.00.01	WinCC OPC-UA Server	V1.0 + SP7	01.00.07.00_01.14.00.01	SIMATIC WinCC Smart Tools	V7.5	V07.05.00.00_01.39.00.03
Name	Version	Release																																																																																																			
PCS7 Common Classes	9.0	09.00.01.00_00.03.00.07																																																																																																			
SIMATIC HMI ProSave	16.0.0.0	V16.00.00.00_31.02.00.01																																																																																																			
SIMATIC HMI Symbol Library	16.0.0.0	V16.00.00.00_31.02.00.01																																																																																																			
SIMATIC HMI Touch Input	16.0.0.0	V16.00.00.00_31.02.00.01																																																																																																			
SIMATIC Runtime Interfaces	2.1	K02.01.00.03_01.01.00.01																																																																																																			
SIMATIC Version View	1.7.10.0	K1.7.10.0_1.1.0.1																																																																																																			
SIMATIC Device Drivers WoW	29.2	29.02.04.00_01.04.00.05																																																																																																			
SIMATIC Event Database	5.6	05.06.02.00_01.01.00.01																																																																																																			
SeCon	2.6	V02.06.01.00_01.08.00.01																																																																																																			
SIMATIC Station Observer	K7.3.1.0	V07.03.01.00_01.01.00.14																																																																																																			
SIMATIC SCS	K7.5.2.0	V07.05.02.00_01.21.00.02																																																																																																			
SIMATIC WinCC Common Archiving	V7.5.0.0	V07.05.00.00_01.39.00.03																																																																																																			
WinCC Runtime Advanced Simulator	16.0.0.0	V16.00.00.00_31.02.00.01																																																																																																			
Products																																																																																																					
Name	Version	Release																																																																																																			
TIA Portal Project Server	V16.0	V16.00.00.00_31.02.00.01																																																																																																			
SIMATIC S7-PLCSIM	V16.0	V16.00.00.00_31.00.13.01																																																																																																			
TIA Administrator	V1.0	01.00.02.00_01.10.00.01																																																																																																			
SIMATIC STEP 7 Prof - STEP 7 Safety - WinCC Adv	V16.0	V16.00.00.00_31.02.00.01																																																																																																			
User Management Component	V2.7	V02.07.00.00_00.00.00.00																																																																																																			
SIMATIC WinCC Runtime Advanced Simulation	V16.0	V16.00.00.00_31.02.00.01																																																																																																			
Automation License Manager	V6.0 + SP5 + Upd1	06.00.05.01_02.01.00.05																																																																																																			
FORDM																																																																																																					
S7-PLCSIM	V5.4 + SP8	V05.04.08.01_01.24.00.01																																																																																																			
SIMATIC ProSave	V16.0	V16.00.00.00_31.02.00.01																																																																																																			
S7-PCT	V3.5 + SP1	K3.5.1.0_1.19.0.1																																																																																																			
WinCC Runtime	V7.5	V07.05.00.00_01.39.00.03																																																																																																			
WinCC Configuration	V7.5	V07.05.00.00_01.39.00.03																																																																																																			
WinCC OPC Server	V3.9 + SP9	03.09.09.00_01.09.00.01																																																																																																			
WinCC OPC-UA Client	V1.1	01.01.00.00_01.28.00.01																																																																																																			
WinCC OPC-UA Server	V1.0 + SP7	01.00.07.00_01.14.00.01																																																																																																			
SIMATIC WinCC Smart Tools	V7.5	V07.05.00.00_01.39.00.03																																																																																																			

Totally Integrated Automation Portal					
--------------------------------------	--	--	--	--	--

Flow

PLC_1 [CPU 314C-2 PN/DP]

PLC_1

General

Name	PLC_1	Author	home	Comment	
Rack	0	Slot	2		

General\Catalog information

Short designation	CPU 314C-2 PN/DP	Description	Work memory 192KB; 0.6ms/1000 instructions; DI24/DO16; AI5/AO2 integrated; 4 pulse outputs (2.5kHz); 4 channels counting and measuring with 24 V (60kHz) incremental encoders; integrated positioning function; PROFINET interface and 2 Ports; MRP; PROFINET CBA; PROFINET CBA Proxy; TCP/IP transport protocol; combined MPI/DP interface (MPI or DP master or DP slave); multi-tier configuration up to 31 modules; capable of sending and receiving in direct data exchange; constant bus cycle time; routing; firm-ware V3.3		
Firmware version	V3.3				

General\Identification & Maintenance

Plant designation		Location identifier			
-------------------	--	---------------------	--	--	--

MPI/DP interface [X1]\General

Name	MPI/DP interface_1	Comment			
------	--------------------	---------	--	--	--

MPI/DP interface [X1]\MPI address\Interface networked with

Subnet:	Not networked				
---------	---------------	--	--	--	--

MPI/DP interface [X1]\MPI address\Parameters

Interface type:	Mpi	Address:	2	Highest address:	
Transmission speed:					

MPI/DP interface [X1]\Time-of-day synchronization\SIMATIC mode

Type of synchroniza-tion	None	Time interval	None		
--------------------------	------	---------------	------	--	--

MPI/DP interface [X1]\Diagnostics addresses\Diagnostics addresses

Start address	2047				
---------------	------	--	--	--	--

PROFINET interface [X2]\General

Name	PROFINET interface_1	Comment			
------	----------------------	---------	--	--	--

PROFINET interface [X2]\Ethernet addresses\Interface networked with

Subnet:	Not connected				
---------	---------------	--	--	--	--

PROFINET interface [X2]\Ethernet addresses\IP protocol

IP configuration	Set IP address in the project	IP address:	192.168.0.1	Subnet mask:	255.255.255.0
Use router	False				

PROFINET interface [X2]\Ethernet addresses\PROFINET

PROFINET device name is set directly at the device	False	Generate PROFINET device name auto-matically	True	PROFINET device name:	plc_1
Converted name:	plcxb1d0ed	Device number:	0		

PROFINET interface [X2]\Time-of-day synchronization\NTP mode

Enable time synchro-nization via NTP serv-er	False		IP addresses	Server 1	0.0.0.0
Server 2	0.0.0.0	Server 3	0.0.0.0	Server 4	0.0.0.0
Update interval	10s				

PROFINET interface [X2]\Operating mode

IO controller	True	IO system		Device number	0
IO device	False				

PROFINET interface [X2]\Advanced options\Interface options

Call the user program if communication er-rors occur	False	Support device re-placement without exchangeable medi-um	True	Use IEC V2.2 LLDP mode	True
Keep-Alive connec-tion monitoring:	30s				

PROFINET interface [X2]\Advanced options\Real time settings\IO communication

Send clock:	1.000ms				
-------------	---------	--	--	--	--

PROFINET interface [X2]\Advanced options\Real time settings\Synchronization

RT class:	RT,IRT				
-----------	--------	--	--	--	--

PROFINET interface [X2]\Advanced options\Real time settings\Real time options


Calculated bandwidth for cyclic IO data:	0.000ms	Calculated bandwidth for cyclic IO data:	0.000%		
--	---------	--	--------	--	--


PROFINET interface [X2]\Advanced options\Port [X2 P1 R]\General

Name	Port_1	Comment			
------	--------	---------	--	--	--

PROFINET interface [X2]\Advanced options\Port [X2 P1 R]\Port interconnection\Local port:

Local port:	PLC_1\PROFINET interface_1 [X2]\Port_1 [X2 P1 R]	Medium:	Copper	Cable name:	---
-------------	--	---------	--------	-------------	-----



Totally Integrated Automation Portal						
PROFINET interface [X2]\Advanced options\Port [X2 P1 R]\Port interconnection\Partner port:						
	Monitoring of partner port is not possible		Partner port:	Any partner		
PROFINET interface [X2]\Advanced options\Port [X2 P1 R]\Port options\Activate						
Activate this port for use	True					
PROFINET interface [X2]\Advanced options\Port [X2 P1 R]\Port options\Connection						
Transmission rate / duplex:	Automatic		Monitor	False	Enable autonegotiation	True
PROFINET interface [X2]\Advanced options\Port [X2 P1 R]\Port options\Boundaries						
End of detection of accessible devices	False		End of topology discovery	False	End of the sync domain	False
PROFINET interface [X2]\Advanced options\Port [X2 P1 R]\Diagnostics addresses\Diagnostics addresses						
Start address	2045					
PROFINET interface [X2]\Advanced options\Port [X2 P2 R]\General						
Name	Port_2		Comment			
PROFINET interface [X2]\Advanced options\Port [X2 P2 R]\Port interconnection\Local port:						
Local port:	PLC_1\PROFINET interface_1 [X2]\Port_2 [X2 P2 R]		Medium:	Copper	Cable name:	---
						
PROFINET interface [X2]\Advanced options\Port [X2 P2 R]\Port interconnection\Partner port:						
	Monitoring of partner port is not possible		Partner port:	Any partner		
PROFINET interface [X2]\Advanced options\Port [X2 P2 R]\Port options\Activate						
Activate this port for use	True					
PROFINET interface [X2]\Advanced options\Port [X2 P2 R]\Port options\Connection						
Transmission rate / duplex:	Automatic		Monitor	False	Enable autonegotiation	True
PROFINET interface [X2]\Advanced options\Port [X2 P2 R]\Port options\Boundaries						
End of detection of accessible devices	False		End of topology discovery	False	End of the sync domain	False
PROFINET interface [X2]\Advanced options\Port [X2 P2 R]\Diagnostics addresses\Diagnostics addresses						
Start address	2044					
PROFINET interface [X2]\Diagnostics addresses\Diagnostics addresses						
Start address	2046					
DI 24/DO 16\General						
Name	DI 24/DO 16_1		Comment			
DI 24/DO 16\General\Catalog information						
Short designation	DI 24/DO 16		Description	Digital input/output DI24 + DO16		
DI 24/DO 16\Inputs\Channel group 0 - 3						
Input delay	3ms					
DI 24/DO 16\Inputs\Channel group 0 - 3\Hardware interrupt channel 0\Rising (positive) edge						
Rising (positive) edge	False					
DI 24/DO 16\Inputs\Channel group 0 - 3\Hardware interrupt channel 0\Falling (negative) edge						
Falling (negative) edge	False					
DI 24/DO 16\Inputs\Channel group 0 - 3\Hardware interrupt channel 1\Rising (positive) edge						
Rising (positive) edge	False					
DI 24/DO 16\Inputs\Channel group 0 - 3\Hardware interrupt channel 1\Falling (negative) edge						
Falling (negative) edge	False					
DI 24/DO 16\Inputs\Channel group 0 - 3\Hardware interrupt channel 2\Rising (positive) edge						
Rising (positive) edge	False					
DI 24/DO 16\Inputs\Channel group 0 - 3\Hardware interrupt channel 2\Falling (negative) edge						
Falling (negative) edge	False					
DI 24/DO 16\Inputs\Channel group 0 - 3\Hardware interrupt channel 3\Rising (positive) edge						
Rising (positive) edge	False					
DI 24/DO 16\Inputs\Channel group 0 - 3\Hardware interrupt channel 3\Falling (negative) edge						
Falling (negative) edge	False					
DI 24/DO 16\Inputs\Channel group 4 - 7						
Input delay	3ms					
DI 24/DO 16\Inputs\Channel group 4 - 7\Hardware interrupt channel 4\Rising (positive) edge						
Rising (positive) edge	False					
DI 24/DO 16\Inputs\Channel group 4 - 7\Hardware interrupt channel 4\Falling (negative) edge						
Falling (negative) edge	False					
DI 24/DO 16\Inputs\Channel group 4 - 7\Hardware interrupt channel 5\Rising (positive) edge						
Rising (positive) edge	False					
DI 24/DO 16\Inputs\Channel group 4 - 7\Hardware interrupt channel 5\Falling (negative) edge						
Falling (negative) edge	False					
DI 24/DO 16\Inputs\Channel group 4 - 7\Hardware interrupt channel 6\Rising (positive) edge						
Rising (positive) edge	False					
DI 24/DO 16\Inputs\Channel group 4 - 7\Hardware interrupt channel 6\Falling (negative) edge						
Falling (negative) edge	False					
DI 24/DO 16\Inputs\Channel group 4 - 7\Hardware interrupt channel 7\Rising (positive) edge						
Rising (positive) edge	False					

Totally Integrated Automation Portal						
DI 24/DO 16\Inputs\Channel group 20 - 23\Hardware interrupt channel 23\Falling (negative) edge						
Falling (negative) edge	False					
DI 24/DO 16\I/O addresses\Input addresses						
Start address	136.0		End address	138.7		Process image OB1-PI
Interrupt OB number	40					
DI 24/DO 16\I/O addresses\Output addresses						
Start address	136.0		End address	137.7		Process image OB1-PI
AI 5/AO 2\General						
Name	AI 5/AO 2_1		Comment			
AI 5/AO 2\General\Catalog information						
Short designation	AI 5/AO 2		Description	Analog I/O AI5 + AO2		
AI 5/AO 2\Inputs						
Temperature unit	Degrees Celsius					
AI 5/AO 2\Inputs\Channel 0						
Measurement type	Voltage		Measuring range	+/- 10V		Interference frequency suppression 50Hz
Integration time	20ms					
AI 5/AO 2\Inputs\Channel 1						
Measurement type	Voltage		Measuring range	+/- 10V		Interference frequency suppression 50Hz
Integration time	20ms					
AI 5/AO 2\Inputs\Channel 2						
Measurement type	Voltage		Measuring range	+/- 10V		Interference frequency suppression 50Hz
Integration time	20ms					
AI 5/AO 2\Inputs\Channel 3						
Measurement type	Voltage		Measuring range	+/- 10V		Interference frequency suppression 50Hz
Integration time	20ms					
AI 5/AO 2\Inputs\Channel 4						
Measurement type	Resistor (2-wire)		Measuring range	600 ohmsOhm		
AI 5/AO 2\Outputs\Output 0						
Output type	Voltage		Output range	+/- 10V		
AI 5/AO 2\Outputs\Output 1						
Output type	Voltage		Output range	+/- 10V		
AI 5/AO 2\I/O addresses\Input addresses						
Start address	800		End address	809		Process image None
Interrupt OB number	40					
AI 5/AO 2\I/O addresses\Output addresses						
Start address	800		End address	803		Process image None
Count\General						
Name	Count_1		Comment			
Count\General\Catalog information						
Short designation	Count		Description	4 channels; counting and frequency measurement at 60 kHz, pulse width modulation at 2.5 kHz switching frequency		
Count\Interrupt selection						
Interrupt selection	None					
Count\Channel 0						
Operating mode	Not configured					
Count\Channel 1						
Operating mode	Not configured					
Count\Channel 2						
Operating mode	Not configured					
Count\Channel 3						
Operating mode	Not configured					
Count\I/O addresses\Input addresses						
Start address	816		End address	831		Process image None
Interrupt OB number	40					
Count\I/O addresses\Output addresses						
Start address	816		End address	831		Process image None
Positioning\General						
Name	Positioning_1		Comment			
Positioning\General\Catalog information						
Short designation	Positioning		Description	1 channel; positioning with analog and digital outputs, counting frequency		
Positioning\Interrupt selection						
Interrupt selection	None					
Positioning\Channel 0						
Operating mode	None					
Positioning\I/O addresses\Input addresses						
Start address	832		End address	847		Process image None
Interrupt OB number	40					
Positioning\I/O addresses\Output addresses						
Start address	832		End address	847		Process image None
Startup						
Startup if preset configuration does not match actual configuration	True		Startup after POWER ON	Warm restart		
Startup\Monitoring time for						
Ready message from modules	650x 100 ms		Parameter transfer to modules	100x 100 ms		

Totally Integrated Automation Portal						
Cycle						
Cycle monitoring time	150ms	Cycle load due to communication	20%	Size of the process image input:	256	
Size of the process image output:	256	OB85 call if I/O access error occurs	No OB85 call			
Clock memory						
Clock memory	False	Memory byte	0			
Interrupts\Isochronous mode interrupts						
OB number	Priority	Distributed I/O	Process image partition(s)	Delay time (ms)	Automatic setting	
OB 61	25	0		0.000	True	
Interrupts\Isochronous mode interrupts\OB 61						
Application cycle:	0ms	Delay time:	0.000ms	Automatic setting	True	
Distributed I/O:	0					
Interrupts\Isochronous mode interrupts\OB 61\Process image partition						
PIP:						
Interrupts\Time-of-day interrupts\						
OB number	Priority	Active	Execution	Start time		
OB 10	2	False	None	1994-01-01 00:00:00.000		
Interrupts\Time-delay interrupts\						
OB number	Priority			Process image partition(s)		
OB 20	3			None		
OB 21	4			None		
Interrupts\Cyclic interrupts\						
OB number	Priority	Execution	Phase offset	Unit		
OB 32	9	1000	0	ms		
OB 33	10	500	0	ms		
OB 34	11	200	0	ms		
OB 35	12	500	0	ms		
Interrupts\Hardware interrupts\						
OB number				Priority		
OB 40				16		
Interrupts\Interrupts for DPV1\						
OB number				Priority		
OB 55				2		
OB 56				2		
OB 57				2		
Interrupts\Asynchronous error interrupts\						
OB number				Priority		
OB 82				26		
OB 83				26		
OB 85				26		
OB 86				26		
OB 87				26		
Retentive memory						
Number of memory bytes starting at MB 0	16	Number of S7 timers starting at T 0	0	Number of S7 counters starting at C 0	8	
Protection						
Password		Confirm password				
Protection\						
Level of protection	No protection					
Protection\Can be canceled with password						
Can be canceled with password	False					
Diagnostics system						
Report cause of STOP	True	Number of alarms in the diagnostics buffer	10			
System diagnostics\General						
Activate system diagnostics for this device	True					
System diagnostics\Diagnostic support						
Query for status "activated/deactivated" after startup	False	Send alarm if status changes from/to activated or deactivated	False			
Additional blocks for diagnostic data	Create	Block name	Block number			
Diagnostic status DB:	True	RSE_DIAGNOSTIC_STATUS_DB	127			
System diagnostics\System diagnostic blocks						
System diagnostic blocks	Block name			Block number		
FB:	RSE_FB			49		
DB:	RSE_DB			49		
Global DB:	RSE_GLOBAL_DB			50		
FC:	RSE_FC			49		
Time of day						
Correction factor	0ms					
Time of day\Synchronization on PLC						
Type of synchronization	None	Time interval	None			
Time of day\Synchronization on MPI						
Type of synchronization	None	Time interval	None			
Web server\General						
Activate web server on this module	False	Permit access only with HTTPS	False			
Web server\Automatic update						
Enable automatic update	False	Update interval	0s			

Totally Integrated Automation Portal

Web serverLanguages

Active	Web server language	Assign project language
False	German	None
False	English	None
False	French	None
False	Spanish	None
False	Italian	None
False	Japanese	None
False	Chinese (simplified)	None

Web serverUser management

User name	User rights
Everybody	

Web serverUser-defined web pages

Application name	HTML source path	Default HTML page	Files with dynamic content	Web DB number	Fragment DB number
		index.htm	.htm;.html	333	334

Web serverText_Display_classes_of_messages

Display class	Active
0	True
1	True
2	True
3	True
4	True
5	True
6	True
7	True
8	True
9	True
10	True
11	True
12	True
13	True
14	True
15	True
16	True

Connection resources

PG communication:	1	OP communication:	1	S7 basic communication:	0
S7 communication:	0	Maximum number of S7 connection resources:	12		

Overview of addressesOverview of addressesOverview of addresses

Inputs	True	Outputs	True	Address gaps	False
Slot	True				

Type	Addr. from	Addr. to	Module	PIP	Device name	Device number	Size	Master / IO system	Rack	Slot
I*	2047	2047	MPI/DP interface_1	---	PLC_1 [CPU 314C-2 PN/DP]	-	0 Bits	-	0	2 X1
I*	2046	2046	PROFINET interface_1	---	PLC_1 [CPU 314C-2 PN/DP]	-	0 Bits	-	0	2 X2
I*	2045	2045	Port_1	---	PLC_1 [CPU 314C-2 PN/DP]	-	0 Bits	-	0	2 X2 P1 R
I*	2044	2044	Port_2	---	PLC_1 [CPU 314C-2 PN/DP]	-	0 Bits	-	0	2 X2 P2 R
I	136	138	DI 24/DO 16_1	OB1-PI	PLC_1 [CPU 314C-2 PN/DP]	-	3 Bytes	-	0	2 5
O	136	137	DI 24/DO 16_1	OB1-PI	PLC_1 [CPU 314C-2 PN/DP]	-	2 Bytes	-	0	2 5
I	800	809	AI 5/AO 2_1	OB1-PI	PLC_1 [CPU 314C-2 PN/DP]	-	10 Bytes	-	0	2 6
O	800	803	AI 5/AO 2_1	OB1-PI	PLC_1 [CPU 314C-2 PN/DP]	-	4 Bytes	-	0	2 6
I	816	831	Count_1	OB1-PI	PLC_1 [CPU 314C-2 PN/DP]	-	16 Bytes	-	0	2 7
O	816	831	Count_1	OB1-PI	PLC_1 [CPU 314C-2 PN/DP]	-	16 Bytes	-	0	2 7
I	832	847	Positioning_1	OB1-PI	PLC_1 [CPU 314C-2 PN/DP]	-	16 Bytes	-	0	2 8
O	832	847	Positioning_1	OB1-PI	PLC_1 [CPU 314C-2 PN/DP]	-	16 Bytes	-	0	2 8
I	256	259	AI 2x12BIT_1	OB1-PI	PLC_1 [CPU 314C-2 PN/DP]	-	4 Bytes	-	0	4
O	272	275	AO 2x12BIT_1	OB1-PI	PLC_1 [CPU 314C-2 PN/DP]	-	4 Bytes	-	0	5

Flow / PLC_1 [CPU 314C-2 PN/DP] / Program blocks

Main [OB1]

Main Properties

General


Name	Main	Number	1	Type	OB	Language	LAD
Numbering	Manual						

Information


Title	"Main Program Sweep (Cycle)"	Author		Comment		Family	
Version	0.1	User-defined ID					

Name	Data type	Offset	Default value	Comment
▼ Temp				
OB1_EV_CLASS	Byte	0.0		Bits 0-3 = 1 (Coming event), Bits 4-7 = 1 (Event class 1)
OB1_SCAN_1	Byte	1.0		1 (Cold restart scan 1 of OB 1), 3 (Scan 2-n of OB 1)
OB1_PRIORITY	Byte	2.0		Priority of OB Execution
OB1_OB_NUMBR	Byte	3.0		1 (Organization block 1, OB1)
OB1_RESERVED_1	Byte	4.0		Reserved for system
OB1_RESERVED_2	Byte	5.0		Reserved for system
OB1_PREV_CYCLE	Int	6.0		Cycle time of previous OB1 scan (milliseconds)
OB1_MIN_CYCLE	Int	8.0		Minimum cycle time of OB1 (milliseconds)
OB1_MAX_CYCLE	Int	10.0		Maximum cycle time of OB1 (milliseconds)
OB1_DATE_TIME	Date_And_Time	12.0		Date and time OB1 started
Constant				

Network 1:




Network 2:




Network 3:


Network 3:



Network 4:



Network 5:



Network 6:



Network 7: Call system diagnostics block


```
0001      CALL    "RSE_FB", "RSE_DB"
```

Flow / PLC_1 [CPU 314C-2 PN/DP] / Program blocks

Analog In [FC1]

Analog In Properties							
General							
Name	Analog In	Number	1	Type	FC	Language	LAD
Numbering	Automatic						
Information							
Title		Author		Comment		Family	
Version	0.1	User-defined ID					
Name		Data type	Offset	Default value	Comment		
▼ Input							
in		Int					
PIW_max		Real					
PIW_min		Real					
x_max		Real					
x_min		Real					
▼ Output							
out		Real					
InOut							
▼ Temp							
temp1		DInt	0.0				
temp2		Real	4.0				
temp3		Real	8.0				
temp4		Real	12.0				
temp5		Real	16.0				
temp6		Real	20.0				
temp7		Real	24.0				
Constant							
▼ Return							
Analog In		Void					

Network 1:



Flow / PLC_1 [CPU 314C-2 PN/DP] / Program blocks


Analog Out [FC2]

Analog Out Properties							
General							
Name	Analog Out	Number	2	Type	FC	Language	LAD
Numbering	Automatic						
Information							
Title		Author		Comment		Family	
Version	0.1	User-defined ID					

Name	Data type	Offset	Default value	Comment
▼ Input				
mv	Real			
mvmin	Real			
mvmax	Real			
PQWmax	Real			
PQWmin	Real			
▼ Output				
PQWx	Int			
InOut				
▼ Temp				
temp3	Real	0.0		
temp4	Real	4.0		
temp5	Real	8.0		
temp6	Real	12.0		
temp7	Real	16.0		
temp8	Real	20.0		
temp9	DInt	24.0		
Constant				
▼ Return				
Analog Out	Void			

Network 1:

Network 1:




Flow / PLC_1 [CPU 314C-2 PN/DP] / Program blocks

PID [FC3]

PID Properties							
General							
Name	PID	Number	3	Type	FC	Language	LAD
Numbering	Automatic						
Information							
Title		Author		Comment		Family	
Version	0.1	User-defined ID					

Name	Data type	Offset	Default value	Comment
▼ Input				
kc	Real			
taui	Real			
taud	Real			
deltat	Real			
ek	Real			
ek-1	Real			
ek-2	Real			
mvk-1	Real			
▼ Output				
mvk	Real			
InOut				
▼ Temp				
temp1	Real	0.0		
temp2	Real	4.0		
temp3	Real	8.0		
temp4	Real	12.0		
temp5	Real	16.0		
temp6	Real	20.0		
temp7	Real	24.0		
temp8	Real	28.0		
temp9	Real	32.0		
temp10	Real	36.0		
temp11	Real	40.0		
temp12	Real	44.0		
temp13	Real	48.0		
temp14	Real	52.0		
temp15	Real	56.0		
Constant				
▼ Return				
PID	Void			

Network 1:



Totally Integrated Automation Portal

Flow / PLC_1 [CPU 314C-2 PN/DP] / Program blocks

Data_block_1 [DB1]

Data_block_1 Properties

General

Name	Data_block_1	Number	1	Type	DB	Language	DB
Numbering	Automatic						

Information

Title		Author		Comment		Family	
Version	0.1	User-defined ID					


Name	Data type	Offset	Start value	Retain	Accessi-ble from HMI/OPC UA/Web API	Writ-able from HMI/OPC UA/ Web API	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
▼ Static										
kc	Real	0.0	0.0	True	True	True	True	False		
taui	Real	4.0	0.0	True	True	True	True	False		
taud	Real	8.0	0.0	True	True	True	True	False		
mvk	Real	12.0	0.0	True	True	True	True	False		
mvk-1	Real	16.0	0.0	True	True	True	True	False		
ek	Real	20.0	0.0	True	True	True	True	False		
ek-1	Real	24.0	0.0	True	True	True	True	False		
ek-2	Real	28.0	0.0	True	True	True	True	False		
deltat	Real	32.0	0.0	True	True	True	True	False		

Flow / PLC_1 [CPU 314C-2 PN/DP] / Program blocks
CYC_INT5 [OB35]

CYC_INT5 Properties							
General							
Name	CYC_INT5	Number	35	Type	OB	Language	LAD
Numbering	Manual						
Information							
Title	"Cyclic Interrupt"	Author		Comment		Family	
Version	0.1	User-defined ID					

Name	Data type	Offset	Default value	Comment
▼ Temp				
OB35_EV_CLASS	Byte	0.0		Bits 0-3 = 1 (Coming event), Bits 4-7 = 1 (Event class 1)
OB35_STRT_INF	Byte	1.0		16#36 (OB 35 has started)
OB35_PRIORITY	Byte	2.0		Priority of OB Execution
OB35_OB_NUMBR	Byte	3.0		35 (Organization block 35, OB35)
OB35_RESERVED_1	Byte	4.0		Reserved for system
OB35_RESERVED_2	Byte	5.0		Reserved for system
OB35_PHASE_OFFSET	Word	6.0		Phase offset (msec)
OB35_RESERVED_3	Int	8.0		Reserved for system
OB35_EXC_FREQ	Int	10.0		Frequency of execution (msec)
OB35_DATE_TIME	Date_And_Time	12.0		Date and time OB35 started
Constant				

Network 1:



Flow / PLC_1 [CPU 314C-2 PN/DP] / Program blocks

I/O_FLT1 [OB82]

I/O_FLT1 Properties							
General							
Name	I/O_FLT1	Number	82	Type	OB	Language	STL
Numbering	Manual						
Information							
Title	"I/O Point Fault"	Author		Comment		Family	
Version	0.1	User-defined ID					

Name	Data type	Offset	Default value	Comment
▼ Temp				
OB82_EV_CLASS	Byte	0.0		16#39, Event class 3, Entering event state, Internal fault event
OB82_FLT_ID	Byte	1.0		16#XX, Fault identification code
OB82_PRIORITY	Byte	2.0		Priority of OB Execution
OB82_OB_NUMBR	Byte	3.0		82 (Organization block 82, OB82)
OB82_RESERVED_1	Byte	4.0		Reserved for system
OB82_IO_FLAG	Byte	5.0		Input (01010100), Output (01010101)
OB82_MDL_ADDR	Word	6.0		Base address of module with fault
OB82_MDL_DEFECT	Bool	8.0		Module defective
OB82_INT_FAULT	Bool	8.1		Internal fault
OB82_EXT_FAULT	Bool	8.2		External fault
OB82_PNT_INFO	Bool	8.3		Point information
OB82_EXT_VOLTAGE	Bool	8.4		External voltage low
OB82_FLD_CONNCTR	Bool	8.5		Field wiring connector missing
OB82_NO_CONFIG	Bool	8.6		Module has no configuration data
OB82_CONFIG_ERR	Bool	8.7		Module has configuration error
OB82_MDL_TYPE	Byte	9.0		Type of module
OB82_SUB_MDL_ERR	Bool	10.0		Sub-Module is missing or has error
OB82_COMM_FAULT	Bool	10.1		Communication fault
OB82_MDL_STOP	Bool	10.2		Module is stopped
OB82_WTCH_DOG_FLT	Bool	10.3		Watch dog timer stopped module
OB82_INT_PS_FLT	Bool	10.4		Internal power supply fault
OB82_PRIM_BATT_FLT	Bool	10.5		Primary battery is in fault
OB82_BCKUP_BATT_FLT	Bool	10.6		Backup battery is in fault
OB82_RESERVED_2	Bool	10.7		Reserved for system
OB82_RACK_FLT	Bool	11.0		Rack fault, only for bus interface module
OB82_PROC_FLT	Bool	11.1		Processor fault
OB82_EPROM_FLT	Bool	11.2		EPROM fault
OB82_RAM_FLT	Bool	11.3		RAM fault
OB82_ADU_FLT	Bool	11.4		ADU fault
OB82_FUSE_FLT	Bool	11.5		Fuse fault
OB82_HW_INTR_FLT	Bool	11.6		Hardware interrupt input in fault
OB82_RESERVED_3	Bool	11.7		Reserved for system
OB82_DATE_TIME	Date_And_Time	12.0		Date and time OB82 started
Constant				

Network 1: Call system diagnostics block

```
0001      CALL  "RSE_FB", "RSE_DB"
```

Flow / PLC_1 [CPU 314C-2 PN/DP] / Program blocks

I/O_FLT2 [OB83]

I/O_FLT2 Properties							
General							
Name	I/O_FLT2	Number	83	Type	OB	Language	STL
Numbering	Manual						
Information							
Title	"I/O Point Fault"	Author		Comment		Family	
Version	0.1	User-defined ID					
Name		Data type	Offset	Default value		Comment	
▼ Temp							
OB83_EV_CLASS		Byte	0.0			16#38/39, Event class 3, module inserted/removed (8/9)	
OB83_FLT_ID		Byte	1.0			16#XX, Fault identification code	
OB83_PRIORITY		Byte	2.0			Priority of OB Execution	
OB83_OB_NUMBR		Byte	3.0			83 (Organization block 83, OB83)	
OB83_RESERVED_1		Byte	4.0			Reserved for system	
OB83_MDL_ID		Byte	5.0			Input module (01010100), Output module (01010101)	
OB83_MDL_ADDR		Word	6.0			Base address of module with point fault	
OB83_RACK_NUM		Int	8.0			Number of rack that has module with point fault	
OB83_MDL_TYPE		Word	10.0			Module type with point fault	
OB83_DATE_TIME		Date_And_Time	12.0			Date and time OB83 started	
Constant							

Network 1: Call system diagnostics block

```
0001      CALL  "RSE_FB", "RSE_DB"
```


Flow / PLC_1 [CPU 314C-2 PN/DP] / Program blocks

RACK_FLT [OB86]

RACK_FLT Properties							
General							
Name	RACK_FLT	Number	86	Type	OB	Language	STL
Numbering	Manual						
Information							
Title	"Loss Of Rack Fault"	Author		Comment		Family	
Version	0.1	User-defined ID					
Name		Data type	Offset	Default value		Comment	
▼ Temp							
OB86_EV_CLASS		Byte	0.0			16#38/39 Event class 3	
OB86_FLT_ID		Byte	1.0			16#C1/C4/C5, Fault identification code	
OB86_PRIORITY		Byte	2.0			Priority of OB Execution	
OB86_OB_NUMBR		Byte	3.0			86 (Organization block 86, OB86)	
OB86_RESERVED_1		Byte	4.0			Reserved for system	
OB86_RESERVED_2		Byte	5.0			Reserved for system	
OB86_MDL_ADDR		Word	6.0			Base address of IM module in rack with fault	
▼ OB86_RACKS_FLTD		Array[0..31] of Bool	8.0			Racks in fault	
OB86_RACKS_FLTD[0]		Bool	8.0			Racks in fault	
OB86_RACKS_FLTD[1]		Bool	8.1			Racks in fault	
OB86_RACKS_FLTD[2]		Bool	8.2			Racks in fault	
OB86_RACKS_FLTD[3]		Bool	8.3			Racks in fault	
OB86_RACKS_FLTD[4]		Bool	8.4			Racks in fault	
OB86_RACKS_FLTD[5]		Bool	8.5			Racks in fault	
OB86_RACKS_FLTD[6]		Bool	8.6			Racks in fault	
OB86_RACKS_FLTD[7]		Bool	8.7			Racks in fault	
OB86_RACKS_FLTD[8]		Bool	9.0			Racks in fault	
OB86_RACKS_FLTD[9]		Bool	9.1			Racks in fault	
OB86_RACKS_FLTD[10]		Bool	9.2			Racks in fault	
OB86_RACKS_FLTD[11]		Bool	9.3			Racks in fault	
OB86_RACKS_FLTD[12]		Bool	9.4			Racks in fault	
OB86_RACKS_FLTD[13]		Bool	9.5			Racks in fault	
OB86_RACKS_FLTD[14]		Bool	9.6			Racks in fault	
OB86_RACKS_FLTD[15]		Bool	9.7			Racks in fault	
OB86_RACKS_FLTD[16]		Bool	10.0			Racks in fault	
OB86_RACKS_FLTD[17]		Bool	10.1			Racks in fault	
OB86_RACKS_FLTD[18]		Bool	10.2			Racks in fault	
OB86_RACKS_FLTD[19]		Bool	10.3			Racks in fault	
OB86_RACKS_FLTD[20]		Bool	10.4			Racks in fault	
OB86_RACKS_FLTD[21]		Bool	10.5			Racks in fault	
OB86_RACKS_FLTD[22]		Bool	10.6			Racks in fault	
OB86_RACKS_FLTD[23]		Bool	10.7			Racks in fault	
OB86_RACKS_FLTD[24]		Bool	11.0			Racks in fault	
OB86_RACKS_FLTD[25]		Bool	11.1			Racks in fault	
OB86_RACKS_FLTD[26]		Bool	11.2			Racks in fault	
OB86_RACKS_FLTD[27]		Bool	11.3			Racks in fault	
OB86_RACKS_FLTD[28]		Bool	11.4			Racks in fault	
OB86_RACKS_FLTD[29]		Bool	11.5			Racks in fault	
OB86_RACKS_FLTD[30]		Bool	11.6			Racks in fault	
OB86_RACKS_FLTD[31]		Bool	11.7			Racks in fault	
OB86_DATE_TIME		Date_And_Time	12.0			Date and time OB86 started	
Constant							

Network 1: Call system diagnostics block

0001CALL"RSE_FB", "RSE_DB"

Totally Integrated Automation Portal

Flow / PLC_1 [CPU 314C-2 PN/DP] / Program blocks

OBNL_FLT [OB85]

OBNL_FLT Properties

General

Name	OBNL_FLT	Number	85	Type	OB	Language	STL
Numbering	Manual						

Information

Title	"Organization Block (OB) Not Loaded Fault"	Author		Comment		Family	
Version	0.1	User-defined ID					

Name	Data type	Offset	Default value	Comment
▼ Temp				
OB85_EV_CLASS	Byte	0.0		16#35 Event class 3
OB85_FLT_ID	Byte	1.0		16#XX, Fault identification code
OB85_PRIORITY	Byte	2.0		Priority of OB Execution
OB85_OB_NUMBR	Byte	3.0		85 (Organization block 85, OB85)
OB85_RESERVED_1	Byte	4.0		Reserved for system
OB85_RESERVED_2	Byte	5.0		Reserved for system
OB85_RESERVED_3	Int	6.0		Reserved for system
OB85_ERR_EV_CLASS	Byte	8.0		Class of event causing error
OB85_ERR_EV_NUM	Byte	9.0		Number of event causing error
OB85_OB_PRIOR	Byte	10.0		Priority of OB causing error
OB85_OB_NUM	Byte	11.0		Number of OB causing error
OB85_DATE_TIME	Date_And_Time	12.0		Date and time OB85 started
Constant				

Network 1:

0001

L

b#16#A1

//

0002

L

#OB85_FLT_ID

0003

==I

0004

JC

K_OB

0005

L

b#16#A2

//

0006

==I

0007

JC

K_OB

0008

L

b#16#A3

//

0009

L

#OB85_FLT_ID

0010

==I

0011

JC

K_B

0012

JU

F_PA

0013

Network 2:

0001

K_OB:

JU

STOP

0002

JU

ENDE

0003

Network 3:

0001

K_B:

JU

STOP

0002

JU

ENDE

0003

Network 4:

0001

F_PA:

NOP

0

0002

JU

ENDE

0003

Network 5:

0001

STOP:

CALL

STP

0002

Network 6:

0001

0002

//

0003

0004

ENDE:

NOP

0

0005

Totally Integrated Automation Portal		
<div>Flow / PLC_1 [CPU 314C-2 PN/DP] / Program blocks / System blocks</div> <div>Program resources</div> <div>This folder is empty.</div>		

RSE_DIAGNOSTIC_STATUS_DB [DB127]

Name	Data type	Offset	Start value	Retain	Accessi- ble from HMI/OPC UA/Web API	Writ- able from HMI/ OPC UA/ Web API	Visible in HMI engi- neering	Setpoint	Supervi- sion	Comment
▼ Static										
▼ Directory	Struct	0.0		False	True	True	False	False		
D_Version	Word	0.0	WORD#16#0100	False	True	True	False	False		Version that supports RSE
D_pGlobalState	Word	2.0	WORD#16#0010	False	True	True	False	False		Byte offset to the start of the "GlobalState" section
D_pQuery	Word	4.0	WORD#16#0014	False	True	True	False	False		Byte offset to the start of the "Query" section
D_pComponent	Word	6.0	WORD#16#0020	False	True	True	False	False		Byte offset to the start of the "Component" section
D_pError	Word	8.0	WORD#16#0024	False	True	True	False	False		Byte offset to the start of the "Error" section
D_pState	Word	10.0	WORD#16#0028	False	True	True	False	False		Byte offset to the start of the "State" section
D_pAlarm	Word	12.0	WORD#16#005A	False	True	True	False	False		Byte offset to the start of the "Alarm" section
D_pSubComponent	Word	14.0	WORD#16#0082	False	True	True	False	False		Byte offset to the start of the "Sub-component" section
▼ GlobalState	Struct	16.0		False	True	True	False	False		
G_EventCount	Word	16.0	WORD#16#0000	False	True	True	False	False		ID of the last event (counter)
G_StartReporting	Bool	18.0	FALSE	False	True	True	False	False		Startup evaluation running
▼ Query	Struct	20.0		False	True	True	False	False		
Q_ClientID_User	DWord	20.0	DWORD#16#0000_0000	False	True	True	False	False		ID of the client
Q_ClientID_Intern	DWord	24.0	DWORD#16#0000_0000	False	True	True	False	False		ID of the client (internal)
Q_WithSubComponent	Bool	28.0	FALSE	False	True	True	False	False		With/without status of the underlying components (slower)
Q_SubComponentAlarm	Bool	28.1	FALSE	False	True	True	False	False		AS-iMaster gibt AS-iSlave Alarme zurück
Q_Reserved2	Bool	28.2	FALSE	False	True	True	False	False		Reserved
Q_Reserved3	Bool	28.3	FALSE	False	True	True	False	False		Reserved
Q_Reserved4	Bool	28.4	FALSE	False	True	True	False	False		Reserved
Q_Reserved5	Bool	28.5	FALSE	False	True	True	False	False		Reserved
Q_Reserved6	Bool	28.6	FALSE	False	True	True	False	False		Reserved
Q_Reserved7	Bool	28.7	FALSE	False	True	True	False	False		Reserved
Q_Start	Bool	29.0	FALSE	False	True	True	False	False		Start query
Q_Error	Byte	30.0	BYTE#16#00	False	True	True	False	False		Internal error in query
Q_Reserved8	Byte	31.0	BYTE#16#00	False	True	True	False	False		Reserved
▼ Component	Struct	32.0		False	True	True	False	False		
C_AddressMode	Byte	32.0	BYTE#16#00	False	True	True	False	False		Addressing mode of the module
C_Reserved1	Byte	33.0	BYTE#16#00	False	True	True	False	False		Reserved
C_ComponentID	Word	34.0	WORD#16#0000	False	True	True	False	False		Hardware ID of the component (internal)
▼ Error	Struct	36.0		False	True	True	False	False		
E_ErrorNo	Word	36.0	WORD#16#0000	False	True	True	False	False		Index of the requested/actual error
E_LastError	Bool	38.0	FALSE	False	True	True	False	False		TRUE, if E_ErrorNo contains the index of the last error, otherwise FALSE
▼ State	Struct	40.0		False	True	True	False	False		
S_Hierarchy	Byte	40.0	BYTE#16#00	False	True	True	False	False		Reserved
S_Periphery	Byte	41.0	BYTE#16#00	False	True	True	False	False		Reserved
S_SupFault	Bool	42.0	FALSE	False	True	True	False	False		The component is not obtainable
S_NotAvailable	Bool	42.1	FALSE	False	True	True	False	False		The component does not exist
S_Faulty	Bool	42.2	FALSE	False	True	True	False	False		The component is disrupted; the "Alarm" section is not empty
S_MoreErrors	Bool	42.3	FALSE	False	True	True	False	False		There are more errors than RSE can store.
S_Maintenance1	Bool	42.4	FALSE	False	True	True	False	False		Maintenance required is indicated
S_Maintenance2	Bool	42.5	FALSE	False	True	True	False	False		Maintenance demand is indicated
S_Deactivated	Bool	42.6	FALSE	False	True	True	False	False		The component was deactivated

RSE_FB [FB49]

Name	Data type	Offset	Default value	Accessible from HMI/OPC UA/Web API	Writ-able from HMI/OPC UA/Web API	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment
Input									
Output									
InOut									
▼ Static									
dDB127BGID	DWord	0.0	16#0	True	True	False	False		
dDB127Vorgang	Byte	4.0	16#0	True	True	False	False		
wMaxASISlave_a	Byte	5.0	16#0	True	True	False	False		
wMaxASISlave_b	Byte	6.0	16#0	True	True	False	False		
CyclesDB127WorkOn	Byte	7.0	16#0	True	True	False	False		
dDB127Stuffe	Byte	8.0	16#0	True	True	False	False		
w127Timer_a	Byte	9.0	BYTE#16#80	True	True	False	False		
w127Timer_b	Byte	10.0	BYTE#16#00	True	True	False	False		
tDB127TIAMS_a	Byte	11.0	16#0	True	True	False	False		
tDB127TIAMS_b	Byte	12.0	16#0	True	True	False	False		
tDB127TIAMS_c	Byte	13.0	16#0	True	True	False	False		
tDB127TIAMS_d	Byte	14.0	16#0	True	True	False	False		
tDB127TIACChannelExist_a	Byte	15.0	16#0	True	True	False	False		
tDB127TIACChannelExist_b	Byte	16.0	16#0	True	True	False	False		
tDB127TIACChannelExist_c	Byte	17.0	16#0	True	True	False	False		
tDB127TIACChannelExist_d	Byte	18.0	16#0	True	True	False	False		
tDB127TIACChannelOK_a	Byte	19.0	16#0	True	True	False	False		
tDB127TIACChannelOK_b	Byte	20.0	16#0	True	True	False	False		
tDB127TIACChannelOK_c	Byte	21.0	16#0	True	True	False	False		
tDB127TIACChannelOK_d	Byte	22.0	16#0	True	True	False	False		
tDB127Schleife_a	Byte	23.0	16#0	True	True	False	False		
tDB127Schleife_b	Byte	24.0	16#0	True	True	False	False		
tDB127LoggedOn	Bool	25.0	false	True	True	False	False		
xAnwenderMeldungsSignal	Bool	25.1	false	True	True	False	False		
xAnwenderKanalFehler	Bool	25.2	false	True	True	False	False		
bAnwenderIO_Flag	Byte	26.0	BYTE#16#54	True	True	False	False		
dMeldeNummer	DWord	28.0	16#0	True	True	False	False		
wAnwenderTextID	Word	32.0	16#0	True	True	False	False		
wAnwenderFehlerNummer	Word	34.0	16#0	True	True	False	False		
wAnwenderKanalNummer	Word	36.0	16#0	True	True	False	False		
wAnwenderHErrClass	Word	38.0	WORD#16#0000	True	True	False	False		
iAnwenderSFCRetVal	Int	40.0	0	True	True	False	False		
wRackEntry1	Word	42.0	WORD#16#02E0	True	True	False	False		
xFrei	Bool	44.0	TRUE	True	True	False	False		
xADA	Bool	44.1	false	True	True	False	False		
xWieder	Bool	44.2	false	True	True	False	False		
xGehend	Bool	44.3	false	True	True	False	False		
iFunktion	Byte	45.0	16#0	True	True	False	False		
iDaten	Byte	46.0	16#0	True	True	False	False		
wBGID_a	Byte	47.0	16#0	True	True	False	False		
wBGID_b	Byte	48.0	16#0	True	True	False	False		
bFill0	Byte	49.0	BYTE#16#00	True	True	False	False		
▼ LDB54	RALRM	50.0		True	True	False	True		
▼ Input									
MODE	Int	50.0	0	True	True	False	False		
F_ID	DWord	52.0	16#0	True	True	False	False		
MLEN	Int	56.0	0	True	True	False	False		

Totally Integrated Automation Portal										
Name	Data type	Offset	Default value	Accessible from HMI/OPC UA/Web API	Writ-able from HMI/OPC UA/W eb API	Visible in HMI engi-neering	Setpoint	Supervi-sion	Comment	
VFTable4_Fehlerklasse	Byte	165.0	BYTE#16#00	True	True	False	False			
VFTable4_TextListIndex	Byte	166.0	BYTE#16#03	True	True	False	False			
VFTable4_OC96Dat	Byte	167.0	BYTE#16#03	True	True	False	False			
VFTable5_Peri	Byte	168.0	BYTE#16#02	True	True	False	False			
VFTable5_Hiera	Byte	169.0	BYTE#16#12	True	True	False	False			
VFTable5_AsyncFct	Byte	170.0	BYTE#16#02	True	True	False	False			
VFTable5_AsyncDat	Byte	171.0	BYTE#16#05	True	True	False	False			
VFTable5_SyncFct	Byte	172.0	BYTE#16#01	True	True	False	False			
VFTable5_SyncDat	Byte	173.0	BYTE#16#04	True	True	False	False			
VFTable5_GehendDat	Byte	174.0	BYTE#16#07	True	True	False	False			
VFTable5_Fehlerklasse	Byte	175.0	BYTE#16#00	True	True	False	False			
VFTable5_TextListIndex	Byte	176.0	BYTE#16#03	True	True	False	False			
VFTable5_OC96Dat	Byte	177.0	BYTE#16#00	True	True	False	False			
▼ ADA	Array[1..5] of Byte	178.0		True	True	False	False			
ADA[1]	Byte	178.0	16#0	True	True	False	False			
ADA[2]	Byte	179.0	16#0	True	True	False	False			
ADA[3]	Byte	180.0	16#0	True	True	False	False			
ADA[4]	Byte	181.0	16#0	True	True	False	False			
ADA[5]	Byte	182.0	16#0	True	True	False	False			
▼ DiagPuffer	Array[1..272] of Byte	184.0		True	True	False	False			
DiagPuffer[1]	Byte	184.0	16#0	True	True	False	False			
DiagPuffer[2]	Byte	185.0	16#0	True	True	False	False			
DiagPuffer[3]	Byte	186.0	16#0	True	True	False	False			
DiagPuffer[4]	Byte	187.0	16#0	True	True	False	False			
DiagPuffer[5]	Byte	188.0	16#0	True	True	False	False			
DiagPuffer[6]	Byte	189.0	16#0	True	True	False	False			
DiagPuffer[7]	Byte	190.0	16#0	True	True	False	False			
DiagPuffer[8]	Byte	191.0	16#0	True	True	False	False			
DiagPuffer[9]	Byte	192.0	16#0	True	True	False	False			
DiagPuffer[10]	Byte	193.0	16#0	True	True	False	False			
DiagPuffer[11]	Byte	194.0	16#0	True	True	False	False			
DiagPuffer[12]	Byte	195.0	16#0	True	True	False	False			
DiagPuffer[13]	Byte	196.0	16#0	True	True	False	False			
DiagPuffer[14]	Byte	197.0	16#0	True	True	False	False			
DiagPuffer[15]	Byte	198.0	16#0	True	True	False	False			
DiagPuffer[16]	Byte	199.0	16#0	True	True	False	False			
DiagPuffer[17]	Byte	200.0	16#0	True	True	False	False			
DiagPuffer[18]	Byte	201.0	16#0	True	True	False	False			
DiagPuffer[19]	Byte	202.0	16#0	True	True	False	False			
DiagPuffer[20]	Byte	203.0	16#0	True	True	False	False			
DiagPuffer[21]	Byte	204.0	16#0	True	True	False	False			
DiagPuffer[22]	Byte	205.0	16#0	True	True	False	False			
DiagPuffer[23]	Byte	206.0	16#0	True	True	False	False			
DiagPuffer[24]	Byte	207.0	16#0	True	True	False	False			
DiagPuffer[25]	Byte	208.0	16#0	True	True	False	False			
DiagPuffer[26]	Byte	209.0	16#0	True	True	False	False			
DiagPuffer[27]	Byte	210.0	16#0	True	True	False	False			
DiagPuffer[28]	Byte	211.0	16#0	True	True	False	False			
DiagPuffer[29]	Byte	212.0	16#0	True	True	False	False			
DiagPuffer[30]	Byte	213.0	16#0	True	True	False	False			
DiagPuffer[31]	Byte	214.0	16#0	True	True	False	False			
DiagPuffer[32]	Byte	215.0	16#0	True	True	False	False			
DiagPuffer[33]	Byte	216.0	16#0	True	True	False	False			
DiagPuffer[34]	Byte	217.0	16#0	True	True	False	False			
DiagPuffer[35]	Byte	218.0	16#0	True	True	False	False			
DiagPuffer[36]	Byte	219.0	16#0	True	True	False	False			
DiagPuffer[37]	Byte	220.0	16#0	True	True	False	False			
DiagPuffer[38]	Byte	221.0	16#0	True	True	False	False			
DiagPuffer[39]	Byte	222.0	16#0	True	True	False	False			
DiagPuffer[40]	Byte	223.0	16#0	True	True	False	False			
DiagPuffer[41]	Byte	224.0	16#0	True	True	False	False			
DiagPuffer[42]	Byte	225.0	16#0	True	True	False	False			
DiagPuffer[43]	Byte	226.0	16#0	True	True	False	False			
DiagPuffer[44]	Byte	227.0	16#0	True	True	False	False			
DiagPuffer[45]	Byte	228.0	16#0	True	True	False	False			
DiagPuffer[46]	Byte	229.0	16#0	True	True	False	False			
DiagPuffer[47]	Byte	230.0	16#0	True	True	False	False			
DiagPuffer[48]	Byte	231.0	16#0	True	True	False	False			
DiagPuffer[49]	Byte	232.0	16#0	True	True	False	False			
DiagPuffer[50]	Byte	233.0	16#0	True	True	False	False			
DiagPuffer[51]	Byte	234.0	16#0	True	True	False	False			
DiagPuffer[52]	Byte	235.0	16#0	True	True	False	False			

Totally Integrated Automation Portal

Flow / PLC_1 [CPU 314C-2 PN/DP] / Program blocks / System blocks / System diagnostics

RSE_FC [FC49]

RSE_FC Properties

General

Name	RSE_FC	Number	49	Type	FC	Language	RSE
Numbering	Manual						

Information
































Title	Report System Error Diagnostic Block	Author	SIMATIC	Comment	This FC contains the code generated from STEP 7 Report System Errors.	Family	RSEDIAG
Version	1.0	User-defined ID	RSE				






























































































Name	Data type	Offset	Default value	Comment
Input				
Output				
InOut				
▼ Return				
RSE_FC	Void			

Totally Integrated Automation Portal		
<div>Flow / PLC_1 [CPU 314C-2 PN/DP]</div> <div>Technology objects</div> <div>This folder is empty.</div>		

Flow / PLC_1 [CPU 314C-2 PN/DP]

PLC tags

PLC tags						
Icon	Name	Data type	Address	Visible in HMI engineering	Accessible from HMI/OPC UA/Web API	Comment
	AUTO	Bool	%M66.0	True	True	
	CV	Real	%MD3	True	True	
	Lamp	Bool	%Q136.0	True	True	
	MV	Real	%MD7	True	True	
	MV_Man	Bool	%M2.0	True	True	
	Pump_Off	Bool	%M1.0	True	True	
	Pump_On	Bool	%M0.5	True	True	
	R_Pump	Bool	%M0.6	True	True	
	R_Pump_off	Bool	%M0.7	True	True	
	SP	Real	%MD11	True	True	
	Tag_1	Bool	%M0.0	True	True	
	Tag_2	Bool	%M100.0	True	True	
	Tag_3	Bool	%Q0.0	True	True	
	Tag_4	Bool	%M0.1	True	True	
	Tag_5	Int	%IW158	True	True	
	Tag_6	Int	%IW258	True	True	
	Tag_7	Bool	%M1.1	True	True	
	Tag_9	Int	%QW274	True	True	
	Tag_10	Bool	%M0.2	True	True	
	Tag_12	Bool	%M200.0	True	True	
	Tag_13	Bool	%Q0.1	True	True	
	Tag_16	Real	%MD54	True	True	
	Tag_18	Bool	%M0.3	True	True	
	Tag_19	Real	%MD15	True	True	
	Tag_20	Real	%MD50	True	True	
	Tag_21	Bool	%M0.4	True	True	
	Tag_22	Real	%MD60	True	True	
	Tag_23	Real	%MD56	True	True	
	Tag_24	Real	%MD64	True	True	
	V1	Bool	%Q136.2	True	True	
	V3	Bool	%Q136.1	True	True	

Totally Integrated Automation Portal																																																																																																																																																																																																																																											
<div>Flow / PLC_1 [CPU 314C-2 PN/DP] / PLC tags</div> <div>Default tag table [31]</div> <table><tr><th colspan="7">PLC tags</th></tr><tr><th>Icon</th><th>Name</th><th>Data type</th><th>Address</th><th>Visible in HMI engineering</th><th>Accessible from HMI/OPC UA/Web API</th><th>Comment</th></tr><tr><td></td><td>AUTO</td><td>Bool</td><td>%M66.0</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>CV</td><td>Real</td><td>%MD3</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>Lamp</td><td>Bool</td><td>%Q136.0</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>MV</td><td>Real</td><td>%MD7</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>MV_Man</td><td>Bool</td><td>%M2.0</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>Pump_Off</td><td>Bool</td><td>%M1.0</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>Pump_On</td><td>Bool</td><td>%M0.5</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>R_Pump</td><td>Bool</td><td>%M0.6</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>R_Pump_off</td><td>Bool</td><td>%M0.7</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>SP</td><td>Real</td><td>%MD11</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>Tag_1</td><td>Bool</td><td>%M0.0</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>Tag_2</td><td>Bool</td><td>%M100.0</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>Tag_3</td><td>Bool</td><td>%Q0.0</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>Tag_4</td><td>Bool</td><td>%M0.1</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>Tag_5</td><td>Int</td><td>%IW158</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>Tag_6</td><td>Int</td><td>%IW258</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>Tag_7</td><td>Bool</td><td>%M1.1</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>Tag_9</td><td>Int</td><td>%QW274</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>Tag_10</td><td>Bool</td><td>%M0.2</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>Tag_12</td><td>Bool</td><td>%M200.0</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>Tag_13</td><td>Bool</td><td>%Q0.1</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>Tag_16</td><td>Real</td><td>%MD54</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>Tag_18</td><td>Bool</td><td>%M0.3</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>Tag_19</td><td>Real</td><td>%MD15</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>Tag_20</td><td>Real</td><td>%MD50</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>Tag_21</td><td>Bool</td><td>%M0.4</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>Tag_22</td><td>Real</td><td>%MD60</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>Tag_23</td><td>Real</td><td>%MD56</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>Tag_24</td><td>Real</td><td>%MD64</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>V1</td><td>Bool</td><td>%Q136.2</td><td>True</td><td>True</td><td></td></tr><tr><td></td><td>V3</td><td>Bool</td><td>%Q136.1</td><td>True</td><td>True</td><td></td></tr></table>			PLC tags							Icon	Name	Data type	Address	Visible in HMI engineering	Accessible from HMI/OPC UA/Web API	Comment		AUTO	Bool	%M66.0	True	True			CV	Real	%MD3	True	True			Lamp	Bool	%Q136.0	True	True			MV	Real	%MD7	True	True			MV_Man	Bool	%M2.0	True	True			Pump_Off	Bool	%M1.0	True	True			Pump_On	Bool	%M0.5	True	True			R_Pump	Bool	%M0.6	True	True			R_Pump_off	Bool	%M0.7	True	True			SP	Real	%MD11	True	True			Tag_1	Bool	%M0.0	True	True			Tag_2	Bool	%M100.0	True	True			Tag_3	Bool	%Q0.0	True	True			Tag_4	Bool	%M0.1	True	True			Tag_5	Int	%IW158	True	True			Tag_6	Int	%IW258	True	True			Tag_7	Bool	%M1.1	True	True			Tag_9	Int	%QW274	True	True			Tag_10	Bool	%M0.2	True	True			Tag_12	Bool	%M200.0	True	True			Tag_13	Bool	%Q0.1	True	True			Tag_16	Real	%MD54	True	True			Tag_18	Bool	%M0.3	True	True			Tag_19	Real	%MD15	True	True			Tag_20	Real	%MD50	True	True			Tag_21	Bool	%M0.4	True	True			Tag_22	Real	%MD60	True	True			Tag_23	Real	%MD56	True	True			Tag_24	Real	%MD64	True	True			V1	Bool	%Q136.2	True	True			V3	Bool	%Q136.1	True	True			
PLC tags																																																																																																																																																																																																																																											
Icon	Name	Data type	Address	Visible in HMI engineering	Accessible from HMI/OPC UA/Web API	Comment																																																																																																																																																																																																																																					
	AUTO	Bool	%M66.0	True	True																																																																																																																																																																																																																																						
	CV	Real	%MD3	True	True																																																																																																																																																																																																																																						
	Lamp	Bool	%Q136.0	True	True																																																																																																																																																																																																																																						
	MV	Real	%MD7	True	True																																																																																																																																																																																																																																						
	MV_Man	Bool	%M2.0	True	True																																																																																																																																																																																																																																						
	Pump_Off	Bool	%M1.0	True	True																																																																																																																																																																																																																																						
	Pump_On	Bool	%M0.5	True	True																																																																																																																																																																																																																																						
	R_Pump	Bool	%M0.6	True	True																																																																																																																																																																																																																																						
	R_Pump_off	Bool	%M0.7	True	True																																																																																																																																																																																																																																						
	SP	Real	%MD11	True	True																																																																																																																																																																																																																																						
	Tag_1	Bool	%M0.0	True	True																																																																																																																																																																																																																																						
	Tag_2	Bool	%M100.0	True	True																																																																																																																																																																																																																																						
	Tag_3	Bool	%Q0.0	True	True																																																																																																																																																																																																																																						
	Tag_4	Bool	%M0.1	True	True																																																																																																																																																																																																																																						
	Tag_5	Int	%IW158	True	True																																																																																																																																																																																																																																						
	Tag_6	Int	%IW258	True	True																																																																																																																																																																																																																																						
	Tag_7	Bool	%M1.1	True	True																																																																																																																																																																																																																																						
	Tag_9	Int	%QW274	True	True																																																																																																																																																																																																																																						
	Tag_10	Bool	%M0.2	True	True																																																																																																																																																																																																																																						
	Tag_12	Bool	%M200.0	True	True																																																																																																																																																																																																																																						
	Tag_13	Bool	%Q0.1	True	True																																																																																																																																																																																																																																						
	Tag_16	Real	%MD54	True	True																																																																																																																																																																																																																																						
	Tag_18	Bool	%M0.3	True	True																																																																																																																																																																																																																																						
	Tag_19	Real	%MD15	True	True																																																																																																																																																																																																																																						
	Tag_20	Real	%MD50	True	True																																																																																																																																																																																																																																						
	Tag_21	Bool	%M0.4	True	True																																																																																																																																																																																																																																						
	Tag_22	Real	%MD60	True	True																																																																																																																																																																																																																																						
	Tag_23	Real	%MD56	True	True																																																																																																																																																																																																																																						
	Tag_24	Real	%MD64	True	True																																																																																																																																																																																																																																						
	V1	Bool	%Q136.2	True	True																																																																																																																																																																																																																																						
	V3	Bool	%Q136.1	True	True																																																																																																																																																																																																																																						

Totally Integrated Automation Portal		
<div>Flow / PLC_1 [CPU 314C-2 PN/DP]</div> <div>PLC data types</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal												
<div>Flow / PLC_1 [CPU 314C-2 PN/DP] / Watch and force tables</div> <div>Force table</div> <table><tr><th>Name</th><th>Address</th><th>Display format</th><th>Force value</th><th>Comment</th></tr><tr><td colspan="5"></td></tr></table>			Name	Address	Display format	Force value	Comment					
Name	Address	Display format	Force value	Comment								

Totally Integrated Automation Portal

Flow / PLC_1 [CPU 314C-2 PN/DP] / Watch and force tables

Watch table_1

Name	Address	Display format	Modify value	Comment
"SP"	%MD11	Floating-point number	2.0	
"MV"	%MD7	Floating-point number	0.0	
"CV"	%MD3	Floating-point number		
"Data_block_1".kc	%DB1.DBDO	Floating-point number	2.575	
"Data_block_1".taui	%DB1.DBDO4	Floating-point number	0.01	
"Data_block_1".taud	%DB1.DBDO8	Floating-point number	0.23	
"Data_block_1".deltat	%DB1.DBDO32	Floating-point number	0.5	
"Data_block_1".mvk	%DB1.DBDO12	Floating-point number		
"Pump_On"	%M0.5	Bool	TRUE	
"AUTO"	%M66.0	Bool	FALSE	

Totally Integrated Automation Portal		
<div>Flow / PLC_1 [CPU 314C-2 PN/DP] / PLC supervisions & alarms</div> <div>PLC alarms</div> <div><div>PLC alarms</div><div>No entries</div></div>		

Totally Integrated Automation Portal		
<div>Flow / PLC_1 [CPU 314C-2 PN/DP] / PLC supervisions & alarms</div> <div>User diagnostics alarms</div> <div><div>User diagnostics alarms</div><div>No entries</div></div>		

Totally Integrated Automation Portal			
Flow / PLC_1 [CPU 314C-2 PN/DP] / PLC supervisions & alarms			
System alarms			
System alarms			
Name	SDIAG_ALCAT_CH_MSG_0001	Type	Alarm_s
ID	1610619737	Range	16
Location	PLC_1	Alarm text	Fault: @1W%t#1K@ - @5W%t#1K@ on @2W%1d@ > Component: @6W%t#276K@ / @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ > Path: @6W%t#266K@ / @6W%t#267K@ / @6W%t#268K@.@6W%t#269K@ / @2W%1d@ HW_ID= @6W%t#264K@ @6W%t#262K@ @6W%t#263K@
Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@	Alarm class	No Acknowledgement
Acknowledgment	False	Priority	0
Display class	0	Report	False
Created by	Report system errors	Date created	10/14/2022 3:59 PM
Last change	10/16/2022 11:35 AM	Group ID	0
Additional text 1		Additional text 2	
Additional text 3		Additional text 4	
Additional text 5		Additional text 6	
Additional text 7		Additional text 8	
Additional text 9			
Name	SDIAG_ALCAT_MODUL_MSG_0003	Type	Alarm_s
ID	1610619739	Range	20
Location	PLC_1	Alarm text	Fault: @1W%t#1K@ - @5W%t#1K@ S7300/ET200M station_1 > Component: @6W%t#276K@ / @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ > Path: @6W%t#266K@ / @6W%t#267K@ / @6W%t#268K@.@6W%t#269K@ HW_ID= @6W%t#264K@ @6W%t#262K@ @6W%t#263K@
Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@	Alarm class	No Acknowledgement
Acknowledgment	False	Priority	0
Display class	0	Report	False
Created by	Report system errors	Date created	10/14/2022 3:59 PM
Last change	10/16/2022 11:35 AM	Group ID	0
Additional text 1		Additional text 2	
Additional text 3		Additional text 4	
Additional text 5		Additional text 6	
Additional text 7		Additional text 8	
Additional text 9			
Name	SDIAG_ALCAT_RACK_MSG_0004	Type	Alarm_s
ID	1610619740	Range	1
Location	PLC_1	Alarm text	Fault: @1W%t#1K@ - @5W%t#1K@ S7300/ET200M station_1 > Component: @6W%t#276K@ / @6W%t#257K@ > Path: @6W%t#266K@ / @6W%t#267K@ HW_ID= @6W%t#264K@ @6W%t#262K@ @6W%t#263K@
Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@	Alarm class	No Acknowledgement
Acknowledgment	False	Priority	0
Display class	0	Report	False
Created by	Report system errors	Date created	10/14/2022 3:59 PM
Last change	10/16/2022 11:35 AM	Group ID	0
Additional text 1		Additional text 2	
Additional text 3		Additional text 4	
Additional text 5		Additional text 6	
Additional text 7		Additional text 8	
Additional text 9			
Name	Module_message_0076	Type	Alarm_s
ID	1610619854	Range	16
Location	PLC_1	Alarm text	Fault: @1W%t#6K@ - @5W%t#6K@ S7300/ET200M station_1 > Component: @6W%t#276K@ / @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ > Path: @6W%t#266K@ / @6W%t#267K@ / @6W%t#268K@.@6W%t#269K@ HW_ID= @6W%t#264K@ @6W%t#262K@ @6W%t#263K@
Info text	Short name: @6W%t#260K@ Order number: @6W%t#265K@	Alarm class	No Acknowledgement
Acknowledgment	False	Priority	0
Display class	0	Report	False
Created by	Report system errors	Date created	10/14/2022 3:59 PM
Last change	10/16/2022 11:35 AM	Group ID	0
Additional text 1		Additional text 2	
Additional text 3		Additional text 4	
Additional text 5		Additional text 6	
Additional text 7		Additional text 8	
Additional text 9			
Name	SDIAG_ALCAT_CH_ERR_MSG_0115	Type	Alarm_s
ID	1610620013	Range	16
Location	PLC_1	Alarm text	Fault: @1W%t#6K@ - @5W%t#6K@ on @2W%1d@ > Component: @6W%t#276K@ / @6W%t#257K@ / @6W%t#258K@.@6W%t#259K@ > Path: @6W%t#266K@ / @6W%t#267K@ / @6W%t#268K@.@6W%t#269K@ / @2W%1d@ HW_ID= @6W%t#264K@ @6W%t#262K@ @6W%t#263K@

Totally Integrated Automation Portal		
<div>Flow / PLC_1 [CPU 314C-2 PN/DP]</div> <div>PLC alarm text lists</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Flow / PLC_1 [CPU 314C-2 PN/DP] / Local modules</div> <div>PS 307 2A_1</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
--------------------------------------	--	--

Flow / PLC_1 [CPU 314C-2 PN/DP] / Local modules

PLC_1 [CPU 314C-2 PN/DP]

PLC_1

General

Name	PLC_1	Author	home	Comment	
Rack	0	Slot	2		

General\Catalog information

Short designation	CPU 314C-2 PN/DP	Description	Work memory 192KB; 0.6ms/1000 instructions; DI24/DO16; AI5/AO2 integrated; 4 pulse outputs (2.5kHz); 4 channels counting and measuring with 24 V (60kHz) incremental encoders; integrated positioning function; PROFINET interface and 2 Ports; MRP; PROFINET CBA; PROFINET CBA Proxy; TCP/IP transport protocol; combined MPI/DP interface (MPI or DP master or DP slave); multi-tier configuration up to 31 modules; capable of sending and receiving in direct data exchange; constant bus cycle time; routing; firm-ware V3.3	Article number	6ES7 314-6EH04-0AB0
Firmware version	V3.3				

General\Identification & Maintenance

Plant designation		Location identifier			
-------------------	--	---------------------	--	--	--

MPI/DP interface [X1]\General

Name	MPI/DP interface_1	Comment			
------	--------------------	---------	--	--	--

MPI/DP interface [X1]\MPI address\Interface networked with

Subnet:	Not networked				
---------	---------------	--	--	--	--

MPI/DP interface [X1]\MPI address\Parameters

Interface type:	Mpi	Address:	2	Highest address:	
Transmission speed:					

MPI/DP interface [X1]\Time-of-day synchronization\SIMATIC mode

Type of synchroniza-tion	None	Time interval	None		
--------------------------	------	---------------	------	--	--

MPI/DP interface [X1]\Diagnostics addresses\Diagnostics addresses

Start address	2047				
---------------	------	--	--	--	--

PROFINET interface [X2]\General

Name	PROFINET interface_1	Comment			
------	----------------------	---------	--	--	--

PROFINET interface [X2]\Ethernet addresses\Interface networked with

Subnet:	Not connected				
---------	---------------	--	--	--	--

PROFINET interface [X2]\Ethernet addresses\IP protocol

IP configuration	Set IP address in the project	IP address:	192.168.0.1	Subnet mask:	255.255.255.0
Use router	False				

PROFINET interface [X2]\Ethernet addresses\PROFINET

PROFINET device name is set directly at the device	False	Generate PROFINET device name auto-matically	True	PROFINET device name:	plc_1
Converted name:	plcxb1d0ed	Device number:	0		

PROFINET interface [X2]\Time-of-day synchronization\NTP mode

Enable time synchro-nization via NTP serv-er	False		IP addresses	Server 1	0.0.0.0
Server 2	0.0.0.0	Server 3	0.0.0.0	Server 4	0.0.0.0
Update interval	10s				

PROFINET interface [X2]\Operating mode

IO controller	True	IO system		Device number	0
IO device	False				

PROFINET interface [X2]\Advanced options\Interface options

Call the user program if communication er-rors occur	False	Support device re-placement without exchangeable medi-um	True	Use IEC V2.2 LLDP mode	True
Keep-Alive connec-tion monitoring:	30s				

PROFINET interface [X2]\Advanced options\Real time settings\IO communication

Send clock:	1.000ms				
-------------	---------	--	--	--	--

PROFINET interface [X2]\Advanced options\Real time settings\Synchronization

RT class:	RT,IRT				
-----------	--------	--	--	--	--

PROFINET interface [X2]\Advanced options\Real time settings\Real time options


Calculated bandwidth for cyclic IO data:	0.000ms	Calculated bandwidth for cyclic IO data:	0.000%		
--	---------	--	--------	--	--


PROFINET interface [X2]\Advanced options\Port [X2 P1 R]\General

Name	Port_1	Comment			
------	--------	---------	--	--	--

PROFINET interface [X2]\Advanced options\Port [X2 P1 R]\Port interconnection\Local port:

Local port:	PLC_1\PROFINET interface_1 [X2]\Port_1 [X2 P1 R]	Medium:	Copper	Cable name:	---
-------------	--	---------	--------	-------------	-----



Totally Integrated Automation Portal						
PROFINET interface [X2]\Advanced options\Port [X2 P1 R]\Port interconnection\Partner port:						
	Monitoring of partner port is not possible		Partner port:	Any partner		
PROFINET interface [X2]\Advanced options\Port [X2 P1 R]\Port options\Activate						
Activate this port for use	True					
PROFINET interface [X2]\Advanced options\Port [X2 P1 R]\Port options\Connection						
Transmission rate / duplex:	Automatic		Monitor	False	Enable autonegotiation	True
PROFINET interface [X2]\Advanced options\Port [X2 P1 R]\Port options\Boundaries						
End of detection of accessible devices	False		End of topology discovery	False	End of the sync domain	False
PROFINET interface [X2]\Advanced options\Port [X2 P1 R]\Diagnostics addresses\Diagnostics addresses						
Start address	2045					
PROFINET interface [X2]\Advanced options\Port [X2 P2 R]\General						
Name	Port_2		Comment			
PROFINET interface [X2]\Advanced options\Port [X2 P2 R]\Port interconnection\Local port:						
Local port:	PLC_1\PROFINET interface_1 [X2]\Port_2 [X2 P2 R]		Medium:	Copper	Cable name:	---
						
PROFINET interface [X2]\Advanced options\Port [X2 P2 R]\Port interconnection\Partner port:						
	Monitoring of partner port is not possible		Partner port:	Any partner		
PROFINET interface [X2]\Advanced options\Port [X2 P2 R]\Port options\Activate						
Activate this port for use	True					
PROFINET interface [X2]\Advanced options\Port [X2 P2 R]\Port options\Connection						
Transmission rate / duplex:	Automatic		Monitor	False	Enable autonegotiation	True
PROFINET interface [X2]\Advanced options\Port [X2 P2 R]\Port options\Boundaries						
End of detection of accessible devices	False		End of topology discovery	False	End of the sync domain	False
PROFINET interface [X2]\Advanced options\Port [X2 P2 R]\Diagnostics addresses\Diagnostics addresses						
Start address	2044					
PROFINET interface [X2]\Diagnostics addresses\Diagnostics addresses						
Start address	2046					
DI 24/DO 16\General						
Name	DI 24/DO 16_1		Comment			
DI 24/DO 16\General\Catalog information						
Short designation	DI 24/DO 16		Description	Digital input/output DI24 + DO16		
DI 24/DO 16\Inputs\Channel group 0 - 3						
Input delay	3ms					
DI 24/DO 16\Inputs\Channel group 0 - 3\Hardware interrupt channel 0\Rising (positive) edge						
Rising (positive) edge	False					
DI 24/DO 16\Inputs\Channel group 0 - 3\Hardware interrupt channel 0\Falling (negative) edge						
Falling (negative) edge	False					
DI 24/DO 16\Inputs\Channel group 0 - 3\Hardware interrupt channel 1\Rising (positive) edge						
Rising (positive) edge	False					
DI 24/DO 16\Inputs\Channel group 0 - 3\Hardware interrupt channel 1\Falling (negative) edge						
Falling (negative) edge	False					
DI 24/DO 16\Inputs\Channel group 0 - 3\Hardware interrupt channel 2\Rising (positive) edge						
Rising (positive) edge	False					
DI 24/DO 16\Inputs\Channel group 0 - 3\Hardware interrupt channel 2\Falling (negative) edge						
Falling (negative) edge	False					
DI 24/DO 16\Inputs\Channel group 0 - 3\Hardware interrupt channel 3\Rising (positive) edge						
Rising (positive) edge	False					
DI 24/DO 16\Inputs\Channel group 0 - 3\Hardware interrupt channel 3\Falling (negative) edge						
Falling (negative) edge	False					
DI 24/DO 16\Inputs\Channel group 4 - 7						
Input delay	3ms					
DI 24/DO 16\Inputs\Channel group 4 - 7\Hardware interrupt channel 4\Rising (positive) edge						
Rising (positive) edge	False					
DI 24/DO 16\Inputs\Channel group 4 - 7\Hardware interrupt channel 4\Falling (negative) edge						
Falling (negative) edge	False					
DI 24/DO 16\Inputs\Channel group 4 - 7\Hardware interrupt channel 5\Rising (positive) edge						
Rising (positive) edge	False					
DI 24/DO 16\Inputs\Channel group 4 - 7\Hardware interrupt channel 5\Falling (negative) edge						
Falling (negative) edge	False					
DI 24/DO 16\Inputs\Channel group 4 - 7\Hardware interrupt channel 6\Rising (positive) edge						
Rising (positive) edge	False					
DI 24/DO 16\Inputs\Channel group 4 - 7\Hardware interrupt channel 6\Falling (negative) edge						
Falling (negative) edge	False					
DI 24/DO 16\Inputs\Channel group 4 - 7\Hardware interrupt channel 7\Rising (positive) edge						
Rising (positive) edge	False					

Totally Integrated Automation Portal						
DI 24/DO 16\Inputs\Channel group 20 - 23\Hardware interrupt channel 23\Falling (negative) edge						
Falling (negative) edge	False					
DI 24/DO 16\I/O addresses\Input addresses						
Start address	136.0		End address	138.7		Process image OB1-PI
Interrupt OB number	40					
DI 24/DO 16\I/O addresses\Output addresses						
Start address	136.0		End address	137.7		Process image OB1-PI
AI 5/AO 2\General						
Name	AI 5/AO 2_1		Comment			
AI 5/AO 2\General\Catalog information						
Short designation	AI 5/AO 2		Description	Analog I/O AI5 + AO2		
AI 5/AO 2\Inputs						
Temperature unit	Degrees Celsius					
AI 5/AO 2\Inputs\Channel 0						
Measurement type	Voltage		Measuring range	+/- 10V		Interference frequency suppression 50Hz
Integration time	20ms					
AI 5/AO 2\Inputs\Channel 1						
Measurement type	Voltage		Measuring range	+/- 10V		Interference frequency suppression 50Hz
Integration time	20ms					
AI 5/AO 2\Inputs\Channel 2						
Measurement type	Voltage		Measuring range	+/- 10V		Interference frequency suppression 50Hz
Integration time	20ms					
AI 5/AO 2\Inputs\Channel 3						
Measurement type	Voltage		Measuring range	+/- 10V		Interference frequency suppression 50Hz
Integration time	20ms					
AI 5/AO 2\Inputs\Channel 4						
Measurement type	Resistor (2-wire)		Measuring range	600 ohmsOhm		
AI 5/AO 2\Outputs\Output 0						
Output type	Voltage		Output range	+/- 10V		
AI 5/AO 2\Outputs\Output 1						
Output type	Voltage		Output range	+/- 10V		
AI 5/AO 2\I/O addresses\Input addresses						
Start address	800		End address	809		Process image None
Interrupt OB number	40					
AI 5/AO 2\I/O addresses\Output addresses						
Start address	800		End address	803		Process image None
Count\General						
Name	Count_1		Comment			
Count\General\Catalog information						
Short designation	Count		Description	4 channels; counting and frequency measurement at 60 kHz, pulse width modulation at 2.5 kHz switching frequency		
Count\Interrupt selection						
Interrupt selection	None					
Count\Channel 0						
Operating mode	Not configured					
Count\Channel 1						
Operating mode	Not configured					
Count\Channel 2						
Operating mode	Not configured					
Count\Channel 3						
Operating mode	Not configured					
Count\I/O addresses\Input addresses						
Start address	816		End address	831		Process image None
Interrupt OB number	40					
Count\I/O addresses\Output addresses						
Start address	816		End address	831		Process image None
Positioning\General						
Name	Positioning_1		Comment			
Positioning\General\Catalog information						
Short designation	Positioning		Description	1 channel; positioning with analog and digital outputs, counting frequency		
Positioning\Interrupt selection						
Interrupt selection	None					
Positioning\Channel 0						
Operating mode	None					
Positioning\I/O addresses\Input addresses						
Start address	832		End address	847		Process image None
Interrupt OB number	40					
Positioning\I/O addresses\Output addresses						
Start address	832		End address	847		Process image None
Startup						
Startup if preset configuration does not match actual configuration	True		Startup after POWER ON	Warm restart		
Startup\Monitoring time for						
Ready message from modules	650x 100 ms		Parameter transfer to modules	100x 100 ms		

Totally Integrated Automation Portal						
Cycle						
Cycle monitoring time	150ms	Cycle load due to communication	20%	Size of the process image input:	256	
Size of the process image output:	256	OB85 call if I/O access error occurs	No OB85 call			
Clock memory						
Clock memory	False	Memory byte	0			
Interrupts\Isochronous mode interrupts						
OB number	Priority	Distributed I/O	Process image partition(s)	Delay time (ms)	Automatic setting	
OB 61	25	0		0.000	True	
Interrupts\Isochronous mode interrupts\OB 61						
Application cycle:	0ms	Delay time:	0.000ms	Automatic setting	True	
Distributed I/O:	0					
Interrupts\Isochronous mode interrupts\OB 61\Process image partition						
PIP:						
Interrupts\Time-of-day interrupts\						
OB number	Priority	Active	Execution	Start time		
OB 10	2	False	None	1994-01-01 00:00:00.000		
Interrupts\Time-delay interrupts\						
OB number	Priority			Process image partition(s)		
OB 20	3			None		
OB 21	4			None		
Interrupts\Cyclic interrupts\						
OB number	Priority	Execution	Phase offset	Unit		
OB 32	9	1000	0	ms		
OB 33	10	500	0	ms		
OB 34	11	200	0	ms		
OB 35	12	500	0	ms		
Interrupts\Hardware interrupts\						
OB number				Priority		
OB 40				16		
Interrupts\Interrupts for DPV1\						
OB number				Priority		
OB 55				2		
OB 56				2		
OB 57				2		
Interrupts\Asynchronous error interrupts\						
OB number				Priority		
OB 82				26		
OB 83				26		
OB 85				26		
OB 86				26		
OB 87				26		
Retentive memory						
Number of memory bytes starting at MB 0	16	Number of S7 timers starting at T 0	0	Number of S7 counters starting at C 0	8	
Protection						
Password		Confirm password				
Protection\						
Level of protection	No protection					
Protection\ \Can be canceled with password						
Can be canceled with password	False					
Diagnostics system						
Report cause of STOP	True	Number of alarms in the diagnostics buffer	10			
System diagnostics\General						
Activate system diagnostics for this device	True					
System diagnostics\Diagnostic support						
Query for status "activated/deactivated" after startup	False	Send alarm if status changes from/to activated or deactivated	False			
Additional blocks for diagnostic data	Create	Block name		Block number		
Diagnostic status DB:	True	RSE_DIAGNOSTIC_STATUS_DB		127		
System diagnostics\System diagnostic blocks						
System diagnostic blocks	Block name			Block number		
FB:	RSE_FB			49		
DB:	RSE_DB			49		
Global DB:	RSE_GLOBAL_DB			50		
FC:	RSE_FC			49		
Time of day						
Correction factor	0ms					
Time of day\Synchronization on PLC						
Type of synchronization	None	Time interval	None			
Time of day\Synchronization on MPI						
Type of synchronization	None	Time interval	None			
Web server\General						
Activate web server on this module	False	Permit access only with HTTPS	False			
Web server\Automatic update						
Enable automatic update	False	Update interval	0s			

Totally Integrated Automation Portal

Web serverLanguages

Active	Web server language	Assign project language
False	German	None
False	English	None
False	French	None
False	Spanish	None
False	Italian	None
False	Japanese	None
False	Chinese (simplified)	None

Web serverUser management

User name	User rights
Everybody	

Web serverUser-defined web pages

Application name	HTML source path	Default HTML page	Files with dynamic content	Web DB number	Fragment DB number
		index.htm	.htm;.html	333	334

Web serverText_Display_classes_of_messages

Display class	Active
0	True
1	True
2	True
3	True
4	True
5	True
6	True
7	True
8	True
9	True
10	True
11	True
12	True
13	True
14	True
15	True
16	True

Connection resources

PG communication:	1	OP communication:	1	S7 basic communication:	0
S7 communication:	0	Maximum number of S7 connection resources:	12		

Overview of addressesOverview of addressesOverview of addresses

Inputs	True	Outputs	True	Address gaps	False
Slot	True				

Type	Addr. from	Addr. to	Module	PIP	Device name	Device number	Size	Master / IO system	Rack	Slot
I*	2047	2047	MPI/DP interface_1	---	PLC_1 [CPU 314C-2 PN/DP]	-	0 Bits	-	0	2 X1
I*	2046	2046	PROFINET interface_1	---	PLC_1 [CPU 314C-2 PN/DP]	-	0 Bits	-	0	2 X2
I*	2045	2045	Port_1	---	PLC_1 [CPU 314C-2 PN/DP]	-	0 Bits	-	0	2 X2 P1 R
I*	2044	2044	Port_2	---	PLC_1 [CPU 314C-2 PN/DP]	-	0 Bits	-	0	2 X2 P2 R
I	136	138	DI 24/DO 16_1	OB1-PI	PLC_1 [CPU 314C-2 PN/DP]	-	3 Bytes	-	0	2 5
O	136	137	DI 24/DO 16_1	OB1-PI	PLC_1 [CPU 314C-2 PN/DP]	-	2 Bytes	-	0	2 5
I	800	809	AI 5/AO 2_1	OB1-PI	PLC_1 [CPU 314C-2 PN/DP]	-	10 Bytes	-	0	2 6
O	800	803	AI 5/AO 2_1	OB1-PI	PLC_1 [CPU 314C-2 PN/DP]	-	4 Bytes	-	0	2 6
I	816	831	Count_1	OB1-PI	PLC_1 [CPU 314C-2 PN/DP]	-	16 Bytes	-	0	2 7
O	816	831	Count_1	OB1-PI	PLC_1 [CPU 314C-2 PN/DP]	-	16 Bytes	-	0	2 7
I	832	847	Positioning_1	OB1-PI	PLC_1 [CPU 314C-2 PN/DP]	-	16 Bytes	-	0	2 8
O	832	847	Positioning_1	OB1-PI	PLC_1 [CPU 314C-2 PN/DP]	-	16 Bytes	-	0	2 8
I	256	259	AI 2x12BIT_1	OB1-PI	PLC_1 [CPU 314C-2 PN/DP]	-	4 Bytes	-	0	4
O	272	275	AO 2x12BIT_1	OB1-PI	PLC_1 [CPU 314C-2 PN/DP]	-	4 Bytes	-	0	5

Totally Integrated Automation Portal		
--------------------------------------	--	--

Flow / PLC_1 [CPU 314C-2 PN/DP] / Local modules

AI 2x12BIT_1

AI 2x12BIT_1

General

Name	AI 2x12BIT_1	Author	home	Comment	
Rack	0	Slot	4		

General\Catalog information

Short designation	AI 2x12BIT	Description	Analog input module AI2 x U/I/R/RTD/TC; 14 bits of resolution; accuracy appr. 1%; grouping 2; common mode voltage appr. 2.3VDC; configurable diagnostics; hardware interrupts; 20-pin front connector		Article number	6ES7 331-7KB02-0AB0
Firmware version						

Inputs\General\Diagnostics

Diagnostics interrupt	Deactivated	
-----------------------	-------------	--

Inputs\General\Hardware interrupts

Hardware interrupt when limit violated	Deactivated	RidPrefixHwlInterrupt	49152	Event name:	0
Hardware interrupt:	0	Hardware interrupt	Hardware interrupt	HardwareInterruptChannelForModule	32768
HardwareInterruptEventIdNull	0				

Inputs\Channel 0 - 1\Diagnostics

Group diagnostics	Deactivated	Check for wire break	Deactivated	
-------------------	-------------	----------------------	-------------	--

Inputs\Channel 0 - 1\Measuring

Measurement type	Voltage	Measuring range	+/- 10 V	Position of measuring range selection module	[B]
Interference frequency suppression	50Hz	Integration time	20ms		

Inputs\Channel 0 - 1\Trigger for hardware interrupt\Channel 0

High limit		Low limit		
------------	--	-----------	--	--

I/O addresses\Input addresses

Start address	256	End address	259	Process image	None
Interrupt OB number	40				

Totally Integrated Automation Portal		
--------------------------------------	--	--

Flow / PLC_1 [CPU 314C-2 PN/DP] / Local modules

AO 2x12BIT_1

AO 2x12BIT_1

General

Name	AO 2x12BIT_1	Author	home	Comment	
Rack	0	Slot	5		

General\Catalog information

Short designation	AO 2x12BIT	Description	Analog output module AO2 x U/I 12bits of resolution; accuracy appr. 0.6%; grouping 2; common mode voltage appr. 3VDC; configurable diagnostics; configurable substitute value for output; 20-pin front connector		Article number	6ES7 332-5HB01-0AB0
Firmware version						

Outputs\Enable

Diagnostics interrupt	Deactivated	
-----------------------	-------------	--

Outputs\Channel 0\Diagnostics

Group diagnostics	Deactivated	
-------------------	-------------	--

Outputs\Channel 0\Output

Output type	Current	Output range	4 to 20 mA	Reaction to CPU STOP	Output has no current or voltage
Substitute value					

Outputs\Channel 1\Diagnostics

Group diagnostics	Deactivated	
-------------------	-------------	--

Outputs\Channel 1\Output

Output type	Current	Output range	4 to 20 mA	Reaction to CPU STOP	Output has no current or voltage
Substitute value					

I/O addresses\Output addresses

Start address	272	End address	275	Process image	None
---------------	-----	-------------	-----	---------------	------

Totally Integrated Automation Portal		
<div>Flow</div> <div>Ungrouped devices</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Flow</div> <div>Security settings</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Flow / Cross-device functions / Project traces</div> <div>Measurements</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal																		
<div>Flow / Common data</div> <div>Alarm classes</div> <table><thead><tr><th colspan="4">Alarm classes</th></tr><tr><th>Name</th><th>Display name</th><th>Acknowledgment</th><th>Priority</th></tr></thead><tbody><tr><td>Acknowledgement</td><td>A</td><td>True</td><td>0</td></tr><tr><td>No Acknowledgement</td><td>NA</td><td>False</td><td>0</td></tr></tbody></table>			Alarm classes				Name	Display name	Acknowledgment	Priority	Acknowledgement	A	True	0	No Acknowledgement	NA	False	0
Alarm classes																		
Name	Display name	Acknowledgment	Priority															
Acknowledgement	A	True	0															
No Acknowledgement	NA	False	0															

Totally Integrated Automation Portal		
<div>Flow / Common data</div> <div>Logs</div> <div>This folder is empty.</div>		

Totally Integrated Automation Portal		
<div>Flow / Languages & resources</div> <div>Project languages</div> <div><div>Languages</div><div><div>Reference language</div><div>English (United States)</div></div><div><div>Editing language</div><div>English (United States)</div></div><div><div>Other project languages</div><div>Empty</div></div></div>		

Totally Integrated Automation Portal																																																																																																																																																											
<div>Flow / Languages & resources / Project texts</div> <div>Project texts</div> <table><tr><th colspan="3">Project texts</th></tr><tr><th>English (United States)</th><th>Category</th><th>Reference</th></tr><tr><td></td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\Network 2\Comment</td></tr><tr><td></td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\Network 3\Comment</td></tr><tr><td></td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\Network 4\Comment</td></tr><tr><td></td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\Network 5\Comment</td></tr><tr><td></td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\Network 1\Comment</td></tr><tr><td>This DB contains the generated data from STEP 7 Report System Errors.</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_GLOBAL_DB [DB50]\Data block comment</td></tr><tr><td>This DB contains the generated data from STEP 7 Report System Errors.</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DB [DB49]\Data block comment</td></tr><tr><td>This DB is part of report system error and will be updated by the RSE FB. It is an interface for support of system diagnosis via the CPU web server.</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Data block comment</td></tr><tr><td>This FB contains the code generated from STEP 7 Report System Errors. It is called in the error OBs and in OB1 or a cyclic interrupt OB. The FB evaluates the system errors and displays them by means of an Alarm_S to the display device. While the FB executes, all interrupts are delayed.</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_FB [FB49]\Block comment</td></tr><tr><td>This FC contains the code generated from STEP 7 Report System Errors.</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_FC [FC49]\Block comment</td></tr><tr><td>"Cyclic Interrupt"</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\CYC_INT5 [OB35]\Block title</td></tr><tr><td>"I/O Point Fault"</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\I/O_FLT1 [OB82]\Block title</td></tr><tr><td>"I/O Point Fault"</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\I/O_FLT2 [OB83]\Block title</td></tr><tr><td>"Loss Of Rack Fault"</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\RACK_FLT [OB86]\Block title</td></tr><tr><td>"Main Program Sweep (Cycle)"</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\Main [OB1]\Block title</td></tr><tr><td>"Organization Block (OB) Not Loaded Fault"</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\Block title</td></tr><tr><td>16#35 Event class 3</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\OB85_EV_CLASS</td></tr><tr><td>16#XX, Fault identification code</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\OB85_FLT_ID</td></tr><tr><td>85 (Organization block 85, OB85)</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\OB85_OB_NUMBR</td></tr><tr><td>A</td><td>Alarm class text</td><td>Flow\Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName</td></tr><tr><td>A</td><td>Alarm class text</td><td>Flow\Acknowledgement\ShortName</td></tr><tr><td>Addressing mode of the module</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Component.C_AddressMode</td></tr><tr><td>An underlying component is disrupted</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\State.S_SubFault</td></tr><tr><td>AS-iMaster gibt AS-iSlave Alarme zurück</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Query.Q_SubComponentAlarm</td></tr><tr><td>Associated values of the message</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Alarm.A_AssociatedValue</td></tr><tr><td>At least one lower-level component is disabled</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\State.S_SubDeactivated</td></tr><tr><td>Byte offset to the start of the "Alarm" section</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Directory.D_pAlarm</td></tr><tr><td>Byte offset to the start of the "Component" section</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Directory.D_pComponent</td></tr><tr><td>Byte offset to the start of the "Error" section</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Directory.D_pError</td></tr><tr><td>Byte offset to the start of the "GlobalState" section</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Directory.D_pGlobalState</td></tr><tr><td>Byte offset to the start of the "Query" section</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Directory.D_pQuery</td></tr><tr><td>Byte offset to the start of the "State" section</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Directory.D_pState</td></tr><tr><td>Byte offset to the start of the "Subcomponent" section</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Directory.D_pSubComponent</td></tr><tr><td>Call system diagnostics block</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\I/O_FLT1 [OB82]\Network 1\Title</td></tr><tr><td>Call system diagnostics block</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\I/O_FLT2 [OB83]\Network 1\Title</td></tr><tr><td>Call system diagnostics block</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\RACK_FLT [OB86]\Network 1\Title</td></tr><tr><td>Call system diagnostics block</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\Main [OB1]\Network 7\Title</td></tr><tr><td>Class of event causing error</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\OB85_ERR_EV_CLASS</td></tr><tr><td>Date and time OB85 started</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\OB85_DATE_TIME</td></tr><tr><td>Hardware ID of the component (internal)</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Component.C_ComponentID</td></tr><tr><td>Hardware ID of the component (internal)</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Alarm.A_ComponentID</td></tr><tr><td>ID of the client</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Query.Q_ClientID_User</td></tr><tr><td>ID of the client (internal)</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Query.Q_ClientID_Intern</td></tr><tr><td>ID of the first error text</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Alarm.A_TextID1</td></tr><tr><td>ID of the first error text in the export file (HMI)</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Alarm.A_MapTextID</td></tr><tr><td>ID of the first error text lexicon</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Alarm.A_TextLexikonID1</td></tr><tr><td>ID of the first help text in the export file (HMI)</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Alarm.A_MapHelpTextID</td></tr><tr><td>ID of the first help text lexicon</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Alarm.A_HelpTextLexikonID1</td></tr><tr><td>ID of the last event (counter)</td><td>Block comment</td><td>Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\GlobalState.G_EventCount</td></tr></table>	Project texts			English (United States)	Category	Reference		Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\Network 2\Comment		Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\Network 3\Comment		Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\Network 4\Comment		Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\Network 5\Comment		Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\Network 1\Comment	This DB contains the generated data from STEP 7 Report System Errors.	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_GLOBAL_DB [DB50]\Data block comment	This DB contains the generated data from STEP 7 Report System Errors.	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DB [DB49]\Data block comment	This DB is part of report system error and will be updated by the RSE FB. It is an interface for support of system diagnosis via the CPU web server.	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Data block comment	This FB contains the code generated from STEP 7 Report System Errors. It is called in the error OBs and in OB1 or a cyclic interrupt OB. The FB evaluates the system errors and displays them by means of an Alarm_S to the display device. While the FB executes, all interrupts are delayed.	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_FB [FB49]\Block comment	This FC contains the code generated from STEP 7 Report System Errors.	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_FC [FC49]\Block comment	"Cyclic Interrupt"	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\CYC_INT5 [OB35]\Block title	"I/O Point Fault"	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\I/O_FLT1 [OB82]\Block title	"I/O Point Fault"	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\I/O_FLT2 [OB83]\Block title	"Loss Of Rack Fault"	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\RACK_FLT [OB86]\Block title	"Main Program Sweep (Cycle)"	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\Main [OB1]\Block title	"Organization Block (OB) Not Loaded Fault"	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\Block title	16#35 Event class 3	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\OB85_EV_CLASS	16#XX, Fault identification code	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\OB85_FLT_ID	85 (Organization block 85, OB85)	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\OB85_OB_NUMBR	A	Alarm class text	Flow\Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName	A	Alarm class text	Flow\Acknowledgement\ShortName	Addressing mode of the module	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Component.C_AddressMode	An underlying component is disrupted	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\State.S_SubFault	AS-iMaster gibt AS-iSlave Alarme zurück	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Query.Q_SubComponentAlarm	Associated values of the message	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Alarm.A_AssociatedValue	At least one lower-level component is disabled	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\State.S_SubDeactivated	Byte offset to the start of the "Alarm" section	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Directory.D_pAlarm	Byte offset to the start of the "Component" section	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Directory.D_pComponent	Byte offset to the start of the "Error" section	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Directory.D_pError	Byte offset to the start of the "GlobalState" section	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Directory.D_pGlobalState	Byte offset to the start of the "Query" section	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Directory.D_pQuery	Byte offset to the start of the "State" section	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Directory.D_pState	Byte offset to the start of the "Subcomponent" section	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Directory.D_pSubComponent	Call system diagnostics block	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\I/O_FLT1 [OB82]\Network 1\Title	Call system diagnostics block	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\I/O_FLT2 [OB83]\Network 1\Title	Call system diagnostics block	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\RACK_FLT [OB86]\Network 1\Title	Call system diagnostics block	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\Main [OB1]\Network 7\Title	Class of event causing error	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\OB85_ERR_EV_CLASS	Date and time OB85 started	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\OB85_DATE_TIME	Hardware ID of the component (internal)	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Component.C_ComponentID	Hardware ID of the component (internal)	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Alarm.A_ComponentID	ID of the client	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Query.Q_ClientID_User	ID of the client (internal)	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Query.Q_ClientID_Intern	ID of the first error text	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Alarm.A_TextID1	ID of the first error text in the export file (HMI)	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Alarm.A_MapTextID	ID of the first error text lexicon	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Alarm.A_TextLexikonID1	ID of the first help text in the export file (HMI)	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Alarm.A_MapHelpTextID	ID of the first help text lexicon	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Alarm.A_HelpTextLexikonID1	ID of the last event (counter)	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\GlobalState.G_EventCount		
Project texts																																																																																																																																																											
English (United States)	Category	Reference																																																																																																																																																									
	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\Network 2\Comment																																																																																																																																																									
	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\Network 3\Comment																																																																																																																																																									
	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\Network 4\Comment																																																																																																																																																									
	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\Network 5\Comment																																																																																																																																																									
	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\Network 1\Comment																																																																																																																																																									
This DB contains the generated data from STEP 7 Report System Errors.	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_GLOBAL_DB [DB50]\Data block comment																																																																																																																																																									
This DB contains the generated data from STEP 7 Report System Errors.	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DB [DB49]\Data block comment																																																																																																																																																									
This DB is part of report system error and will be updated by the RSE FB. It is an interface for support of system diagnosis via the CPU web server.	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Data block comment																																																																																																																																																									
This FB contains the code generated from STEP 7 Report System Errors. It is called in the error OBs and in OB1 or a cyclic interrupt OB. The FB evaluates the system errors and displays them by means of an Alarm_S to the display device. While the FB executes, all interrupts are delayed.	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_FB [FB49]\Block comment																																																																																																																																																									
This FC contains the code generated from STEP 7 Report System Errors.	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_FC [FC49]\Block comment																																																																																																																																																									
"Cyclic Interrupt"	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\CYC_INT5 [OB35]\Block title																																																																																																																																																									
"I/O Point Fault"	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\I/O_FLT1 [OB82]\Block title																																																																																																																																																									
"I/O Point Fault"	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\I/O_FLT2 [OB83]\Block title																																																																																																																																																									
"Loss Of Rack Fault"	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\RACK_FLT [OB86]\Block title																																																																																																																																																									
"Main Program Sweep (Cycle)"	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\Main [OB1]\Block title																																																																																																																																																									
"Organization Block (OB) Not Loaded Fault"	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\Block title																																																																																																																																																									
16#35 Event class 3	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\OB85_EV_CLASS																																																																																																																																																									
16#XX, Fault identification code	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\OB85_FLT_ID																																																																																																																																																									
85 (Organization block 85, OB85)	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\OB85_OB_NUMBR																																																																																																																																																									
A	Alarm class text	Flow\Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName																																																																																																																																																									
A	Alarm class text	Flow\Acknowledgement\ShortName																																																																																																																																																									
Addressing mode of the module	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Component.C_AddressMode																																																																																																																																																									
An underlying component is disrupted	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\State.S_SubFault																																																																																																																																																									
AS-iMaster gibt AS-iSlave Alarme zurück	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Query.Q_SubComponentAlarm																																																																																																																																																									
Associated values of the message	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Alarm.A_AssociatedValue																																																																																																																																																									
At least one lower-level component is disabled	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\State.S_SubDeactivated																																																																																																																																																									
Byte offset to the start of the "Alarm" section	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Directory.D_pAlarm																																																																																																																																																									
Byte offset to the start of the "Component" section	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Directory.D_pComponent																																																																																																																																																									
Byte offset to the start of the "Error" section	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Directory.D_pError																																																																																																																																																									
Byte offset to the start of the "GlobalState" section	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Directory.D_pGlobalState																																																																																																																																																									
Byte offset to the start of the "Query" section	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Directory.D_pQuery																																																																																																																																																									
Byte offset to the start of the "State" section	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Directory.D_pState																																																																																																																																																									
Byte offset to the start of the "Subcomponent" section	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Directory.D_pSubComponent																																																																																																																																																									
Call system diagnostics block	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\I/O_FLT1 [OB82]\Network 1\Title																																																																																																																																																									
Call system diagnostics block	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\I/O_FLT2 [OB83]\Network 1\Title																																																																																																																																																									
Call system diagnostics block	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\RACK_FLT [OB86]\Network 1\Title																																																																																																																																																									
Call system diagnostics block	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\Main [OB1]\Network 7\Title																																																																																																																																																									
Class of event causing error	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\OB85_ERR_EV_CLASS																																																																																																																																																									
Date and time OB85 started	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\OB85_DATE_TIME																																																																																																																																																									
Hardware ID of the component (internal)	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Component.C_ComponentID																																																																																																																																																									
Hardware ID of the component (internal)	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Alarm.A_ComponentID																																																																																																																																																									
ID of the client	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Query.Q_ClientID_User																																																																																																																																																									
ID of the client (internal)	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Query.Q_ClientID_Intern																																																																																																																																																									
ID of the first error text	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Alarm.A_TextID1																																																																																																																																																									
ID of the first error text in the export file (HMI)	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Alarm.A_MapTextID																																																																																																																																																									
ID of the first error text lexicon	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Alarm.A_TextLexikonID1																																																																																																																																																									
ID of the first help text in the export file (HMI)	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Alarm.A_MapHelpTextID																																																																																																																																																									
ID of the first help text lexicon	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\Alarm.A_HelpTextLexikonID1																																																																																																																																																									
ID of the last event (counter)	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAGNOSTIC_STATUS_DB [DB127]\GlobalState.G_EventCount																																																																																																																																																									

Totally Integrated Automation Portal		
English (United States)	Category	Reference
ID of the second error text	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\Alarm.A_TextID2
ID of the second error text in the export file (HMI)	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\Alarm.A_MapTextID2
ID of the second error text lexicon	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\Alarm.A_TextLexikonID2
ID of the second help text in the export file (HMI)	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\Alarm.A_MapHelpTextID2
ID of the second help text lexicon	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\Alarm.A_HelpTextLexikonID2
Index of the requested/actual error	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\Error.E_ErrorNo
Internal error in query	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\Query.Q_Error
List of channels involved; Valid only when Q_WithSubComponent is set	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\State.S_ChannelVector
List of status of subordinate components, 1 byte per component	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\SubComponent.U_SubComponentFault
Maintenance demand is indicated	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\State.S_Maintenance2
Maintenance demand is indicated for an underlying component	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\State.S_SubMaintenance2
Maintenance required is indicated	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\State.S_Maintenance1
Maintenance required is indicated for an underlying component	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\State.S_SubMaintenance1
Maintenance state of the component	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\State.S_TIAMS
Maintenance state: Configured channels	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\State.S_TIAMSCheckExist
Maintenance State: Disrupted channels	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\State.S_TIAMSCheckOK
Message number	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\Alarm.A_AlarmID
NA	Alarm class text	Flow\No Acknowledgement\AlarmClassData_IDisplayNaming_DisplayName
NA	Alarm class text	Flow\No Acknowledgement\ShortName
Number of channels; Valid only when Q_With-SubComponent is set	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\State.S_ChannelCount
Number of event causing error	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\OB85_ERR_EV_NUM
Number of OB causing error	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\OB85_OB_NUM
Number of other occupied bytes	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\Alarm.A_ValueCount
Number of underlying components	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\SubComponent.U_SubComponentCount
Priority of OB causing error	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\OB85_OB_PRIOR
Priority of OB Execution	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\OB85_PRIORITY
Report System Error Diagnostic Block	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_FC [FC49]\Block title
Report System Error Diagnostic Block	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_FB [FB49]\Block title
Report System Error Diagnostic Block	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\Data block title
Report System Error Diagnostic Block	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_GLOB-AL_DB [DB50]\Data block title
Report System Error Diagnostic Block	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DB [DB49]\Data block title
Reserved	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\State.S_Reserved7
Reserved	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\State.S_Reserved6
Reserved	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\State.S_Reserved5
Reserved	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\Query.Q_Reserved5
Reserved	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\Query.Q_Reserved4
Reserved	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\Query.Q_Reserved6
Reserved	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\State.S_Reserved2
Reserved	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\Query.Q_Reserved7
Reserved	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\Query.Q_Reserved3
Reserved	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\Query.Q_Reserved8
Reserved	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\Query.Q_Reserved2
Reserved	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\Component.C_Reserved1
Reserved	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\State.S_Periphery
Reserved	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\State.S_Hierarchy
Reserved	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\System blocks\System diagnostics\RSE_DIAG-NOSTIC_STATUS_DB [DB127]\State.S_Reserved4
Reserved for system	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\OB85_RESERVED_1
Reserved for system	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\OB85_RESERVED_3
Reserved for system	Block comment	Flow\PLC_1 [CPU 314C-2 PN/DP]\Program blocks\OBNL_FLT [OB85]\OB85_RESERVED_2

