SL7 INDUSTRIAL NETWORK

Switch topology • addressing • VLAN membership

18 SWITCHES • 3 ENDPOINTS

UTP | Fiber (MM) | Unspecified type | Endpoint link in source

CONTROL / OPERATOR NETWORK

IE-3000-4TC
SL7
IND-SW-EDNL-SL7
192.168.160.73 (560)
561 590 593

IE-3200-8T2S
SL7 MCC
IND-SW-SL7MCC
192.168.160.112 (560)
561 591 593

IE-3300-8P2S
SL7 Operator
IND-SW-EDNL-SL7Oper
192.168.160.119 (560)
561 591 593

SL7_SCADA_PC
Workstation

IBA_PC
Workstation

Thin Client HMI
HMI endpoint

ESXi / VIRTUAL SERVICES
PLC_ENG (191)
Drives_ENG (191)
Ignition_Collecter (194)
FireWalls
Host links not explicitly shown in source

FIBER (MM)

DEPT34 / PTTL DISTRIBUTION

IE-3000-4TC
TLL
IND-SW-EDNL_TLL
192.168.160.59 (560)
561 590

IE-3000-4TC
Dept34 / PTTL
IND-SW-EDNL_Dept34_PTTL
192.168.160.84 (560)
561 581

IE-3000-4TC
PTTL
IND-SW-EDNL_PTTL
192.168.160.70 (560)
561 590

IE-3000-4TC
PTTL PLC
IND-SW-EDNL_PTTL_PLC
192.168.160.90 (560)
579 581

IE-3000-4TC
PTTL PLC 2
IND-SW-EDNL_PTTL_PLC2
192.168.160.124 (560)
579

IE-3000-4TC
Dept34 Distribution
IND-SW-Dept34_Distr
192.168.160.117 (560)
561 590

IE-3000-4TC
CTLL5
IND-SW-EDNL_CTLL5
192.168.160.71 (560)
561 567 590 591

IE-3000-4TC
SL5
IND-SW-EDNL_SL5
192.168.160.56 (560)
579 581

IE-3000-4TC
SL4
IND-SW-EDNL_SL4
192.168.160.55 (560)
561 590 591

IE-3000-4TC
SL2
IND-SW-EDNL_SL2
192.168.160.54 (560)
561

A17 • COOLING TOWERS • CRANE

IE-3000-4TC
A17 Control Room
IND-SW-EDNL _A17ControlRoom
192.168.160.65 (560)
561 574 593

IE-3000-4TC
External Cooling Tower
IND-SW-EDNL _EXTCOOLINGTOWER
192.168.160.101 (560)
561

IE-3000-4TC
S5 Cooling Towers
IND-SW-EDNL _S5CoolingTowers
192.168.160.31 (560)
561 590

IE-3000-4TC
S4 Cooling Towers
IND-SW-EDNL _S4CoolingTowers
192.168.160.30 (560)
561 590

IE-3000-4TC
CM Crane
IND-SW-EDNL_CM-Crane
192.168.160.126 (560)
561 592 593

VLAN REFERENCE: 561 IND-CESMS • 567 CTTL5_Mgaurd • 574 IND-AnnealingFurnace • 579 PTTL_Network • 581 PTTL_ACDrives 590 EDPowerMeters • 591 SL7 • 592 Crane • 593 Ignition

Design note: Original IPs, switch models, VLAN memberships and identifiers retained. Cable types are assigned only where the source drawing identifies them.

VERIFY IN FIELD: two endpoints inferred from line geometry.