Naming Standard

Technical Order 1042

Rack Naming and Mounting Standard

AN = Access Node (switch). CN = Core Node (router). Rack order is not cosmetic: power at the top, away from data; patch panel directly above the switch it feeds; router beside the switch it uplinks to; and the heavy box lowest for center of gravity.

First Floor Rack

Slot	Device	Name	Why
U1 (top)	**Rack PDU**	**PDU1**	**Power at the top, away from data cabling**
U2	8-port patch panel	Patch1	Directly above its switch – short patch runs
U3	8-port switch	AN-1	Access node, ground floor
U4	Core router	CN-1	Beside the switch it trunks to; feeds the demarc
U5	Rack server	IT2	Heavy and hot – lowest in the rack
U6	—	spare	Leave open for growth

Second Floor Rack

Slot	Device	Name
U1	**Rack PDU**	**PDU2**
U2	Patch panel	Patch2
U3	Switch	AN-2

No server upstairs. Wall mounts are already installed — facilities did that.