

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 3129

Dated: 29/09/2026

It is certified that an inspection team headed by ...Lab... Staff... DWTL... PHED... BHIWANI

(Name of Officers with designation) from District Water Testing Lab... PHED BHIWANI

inspected the ...BITS... INTERNATIONAL SCHOOL PALUWAS BHIWANI

(Name & Address of the school) on 21/09/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 1331 & 1329 dated 29/09/2026

of DWTL Lab BHIWANI (PHED Lab) certified that

the BITS INTERNATIONAL SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 6 Months

Executive Engg.
PH Engg Divn. No.
Bhiwani

Signature with Seal:

Name :

Designation : Executive Engineer

Name & Address of the Office / Department :

To
BITS INTERNATIONAL
SCHOOL, PALUWAS BHIWANI
(Name & Address of the Institution)

Public Health Engg. Department,
Vidya Nagar, Mehram Road, Bhiwani.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Memo No:- 1331

Date:- 29/09/2026

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification :	BHW/04368/9/2026 / Private	Sample Details	Date & Time
Sender :	BITS INTERNATIONAL SCHOOL PALUWAS BHIWANI	Collected By	RAJKUMAR
Location :	BITS INTERNATIONAL SCHOOL PALUWAS BHIWANI	Collection Date	21/09/2026 at 11:36
Sample Description :	Drinking Water	Received at lab	21/09/2026 at 11:44
Latitude / Longitude :	76.152560 / 28.811654	Analysis Start Date	28/09/2026
		Analysis End Date	28/09/2026
		Sample Quantity	2 Ltr.

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	0.26	1 NTU	5 NTU	APHA 24th Edition -2130 B
2	Taste	Agreeable	Agreeable	Agreeable	APHA 24th Edition -2160C
3	Odour	Agreeable	Agreeable	Agreeable	APHA 24th Edition -2150B
4	Color	2	5 Hazen Units	15 Hazen Units	APHA 24th Edition -2120B
5	Total Dissolved Solids @ 180°C ± 2°C	118	500 mg/lit.	2000 mg/lit.	APHA 24th Edition -2540 C
6	Total Hardness as CaCo3	105	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C
7	Calcium (as Ca)	18.04	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B
8	Magnesium (as Mg)	14.58	30 mg/lit.	100 mg/lit.	APHA 24th Edition -3500 Mg B
9	Total Alkalinity	85	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B
10	Chloride (as Cl)	24.82	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B
11	Sulphate as So4	12	200 mg/lit.	400 mg/lit.	USEPA / APHA 24th -4500 SO4-E
12	Fluoride (as F)	0.12	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition-4500F C/
13	Iron (as Fe)	0.04	1.0 mg/lit.	1.0 mg/lit.	USEPA
14	Nitrate (as No3)	0.25	45 mg/lit.	45 mg/lit.	APHA 24th Edition -4500 NO3 D
15	pH @ 25°C	7.91	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B


Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED BHIWANI Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found "CONFORMING" to Limits set in BIS10500:2012 for the tested parameters.



Sample analyzed by : Poince


RAJEEV KUMAR, CHEMIST
DISTRICT WATER TESTING LABORATORY BHIWANI
email:-chemist.bhiwani@phedharyana.gov.in

Subject : Bacteriological Examination Report of Water Samples

Circle Bhiwani Circle

Division Bhiwani PHED No. 2

Sub Division Bhiwani PHED No. 2

S.No.	Tested Parameter *	Result (MPN) **	Protocol Used	Potable / Not Potable
Memo No :- 1329, Date :- 29/09/2026				
1	Sample ID:-BHW/04369/9/2026 /Sender : BITS INTERNATIONAL SCHOOL PALUWAS BHIWANI ,Location : , BITS INTERNATIONAL SCHOOL PALUWAS BHIWANI, Analysis Start/End Date: 22/09/2026 / 24/09/2026, GPS Coordinates: 76.152560 /28.811654			
	Total Coliform per 100 ml	00	IS 15185:2016/APHA 9223B-2023/APHA 9221 B & C	Potable
Abstract Report of Bacteriological Examination Report of Water Sample				
Total Sample		Potable	Not Potable	
1		1	0	

* Requirement (Acceptable Limit) : Shall not be detectable in any 100 ml sample

** MPN (Most Probable Number) Per 100 ML.

Remarks :-

- * The Results Given above are related to the sample as received and tested in BHIWANI lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.



RAJEEV KUMAR, CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY, BHIWANI
email:-chemist.bhiwani@phedharyana.gov.in

Sample analyzed by : WAZIR