

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1229

Dated: 12/02/2026

It is certified that an inspection team headed by DWTL PHED Bhiwani Lab staff

(Name of Officers with designation) from District Water Testing Lab PHED

inspected the BITS International School, Palawas, Bhiwani

(Name & Address of the school) on 09/02/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 112 & 113 dated 12/02/2026

of DWTL, Bhiwani (PHED Lab) certified that

the BITS International School, Palawas (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 6 Months

Executive Engineer
PH Engg. Divn. No. 2

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

Kapil Bhiwani

Executive Engineer

PH Engg. Divn. No. 2, Maham Road
Bhiwani

To

BITS International School,
Palawas, Bhiwani

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Memo No:- 112

Date:- 12/02/2026

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification :	BHW/04835/2/2026 / Private	Sample Details	Date & Time
Sender :	BITS International School, Paluwas, Bhiwani	Collected By	Pradeep Kumar
Location :	, BITS International School, Paluwas, Bhiwani	Collection Date	09/02/2026 at 13:59
Sample Description :	Drinking Water	Received at lab	09/02/2026 at 14:11
Latitude / Longitude :	76.152560 / 28.811650	Analysis Start Date	10/02/2026
		Analysis End Date	10/02/2026
		Sample Quantity	2 ltr.

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	0.19	1 NTU	5 NTU	APHA 24th Edition -2130 B
2	Taste	Agreeable	Agreeable	Agreeable	APHA 24th Edition -2160C
3	Odour	Agreeable	Agreeable	Agreeable	APHA 24th Edition -2150B
4	Color	5	5 Hazen Units	15 Hazen Units	APHA 24th Edition -2120B
5	Total Dissolved Solids @ 180°C ± 2°C	200	500 mg/lit.	2000 mg/lit.	APHA 24th Edition -2540 C
6	Total Hardness as CaCO ₃	95	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C
7	Calcium as Ca	12.02	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B
8	Magnesium as Mg	15.8	30 mg/lit.	100 mg/lit.	APHA 24th Edition -3500 Mg B
9	Total Alkalinity	125	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B
10	Chloride as Cl	74.45	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B
11	Sulphate as SO ₄	41	200 mg/lit.	400 mg/lit.	USEPA / APHA 24th -4500 SO ₄ -E
12	Fluoride as F	0.13	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition-4500F C/
13	Iron as Fe	0.02	1.0 mg/lit.	1.0 mg/lit.	USEPA
14	Nitrate as NO ₃	0.39	45 mg/lit.	45 mg/lit.	APHA 24th Edition -4500 NO ₃ D
15	pH @ 25°C	6.88	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B

Remarks :-

- The Results Given above are related to the sample as received and tested in PHED BHIWANI Lab.
- The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- The test report can't be used for any publicity or any legal purpose.
- Reliability of water sample sample lies with sender/collector of water sample.
- To check the sample report online Scan the QR Code below.
- The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found "CONFORMING" to Limits set in BIS10500:2012 for the tested parameters.



Sample analyzed by : Poince

RAJEEV KUMAR CHEMIST
DISTRICT WATER TESTING LABORATORY BHIWANI
email: chemist.bhiwani@phedharyana.gov.in



PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY ,BHIWANI

Website :- <https://phedharyana.gov.in/>

Subject : Bacteriological Examination Report of Water Samples

Circle **Bhiwani Circle**

Division **Bhiwani PHED No. 2**

Sub Division **Bhiwani PHESD No. 2**

S.No.	Tested Parameter *	Result (MPN) **	Protocol Used	Potable / Not Potable
-------	--------------------	-----------------	---------------	-----------------------

Memo No :- 113, Date :- 12/02/2026

1	Sample ID:-BHW/04836/2/2026 /Sender : BITS International School, Paluwas, Bhiwani ,Location : , BITS International School, Paluwas, Bhiwani, Analysis Start/End Date: 09/02/2026 / 11/02/2026, GPS Coordinates: 76.152560 /28.811650			
---	---	--	--	--

	Total Coliform per 100 ml	00	IS 15185:2016/APHA 9223B-2023/APHA 9221C-2023	Potable
--	---------------------------	----	---	---------

Abstract Report of Bacteriological Examination Report of Water Sample

Total Sample	Potable	Not Potable
1	1	0

* Requirement (Acceptable Limit) : Shall not be detectable in any 100 ml sample

** MPN (Most Probable Number) Per 100 ML.

Remarks :-

- * The Results Given above are related to the sample as received and tested in BHIWANI lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample



RAJEEV KUMAR CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY,BHIWANI
email:-chemist.bhiwani@phedharyana.gov.in

Sample analyzed by : *Prince*