

INSPECTION REPORT IR-2026-014

Follow-up survey - Pressure Vessel V-210

Facility: BCR Unit 5 Date: 12-09-2026 Inspector: A. Kulkarni

Equipment tag: V-210

Ultrasonic thickness readings (mm):

TP1	5.3
TP2	5.1
TP3	4.7
TP4	5.0

Minimum allowable thickness: 5.0 mm

Remarks: TP3 below minimum. Corrosion under insulation confirmed.

Recommend: engineering review before restart.