

SOP-01 Pressure Vessel Inspection

1. Purpose

Defines inspection frequency and acceptance criteria for pressure vessels at BCR.

2. Frequency

External visual and ultrasonic thickness survey every 24 months. Vessels in corrosive service every 12 months.

3. Acceptance criteria

Any thickness reading below the minimum allowable thickness of 5.0 mm for vessel V-210 requires engineering review and a fitness-for-service assessment under SOP-06 before continued operation.

4. Escalation

Inspector notifies the Mechanical Engineering Manager within 24 hours of any below-minimum reading.

SYNTHETIC DEMO DOCUMENT - fictional company, invented data. Not for operational use.