

MINIMUM 5" (16mm) CEMENT BOARD PANELS TO BE INSTALLED PRE-POUR AS FORM PANEL FOR CONCRETE CAP AT TOP OF WALL INSTALLED ON SLOPE TO MATCH ROOF PITCH

CAP FLASHING CLIPPED TO COUNTER FLASHING  
ADDITIONAL FORM SUPPORT AT CEMENT BOARD PANELS IF REQUIRED

DIM 'A' AS SPECIFIED BY ENGINEERING PER APPLICABLE CODES

MINIMUM 6" (152mm) THICK CONTINUOUS CONCRETE CAP AT TOP OF WALL POURED INTEGRAL WITH FIREWALL OR AS PER LOCAL CODE

APPROVED FIRE TEMP. RATED ALUMINUM BURN CLIP AS SPECIFIED

COUNTER FLASHING & CLIP EDGE AS PER CODE SCREWED TO CEMENT BOARDS

ROOF SHEATHING & SHINGLES AS PER CODE

BASE FLASHING AS PER CODE

2x4" (38x89mm) CONT. TO MATCH ROOF SLOPE FASTENED THROUGH TO CAVITY (PRE-POUR)

REINFORCING AS PER DESIGN  
MINIMUM AS PER ULC LISTING W013

5" (16mm) TYPE 'X' GYPSUM BOARD FINISH IN ATTIC BOTH SIDES, TERMINATES AT CEMENT BOARD

STANDARD 8" (203mm) NUDURA FORM UNIT

**DISCLAIMER NOTICE:**  
SPECIFIC INFORMATION REQUIRED FOR COMPLIANCE WITH LOCAL CODES IS THE RESPONSIBILITY OF THE DESIGNER



**NUDURA**  
INTEGRATED BUILDING TECHNOLOGY  
*Building Value.*

NUDURA 8" (203mm) FORM UNIT STC / FIRE WALL DETAILS FIREWALL PROJECTION THROUGH ROOF 2 HOUR FIREWALL

REV. NO.  
001 KS

DWG. NO.

FW8D5

REV. DATE:  
AUGUST 2010

DRAWN BY:  
K. STILL

SCALE:  
1 : 8