



1. THIS P&ID IS REISSUED FOR INFORMATION FOR SAKARYA PROJECT.
2. FOR P&ID LEGEND SHEET SEE DRAWING: SC26-2A-GOE-FGN-PE-PID-100018, SC26-2A-GOE-FGN-PE-PID-100021 TO 100031.
3. FOR MARINE PIPING AND VALVE MATERIAL SPECIFICATION, SEE DOCUMENT: SC26-2A-GOE-FHM-PE-SPC-105001 (4517-BW-L-SA-00002).
4. FOR HELIDECK ARRANGEMENT, REFER TO 0384-KEP-C-XE-00004.001.

1. TIE DOWN POINT WITH DRAINAGE REFER TO REFERENCE DWG.
2. IN CASE OF HELI FUEL SPILL ON HELIDECK, ALL DRAIN LINES SHALL BE ROUTED TO SLOP TANK.
3. a) NORMAL DRAINAGE ROUTE SHALL BE TO OVERBOARD TO CATER RAIN WATER ACCUMULATION;
b) IN EVENT OF PLANNED HELICOPTER OPERATION, PRIOR TO HELICOPTER LANDING, THIS VALVE TO BE LINE UP TO SLOP TANK.



SYSTEM PARAMETERS	
SERVICE	DRAIN
DESIGN PRESSURE(Barg)	2.0
OPERATING PRESSURE(Barg)	ATM
DESIGN TEMPERATURE(°C)	50.0
OPERATING TEMPERATURE(°C)	AMB

-	R02	ISSUED FOR INFORMATION	23/07/25	ZYL	DWJ	DC	SJL
-	R01	ISSUED FOR INFORMATION	28/04/25	ZYL	DWJ	DC	SJL
-	R00	ISSUED FOR INFORMATION (1 st GOE ISSUE)	27/12/24	ZYL	DWJ	DC	SJL
20	-	ISSUED FOR AS-BUILT	28/09/22	JT	JT	NO	PL
03	-	RE-ISSUED FOR CONSTRUCTION	05/01/22	XH	JT	NO	PL
02	-	RE-ISSUED FOR CONSTRUCTION	18/08/21	XH	JT	NO	PL
01	-	RE-ISSUED FOR CONSTRUCTION	27/11/20	XH	JT	NO	PL
00	-	ISSUED FOR CONSTRUCTION	23/01/20	XH	JT	NO	PL
C	-	ISSUED FOR DESIGN	04/09/19	XH	JT	NO	PL
B	-	ISSUED FOR REVIEW	08/07/19	XH	JT	NO	PL
A	-	ISSUED FOR IDC	07/07/19	XH	JT	NO	PL
GOE	OTC	REASON FOR USE	DATE	DRAWN	ISSUED	CHECKED	APPROVED

DISCIPLINE: MR		SYSTEM NO: 56	AREA / MODULE: FHD	IMO NO: 8706014	PROJECT NO: SC26-2A	SCALE: N.T.S.	SIZE: A3	
SUPPLIER:			PROJECT: Sakarya Gas Field Dev't Phase-2a					
 OceanoSTAR Elite			 GLOBAL OFFSHORE ENGINEERING		TITLE: P&ID - HELIDECK DRAIN SYSTEM			
CLIENT:				OTC DOC. NO: SC26-2A-GOE-FHD-MR-PID-125002			GOE REV: -	SHEET 1 of 1
 OTC OFFSHORE TECHNOLOGY CENTER				LEG DOC. NO: -			OTC REV: R02	
				REF. DOC. NO: 0384-KEP-V-XB-56004.001				

This drawing contains proprietary information and may not be transferred, reproduced or used to construct any project other than it was issued for without the written consent of GOF or their Client.