EQUIP. TAG	66PS5503	
EQUIP. NAME	SEWAGE TRANSFER PUMP	
CAPACITY	1.5 m3/hr @ 45m	
CONFIGURATION	1 x 100%	
OPERATING(DESIGN) PRESSURE	4.5 (6)	BARG
OPERATING(DESIGN) TEMP.		°C
DUTY POWER	0.75	kW
MATERIAL	CAST IRON	

EQUIP. TAG	66TB5505	
EQUIP. NAME	BLACK WATER HOLDING TANK	
CAPACITY	4.1 m3	
CONFIGURATION	N.A.	
OPERATING(DESIGN) PRESSURE	ATM	BARG
OPERATING(DESIGN) TEMP.		°C
DUTY POWER	N.A.	kW
MATERIAL		

EQUIP. TAG	66TB5506	
EQUIP. NAME	BLACK WATER OVERFLOW TANK	
CAPACITY	1 m3	
CONFIGURATION	N.A.	
OPERATING(DESIGN) PRESSURE	ATM	BARG
OPERATING(DESIGN) TEMP.		°C
DUTY POWER	N.A.	kW
MATERIAL		

91-6"-VA-G1A-5633 NOTE 1
91-1"-VA-G1A-5632
HOUSE TOP
G1A
FROM SEWAGE TREATMENT PLANT GOE-FHM-MR-PID-105104 0384-KEP-V-XB-66002.001
91-1"-VA-G1-5569
91-6"-VA-G1-5570
91-2 1/2"-VA-G1-5571
FROM SEWAGE TREATMENT PLANT GOE-FHM-MR-PID-105104 0384-KEP-V-XB-66002.001
91-4"-VA-G1-5568
6" x 4"
91-4"-VA-G1-5572
NOTE 10 66 SP 5005
66-2 1/2"-DS-G1-5520
NOTE 6
1" 66BAV5527 NC
1" 66BAV5526 NC
66TB5505 (4.1 M3)
VENT 3/4" 66BAV5882 NC
2" 66BAV5503
66-2"-DS-G1-5758
66 LG 5502 LSH 5502 66 M/S LAH 5502 NOTE 2
66-2"-DS-G1-5526
NOTE 5 66GAV5520 NC 13430 A/B
66BAV5504
3/4" 66BAV5883 NC 2" DRAIN
66-2"-DS-G1-5759
NOTE 10 66 SP 5008
NOTE 3 66 SP 5502
3/4" 66GAV5523 NC
66GAV5518 NO
66-2"-DS-G1-5512
NOTE 10 66 SP 5009
66GAV5517
66-2"-DS-G1-5689
NOTE 10 66 SP 5010
66GAV5516
NOTE 10 66 SP 5011
66GAV5515
66-2"-DS-G1-5523
66 SP 5504
INTERNATIONAL SHORE CONNECTION STBD
66GAV5514 2"x4"
MAIN DECK ENGINE ROOM
66-2 1/2"-DS-G1-7786
TP 7522
TP 7523
2"X2 1/2"
66-2 1/2"-DS-G1-5690
66CHV5503
EFFLUENT/SLUDGE FROM STP GOE-FHM-MR-PID-105104 0384-KEP-V-XB-66002.001
RAW SEWAGE FROM STP GOE-FHM-MR-PID-105104 0384-KEP-V-XB-66002.001
66-2"-DS-G1-5524
66-2"-DS-G1-5525
NOTE 7,9 SET @ 5.5 BARG
66 PSV 5501
PN16
66-1 1/2"-DS-G1-5742
66 PG 5501 NOTE 7 R03
66 PG 5502 NOTE 7 R03
2" 66BAV5551
2" 66BAV5552
1"
66GAV5512
66GAV5513
66 SP 5503
NOTE 3
3/4" 66GAV5522 NC
NOTE 10 66 SP 5006
FROM SEWAGE TREATMENT PLANT GOE-FHM-MR-PID-105104 0384-KEP-V-XB-66002.001
66-2 1/2"-DS-G1-5688
66GAV5509 NO
66TB5506 (1 M3)
VENT 3/4" 66BAV5884 NC
2" 66BAV5505
66-2"-DS-G1-5760
66 LG 5503 LSH 5503 66 M/S LAH 5503 NOTE 2
66-2"-DS-G1-5521
NOTE 5 66GAV5521 NC 5344 A/B
66BAV5506
3/4" 66BAV5885 NC 2" DRAIN
66-2"-DS-G1-5761
NOTE 10 66 SP 5007
66-2"-DS-G1-5522
66GAV5510
66CHV5504
66GAV5511
66PS5503 NOTE 7,8
66 SP 5501 MESH: 5mm
66GAV5531
66-2"-DS-G1-5513
TO SEWAGE TREATMENT PLANT GOE-FHM-MR-PID-105104 0384-KEP-V-XB-66002.001
FROM GREY WATER HOLDING TANK GOE-FHM-MR-PID-105104 0384-KEP-V-XB-66002.001
66-2"-DS-G1-5533

SYSTEM PARAMETERS	
SERVICE	SEWAGE
DESIGN PRESSURE(Barg)	6.0
OPERATING PRESSURE(Barg)	4.5
DESIGN TEMPERATURE(°C)	50.0
OPERATING TEMPERATURE,(°C)	AMB

R03

NOTES:

1. VENT PIPE TO BE ROUTED TO HOUSE TOP, AWAY FROM WALKWAYS AND HVAC AIR INTAKES.
2. MAGNETOSTRICTIVE TYPE.
3. FLUSHING.
4. DELETED.
5. DRAIN.
6. WATER LOOP OF 258MM.
7. VENDOR SUPPLIED.
8. SEWAGE TRANSFER PUMP TO BE CONTROLLED FROM LCP OF SEWAGE TREATMENT PLANT.
9. COUNTER FLANGES TO BE PROVIDED BY VENDOR.
10. EXISTING ITEM ASSIGNED WITH NEW TAG.

GENERAL NOTES:

1. THIS P&ID IS REISSUED FOR INFORMATION FOR SAKARYA PROJECT.
2. NO CHANGE IN SYSTEM.
3. FOR P&ID LEGEND SHEET SEE DRAWING: R03 SC26-2A-GOE-FHM-MR-PID-105133 TO 105139
4. FOR MARINE PIPING AND VALVE MATERIAL SPECIFICATION SEE DOCUMENT: SC26-2A-GOE-FHM-EP-SPC-105001 (4517-BWO-L-SA-00002).
5. R03 FOR CHANGES IN REV.03, PLEASE REFER TO ECN-00320. FOR CHANGES IN REV.02, PLEASE REFER TO ECN-00249.

LEGENDS:

EXISTING PIPE
NEW PIPE

-	R03	ISSUED FOR INFORMATION	09/03/26	ZYL	DWJ	DC	SJL
-	R02	ISSUED FOR INFORMATION	11/09/25	ZYL	DWJ	DC	SJL
-	R01	ISSUED FOR INFORMATION	24/06/25	ZYL	DWJ	DC	SJL
-	R00	ISSUED FOR INFORMATION (1ST GOE ISSUE)	10/01/25	ZYL	DWJ	DC	SJL
Z0	-	ISSUED FOR AS-BUILT	28/09/22	JT	JT	NO	PL
02	-	RE-ISSUED FOR CONSTRUCTION	07/04/21	XH	JT	NO	PL
01	-	RE-ISSUED FOR CONSTRUCTION	07/01/21	XH	JT	NO	PL
00	-	ISSUED FOR CONSTRUCTION	04/02/20	XH	JT	NO	PL
C	-	ISSUED FOR DESIGN	03/09/19	XH	JT	NO	PL
B	-	ISSUED FOR REVIEW	22/07/19	TT	JT	NO	PL
A	-	ISSUED FOR IDC	11/06/19	TT	JT	NO	PL
GOE REV.	OTC REV.	REASON FOR USE	DATE	DRAWN	ISSUED	CHECKED	APPROVED

DISCIPLINE:	SYSTEM NO:	AREA / MODULE:	IMO NO:	PROJECT NO:	SCALE:	SIZE:
MR	66	FHM	8706014	SC26-2A	N.T.S.	A3

SUPPLIER: OceanSTAR Elite / GOE GLOBAL OFFSHORE ENGINEERING

PROJECT: Sakarya Gas Field Dev't Phase-2a

TITLE: P&ID - SEWAGE TREATMENT PLANT (SHEET 2)

CLIENT: TP OTC OFFSHORE TECHNOLOGY CENTER

OTC DOC. NO:	SC26-2A-GOE-FHM-MR-PID-105105	GOE REV.	SHEET
LEG DOC. NO:	-	-	2 of 2
REF. DOC. NO:	0384-KEP-V-XB-66002.002	OTC REV. R03	

This drawing contains proprietary information and may not be transferred, reproduced or used to construct any project other than it was issued for without the written consent of GOE or their Client.