

EQUIP. TAG	53HB7001A/B/C/D (NEW)	
EQUIP. NAME	COOLING MEDIUM/SEAWATER EXCHANGER	
CONFIGURATION	4 x 25%	
SIDE	HOT	COLD
FLUID	COOLING MEDIUM	SEAWATER
CAPACITY	3388 m3/h	6450 m3/h
WORKING/DESIGN PRESSURE	6.0 (IN), 5.8 (OUT) / 10.0 BARG	4.0 (IN), 3.4 (OUT) / 10.0 BARG
WORKING/DESIGN TEMP	56.96 (IN), 34 (OUT) / 85 °C	23 (IN), 35 (OUT) / 85 °C
DUTY POWER	86487	kw

EQUIP. TAG	33PA7001 (NEW)
EQUIP. NAME	PRODUCE WATER SAMPLING PUMP
CAPACITY	HOLD 2
CONFIGURATION	1x100%

53HB7001A/B/C/D INTERFACES			
TP	DESCRIPTION	CONNECTION TYPE / SIZE	MATERIAL
S1	SEAWATER OUTLET	18" ANSI B16.5 150# RF	SB 265 GR.1 w/ TL GR.2 LINER
S2	SEAWATER INLET	18" ANSI B16.5 150# RF	SB 265 GR.1 w/ TL GR.2 LINER
S3	COOLING MEDIUM OUTLET	12" ANSI B16.5 150# RF	SB 265 GR.1 w/ SS316L LINER
S4	COOLING MEDIUM INLET	12" ANSI B16.5 150# RF	SB 265 GR.1 w/ SS316L LINER

97G1521 INTERFACES			
TP	DESCRIPTION	CONNECTION TYPE / SIZE	MATERIAL
N-1	COOLING WATER INLET	GB DN40	CU/NI 70/30
N-2	COOLING WATER OUTLET	GB DN40	CU/NI 70/30
N-3	DRAIN	G 3/4" (M)	STEEL
N-6	SAFETY VALVE OUTLET	5/8" BARE PIPE END	COPPER

SYSTEM PARAMETERS	
SERVICE	SEAWATER COOLING
DESIGN PRESSURE(Barg)	7
OPERATING PRESSURE(Barg)	4.1
DESIGN TEMPERATURE(°C)	35
OPERATING TEMPERATURE(°C)	26

GENERAL NOTES:

- THIS P&ID IS REISSUED FOR NECESSARY UPDATE FOR SAKARYA PROJECT.
- SEQUENTIAL NUMBER 7XXX MEANS THERE IS A MODIFICATION FROM EXISTING UNIT OR NEW.
- FOR P&ID LEGEND SHEET SEE DRAWING: SC26-2A-GOE-FHM-MR-PID-105133 TO 105139
- DELETED.
- FOR MARINE PIPING AND VALVE MATERIAL SPECIFICATION, SEE DOCUMENT: SC26-2A-GOE-FHM-FP-SPC-105001 (4517-BWO-1-SA-00002)
- FOR CHANGES IN REV.03, PLEASE REFER TO ECN-00298, ECN-00449.

NOTES:

- VALVE TO HAVE REMOTE MANUAL CLOSING BY HYDRAULIC HAND PUMP.
- CHEMICAL FLUSHING CONNECTIONS.
- CONNECTION FOR BACKWASH FLOW.
- DELETED.
- EXISTING VALVE MAY BE REUSED DEPENDING ON CONDITION ASSESSMENT.
- FOR COLD MEDIUM SYSTEM AND PG & TG TAGS, SEE P&ID SC26-2A-GOE-FHM-MR-PID-105021(384-53-W-DWG-101_001).
- PRODUCED WATER BRANCH INSERTING POINT TO BE AS CLOSE TO HEAT EXCHANGERS SIDE AS POSSIBLE.
- COUNTER-FLANGES TO BE PROVIDED BY VENDOR.
- INSULATION KIT TO BE PROVIDED.
- 2" 150# RF FLANGE W/ 1/2" NPTM X 1/2" OD SDSS TUBING ADAPTOR TO BE PROVIDED BY EMERSON.
- CAPACITY IS SIZED FOR 4 SETS OF HEAT EXCHANGERS RUNNING AT THE SAME TIME.
- BLIND FLANGE WITH THREAD HOLES TO BE PROVIDED TO CONNECT TUBING WITH PUMP.

HOLDS:

- DELETED.
- VENDOR INFORMATION.
- DELETED.

LEGENDS:

- EXISTING PIPE
- NEW PIPE
- SAMPLING PIPE
- LIKE TO LIKE REPLACEMENT PIPE
- INSULATED PIPE
- SAMPLE QUILL

EQUIP. TAG	97G1521
EQUIP. NAME	NO.6 MACHINERY SPACE WORKSHOP PACKAGED AIR CONDITIONING UNIT
SEAWATER FLOW	8 m3/h
INLET/OUTLET TEMP	26 / 30 °C
INLET/OUTLET PRESSURE	INLET ≥ 1.5 BARG PRESSURE DROP @ 0.11 BARG
COOLING CAPACITY	25 kW

G	R03	APPROVED FOR CONSTRUCTION		27/04/26	ZYL	DWJ	DC	SJL		
F	R02	APPROVED FOR CONSTRUCTION		21/08/25	ZYL	DWJ	DC	SJL		
E	R01	APPROVED FOR CONSTRUCTION		25/04/25	ZYL	DWJ	DC	SJL		
D	R00	APPROVED FOR CONSTRUCTION (1 st GOE ISSUE)		03/12/24	ZYL	DWJ	DC	SJL		
C	R01	ISSUED FOR DESIGN / ISSUED FOR APPROVAL		24/06/24	LCE	CHS1	GYSH	HJM		
B	R00	ISSUED FOR REVIEW		21/03/24	LCE	CHS1	YOLE	HJM		
A	-	INTER DISCIPLINE CHECK		12/12/23	LCE	CHS1	OLLI	CHS1		
GOE REV	OTC REV	REASON FOR USE			DATE	DRAWN	ISSUED	CHECKED	APPROVED	
DISCIPLINE:		SYSTEM NO.	AREA / MODULE:	IMO NO.	PROJECT NO.	SCALE:	SIZE:			
MR		51	FHM	8706014	SC26-2A	N.T.S.	A3			
SUPPLIER:			PROJECT: Sakarya Gas Field Dev't Phase-2a							
 OceanSTAR Elite			 GLOBAL OFFSHORE ENGINEERING							
CLIENT:			P&ID - SEA WATER COOLING SYSTEM NO. 6 MACHINERY SPACE - SHEET 3							
 OTC			OFFSHORE TECHNOLOGY CENTER				OTC DOC. NO: SC26-2A-GOE-FHM-MR-PID-105016		GOE REV: G	SHEET 3 of 3
			LEG DOC. NO: SC26-2A-BWO-FHM-MR-PID-105016				OTC REV: R03			
			REF DOC. NO: 384-51-W-DWG-102_003							
This drawing contains proprietary information and may not be transferred, reproduced or used to construct any project other than it was issued for without the written consent of GOE or their Client.										