

71SJ7002 INTERFACES			
TP	DESCRIPTION	CONNECTION TYPE / SIZE	MATERIAL
TP-01	FIRE WATER INLET	4" SCH 40	CS HDG
TP-02	FOAM LIQUID OUTLET	4" SCH 40	CS HDG
TP-03	FOAM MONITOR INLET	3" 150# RF	BRONZE

RUNNING	71 F & G	XL	SI 7002	
REMOTE	71 F & G	XX	SI 7002	
PUMP START REQUEST	71 F & G	XA2	SI 7002	
COM. FAULT	71 F & G	XA1	SI 7002	
START/STOP	71 F & G	XA	SI 7002	

LOCATION:
ADMIN ROOM
E DECK

CONTROL PANEL
SJ7002-EC01
(EXISTING)

71SJ7002
SC26-2A-DLG-FGN-PE-PID-100000_R00

FROM FIRE RING MAIN
GOE-FLQ-MR-PID-120018
0384-KEP-V-XB-71003.001

1. THIS P&ID IS REISSUED FOR INFORMATION FOR SAKARYA PROJECT.
2. FOR P&ID LEGEND SHEET SEE DRAWING:
SC26-2A-GOE-FHM-MR-PID-105133 TO 105139.  R03
3. FOR MARINE PIPING AND VALVE MATERIAL SPECIFICATION, SEE DOCUMENT:
SC26-2A-GOE-FHM-FP-SPC-105001 (4517-RWO-1-SA-00002)
4. FOR CHANGES IN REV.03, PLEASE REFER TO ECN-00335, ECN-00476.
FOR CHANGES IN REV.02, PLEASE REFER TO ECN-00245. 

1. HYDRANT VALVES TO BE PRESSURE REGULATING TYPE AND TO LIMIT PRESSURE TO MAX 5.5 BARG.
2. DELETED.
3. DELETED.
4. DELETED.
5. HYDRANTS TO BE LOCATED ON THE PORT, STBD AND AFT OF THE HELIDECK.
6. INSULATION KIT TO BE PROVIDED.
7. NEW PIPE INSERTING POINT TO FOLLOW SITE CONDITION.
8. VACUUM BREAKER AIR RELEASE VALVE TO BE MOUNTED AT THE HIGHEST POINT OF PIPE. INSULATION TO FOLLOW SITE CONDITION.

	EXISTING PIPE
	NEW PIPE
	PIPE WITH HEATING TRACING
	INSULATED PIPE

1. DELETED
2. DELETED
3. DELETED
4. DELETED

-	R03	ISSUED FOR INFORMATION	20/05/26	ZYL	DWJ	DC	SJL
-	R02	ISSUED FOR INFORMATION	18/08/25	ZYL	DWJ	DC	SJL
-	R01	ISSUED FOR INFORMATION	30/04/25	ZYL	DWJ	DC	SJL
-	R00	ISSUED FOR INFORMATION (1 GOE ISSUE)	24/01/25	ZYL	DWJ	DC	SJL
Z0	-	ISSUED FOR AS-BUILT	28/09/22	JT	JT	NO	PL
02	-	RE-ISSUED FOR CONSTRUCTION	19/04/21	XH	JT	NO	PL
01	-	RE-ISSUED FOR CONSTRUCTION	28/09/20	XH	JT	NO	PL
00	-	ISSUED FOR CONSTRUCTION	23/12/19	XH	JT	NO	PL
C	-	ISSUED FOR DESIGN	24/07/19	XH	JT	NO	PL
B	-	ISSUED FOR REVIEW	17/05/19	XH	JT	NO	PL
A	-	ISSUED FOR IDC	09/05/19	BL	JT	NO	PL

REV	REV	REASON FOR USE				DATE	DRAWN	ISSUED	CHECKED	APPROVED	
DISCIPLINE:		SYSTEM NO:	AREA / MODULE:	IMO NO:	PROJECT NO:	SCALE:		SIZE:			
MR		71	FHM:	8706014	SC26-2A	N.T.S.		A3			
SUPPLIER:			PROJECT: Sakarya Gas Field Dev't Phase-2a								
 OceanSTAR Elite			 GLOBAL OFFSHORE ENGINEERING			TITLE:					
			P&ID - HELIDECK FOAM SYSTEM								
CLIENT:			OTC DOC. NO: SC26-2A-GOE-FHM-MR-PID-105070						GOE REV. -		SHEET
 OTC OFFSHORE TECHNOLOGY CENTER			LEG. DOC. NO: -						C/03		1 of 1
			REF. DOC. NO: 0384-KFP-V-XR-71005.001						OTC REV.		

This drawing contains proprietary information and may not be transferred, reproduced or used to construct any project other than it was issued for without the written consent of GOE or their Client.