

EQUIP. TAG	82EG5501B-DD01
EQUIP. NAME	ESSENTIAL GENERATOR B ENGINE
CONFIGURATION	3 X 50%
ENGINE OUTPUT	1302kWm @ 1800RPM

SYSTEM PARAMETERS		
SERVICE	FRESH WATER COOLING	MGO
DESIGN PRESSURE(Barg)	8.0	7.0
OPERATING PRESSURE(Barg)	6.0	6.0
DESIGN TEMPERATURE(°C)	65.0	60.0
OPERATING TEMPERATURE(°C)	AVG. 44	54.0

1. ESD 2.1 WILL TRIP ESSENTIAL GENERATOR BATTERY BANKS.
2. FLEXIBLE CONNECTION TO BE PROVIDED BY GENSET VENDOR.
3. WEATHER PROOF FLAME SCREEN.
4. SAMPLING POINT TO USE 5" BS10 FLANGE.
5. VALVE TO BE OPERABLE FROM FLOOR LEVEL.
6. REFER TO VENDOR DRAWING 0384-CSS-V-XB-82002.001 FOR GENERATOR P&ID AND 0384-CSS-V-XE-00001.001 FOR GA LAYOUT.
7. FOR SIGNALS BETWEEN ICSS AND VENDOR PACKAGE, REFER TO 0384-KEP-1-LA-00008.
8. VENDOR SUPPLY.
9. SAMPLING POINT TO BE CLEARLY MARKED ON SITE. REFER TO IMO RULE MEPC.1/CIRC.864/REV1.

1. THIS P&ID IS REISSUED FOR INFORMATION FOR SAKARYA PROJECT.
2. NO CHANGE IN SYSTEM.
3. FOR P&ID LEGEND SHEET SEE DRAWING:
SC26-2A-GOE-FHM-MR-PID-105133 TO 105139.
4. FOR MARINE PIPING AND VALVE MATERIAL SPECIFICATION, SEE DOCUMENT:
SC26-2A-GOE-FHM-EP-SPC-105001 (4517-BWO-1-SA-00002).
5. FOR CHANGES IN REV03, PLEASE REFER TO ECN-00336, ECN-00344.


 EXISTING PIPE
 INSULATED PIPE

[illegible]