



EQUIP. TAG	57PD5501
EQUIP. NAME	LABORATORY DRAIN TANK PUMP
CAPACITY	1 m ³ /h @ 2 barg
CONFIGURATION	1 x 100%
DESIGN (WORKING) PRESSURE	9 (2)

63-3/4"-AP-G1-5548

SERVICE AIR SUPPLY
GOE-FHM-MR-PID-105100
0384-KEP-V-XB-63001.001

68-1"-NG-G2-5503

NOTE 3

LAB BENCHTOP

FUME
CABINET
(LB30)

S

CLOSED DRAIN HEADER
G0E-FHM-MR-PID-105045
384-57-P-DWG-100_001
57-1"-DC-G7-1011

56-1"-DO-G1-5712

MAIN-DECK
ENGINE RM

LABORATORY DRAIN
PUMP

(57PD5501)

TO ENGINE ROOM DRAIN
GOE-FHM-MR-PID-105092
0384-KEP-V-XB-56006.00

66-2"-DS-G1-5692

R03

1. THIS P&ID IS REISSUED FOR INFORMATION FOR SAKARYA PROJECT.
2. NO CHANGE IN SYSTEM.

3. FOR P&ID I EGEND SHEET SEE DRAWING:

SC26-2A-GOF-FHM-MR-PID-105133 TO 105139

4. FOR MARINE PIPING AND VALVE MATERIAL SPECIFICATION SEE DOCUMENT:

C26-2A-GOE-FHM-EP-SPC-105001 (4517-BWO-L-SA-00002)

5. FOR CHANGES IN REV.03, PLEASE REFER TO ECN-00415

NOTES:

1. GREY WATER PIPES SLOPE TO BE 1:100 U.N.O.
2. VENDOR SUPPLIED.
3. FUTURE SCOPE.
4. NO HAZARDOUS SUBSTANCE TO BE DISCHARGED.

LEGENDS:

EXISTING PIPE

F

REV#		REV									
DISCIPLINE:		SYSTEM NO.:		AREA / MODULE:		MO NO.:		PROJECT NO.:		SCALE:	
MR		66		FLQ		8706014		SC26-2A		N.T.S.	
SUPPLIER:						PROJECT:		Sakarya Gas Field Dev't Phase-2a			
				TITLE:							
				P&ID - ACCOMMODATION BLACK AND GREY WATER SYSTEM (SHEET 3)							
CLIENT:		 OTC OFFSHORE TECHNOLOGY CENTER		OTC DOC. NO. SC26-2A-GOE-FLQ-MR-PID-120010						GOE REV. - SHEET	
				LEG DOC. NO. _____						OTC REV. - 3 of 3	
				REF. DOC. NO. 0384-KEP-V-XB-66001.003							
This drawing contains proprietary information and may not be transferred, reproduced or used to construct any project other than it was issued for without the written consent of GOE or their Client.											

This drawing contains proprietary information and may not be transferred, reproduced or used to construct any project other than it was issued for without the written consent of GOE or their Client.