

# TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd  
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd

Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 01

Product : REGULAR

Date generated 04/06/2023

Effective Dates : 03/07/23 to 04/05/23

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
3/7/2023	3,942.00	0.00	931.00	0.00	3,011.00	3,008.00	0.00	-3.00	-3.00	
3/8/2023	3,008.00	0.00	970.00	0.00	2,038.00	2,039.00	0.00	1.00	-2.00	
3/9/2023	2,039.00	0.00	916.00	0.00	1,123.00	1,128.00	0.00	5.00	3.00	
3/10/2023	1,128.00	0.00	802.00	0.00	326.00	331.00	0.00	5.00	8.00	
3/11/2023	331.00	6,000.00	1,323.00	0.00	5,008.00	5,008.00	0.00	0.00	8.00	Verif.Sales
3/12/2023	5,008.00	0.00	1,166.00	0.00	3,842.00	3,842.00	0.00	0.00	8.00	Verif.Sales
3/13/2023	3,842.00	0.00	877.00	0.00	2,965.00	2,962.00	0.00	-3.00	5.00	
3/14/2023	2,962.00	0.00	878.00	0.00	2,084.00	2,084.00	0.00	0.00	5.00	Verif.Sales
3/15/2023	2,084.00	6,467.00	942.00	0.00	7,609.00	7,669.00	0.00	60.00	65.00	
3/16/2023	7,669.00	0.00	977.00	0.00	6,692.00	6,680.00	0.00	-12.00	53.00	
3/17/2023	6,680.00	0.00	0.00	0.00	6,680.00	6,680.00	0.00	0.00	53.00	
3/18/2023	6,680.00	0.00	2,470.00	0.00	4,210.00	4,190.00	0.00	-20.00	33.00	
3/19/2023	4,190.00	0.00	1,094.00	0.00	3,096.00	3,087.00	0.00	-9.00	24.00	
3/20/2023	3,087.00	0.00	1,085.00	0.00	2,002.00	2,013.00	0.00	11.00	35.00	
3/21/2023	2,013.00	0.00	900.00	0.00	1,113.00	1,102.00	0.00	-11.00	24.00	
3/22/2023	1,102.00	0.00	775.00	0.00	327.00	331.00	0.00	4.00	28.00	
3/23/2023	331.00	6,500.00	1,052.00	0.00	5,779.00	5,780.00	0.00	1.00	29.00	
3/24/2023	5,780.00	0.00	1,188.00	0.00	4,592.00	4,587.00	0.00	-5.00	24.00	
3/25/2023	4,587.00	0.00	1,252.00	0.00	3,335.00	3,330.00	0.00	-5.00	19.00	
3/26/2023	3,330.00	0.00	1,194.00	0.00	2,136.00	2,134.00	0.00	-2.00	17.00	
3/27/2023	2,134.00	0.00	1,156.00	0.00	978.00	966.00	0.00	-12.00	5.00	
3/28/2023	966.00	2,583.00	1,103.00	0.00	2,446.00	2,507.00	0.00	61.00	66.00	
3/29/2023	2,507.00	0.00	818.00	0.00	1,689.00	1,693.00	0.00	4.00	70.00	
3/30/2023	1,693.00	0.00	1,048.00	0.00	645.00	648.00	0.00	3.00	73.00	
3/31/2023	648.00	6,501.00	989.00	0.00	6,160.00	6,177.00	0.00	17.00	90.00	
4/1/2023	6,177.00	0.00	888.00	0.00	5,289.00	5,285.00	0.00	-4.00	86.00	
4/2/2023	5,285.00	0.00	937.00	0.00	4,348.00	4,337.00	0.00	-11.00	75.00	
4/3/2023	4,337.00	0.00	1,057.00	0.00	3,280.00	3,276.00	0.00	-4.00	71.00	
4/4/2023	3,276.00	0.00	1,055.00	0.00	2,221.00	2,229.00	0.00	8.00	79.00	
4/5/2023	2,229.00	0.00	797.00	0.00	1,432.00	1,436.00	0.00	4.00	83.00	
TOTALS		28,051.00	30,640.00	0.00			0.00	83.00	83.00	

Leak Check = ( 30,640.00 \* 0.01 + 130 ) = 436.4 gall

## Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	436.4 gall	0.0 inches	0.0638 gph	0.0404 gph	PASS	PASS	PASS
Min. Daily Sales :		0.0	Max. Daily Sales :	2470.0	Avg. Daily Sales :		1021.3

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.  
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496

# TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd  
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd

Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 02

Product : SUPER

Date generated 04/06/2023

Effective Dates : 03/07/23 to 04/05/23

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
3/7/2023	1,132.00	0.00	176.00	0.00	956.00	956.00	0.00	0.00	0.00	Verif.Sales
3/8/2023	956.00	0.00	107.00	0.00	849.00	850.00	0.00	1.00	1.00	
3/9/2023	850.00	0.00	122.00	0.00	728.00	728.00	0.00	0.00	1.00	Verif.Sales
3/10/2023	728.00	0.00	94.00	0.00	634.00	634.00	0.00	0.00	1.00	Verif.Sales
3/11/2023	634.00	1,000.00	175.00	0.00	1,459.00	1,459.00	0.00	0.00	1.00	Verif.Sales
3/12/2023	1,459.00	0.00	114.00	0.00	1,345.00	1,346.00	0.00	1.00	2.00	
3/13/2023	1,346.00	0.00	154.00	0.00	1,192.00	1,193.00	0.00	1.00	3.00	
3/14/2023	1,193.00	0.00	50.00	0.00	1,143.00	1,143.00	0.00	0.00	3.00	Verif.Sales
3/15/2023	1,143.00	700.00	107.00	0.00	1,736.00	1,733.00	0.00	-3.00	0.00	
3/16/2023	1,733.00	0.00	135.00	0.00	1,598.00	1,600.00	0.00	2.00	2.00	
3/17/2023	1,600.00	0.00	0.00	0.00	1,600.00	1,600.00	0.00	0.00	2.00	
3/18/2023	1,600.00	0.00	295.00	0.00	1,305.00	1,305.00	0.00	0.00	2.00	Verif.Sales
3/19/2023	1,305.00	0.00	123.00	0.00	1,182.00	1,182.00	0.00	0.00	2.00	Verif.Sales
3/20/2023	1,182.00	0.00	100.00	0.00	1,082.00	1,082.00	0.00	0.00	2.00	Verif.Sales
3/21/2023	1,082.00	0.00	132.00	0.00	950.00	949.00	0.00	-1.00	1.00	
3/22/2023	949.00	0.00	132.00	0.00	817.00	817.00	0.00	0.00	1.00	Verif.Sales
3/23/2023	817.00	700.00	101.00	0.00	1,416.00	1,420.00	0.00	4.00	5.00	
3/24/2023	1,420.00	0.00	129.00	0.00	1,291.00	1,292.00	0.00	1.00	6.00	
3/25/2023	1,292.00	0.00	112.00	0.00	1,180.00	1,180.00	0.00	0.00	6.00	Verif.Sales
3/26/2023	1,180.00	0.00	197.00	0.00	983.00	983.00	0.00	0.00	6.00	Verif.Sales
3/27/2023	983.00	0.00	80.00	0.00	903.00	903.00	0.00	0.00	6.00	Verif.Sales
3/28/2023	903.00	0.00	161.00	0.00	742.00	741.00	0.00	-1.00	5.00	
3/29/2023	741.00	0.00	139.00	0.00	602.00	603.00	0.00	1.00	6.00	
3/30/2023	603.00	0.00	186.00	0.00	417.00	417.00	0.00	0.00	6.00	Verif.Sales
3/31/2023	417.00	2,000.00	130.00	0.00	2,287.00	2,299.00	0.00	12.00	18.00	
4/1/2023	2,299.00	0.00	167.00	0.00	2,132.00	2,134.00	0.00	2.00	20.00	
4/2/2023	2,134.00	0.00	127.00	0.00	2,007.00	2,007.00	0.00	0.00	20.00	Verif.Sales
4/3/2023	2,007.00	0.00	143.00	0.00	1,864.00	1,866.00	0.00	2.00	22.00	
4/4/2023	1,866.00	0.00	134.00	0.00	1,732.00	1,733.00	0.00	1.00	23.00	
4/5/2023	1,733.00	0.00	182.00	0.00	1,551.00	1,553.00	0.00	2.00	25.00	
TOTALS		4,400.00	4,004.00	0.00			0.00	25.00	25.00	

Leak Check = ( 4,004.00 \* 0.01 + 130 ) = 170.0 gall

## Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago	
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result	
0.1000	170.0 gall	0.0 inches	0.0008 gph	0.0085 gph	PASS	PASS	PASS	
Min. Daily Sales :		0.0	Max. Daily Sales :		295.0	Avg. Daily Sales :		133.5

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.  
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496