



## LINE AND LEAK DETECTOR TEST DATA FORM

**Facility Name:** Kool Corner **Date:** 8/21/2024

**Facility Address:** 6413 Manor Rd  
Austin, TX 78723

**Facility Phone:** 512-905-4631

**Test Contractor:** PETRO-TANK SOLUTIONS, LLC  
**Address:** 803 Summer Park Dr, Ste #150  
STAFFORD, TX 77477 **Tester:** Anil Momin

**Contractor Phone:** (281) 242-2687 **License #** 4865.LTN

<b>Product</b>	<b>REGULAR</b>	<b>SUPER</b>		
<b>Pump Manufacturer</b>	Red Jacket	Red Jacket		
<b>Isolation Mechanism</b>	Ball Valve	Ball Valve		
<b>Test Pressure</b> (1 1/2 times working pressure)	50 PSI	50 PSI		
<b>Initial Cylinder Level (ICL)</b>	0.040	0.040		
<b>Final Cylinder Level (FCL)</b>	0.040	0.040		
<b>Leak Volume = ICL - FCL</b>	0.000	0.000		
<b>Time Started</b>	1:00	1:45		
<b>Time Completed</b>	1:30	2:15		
<b>Total Test Time</b> (30 min. minimum)	30 MIN	30 MIN		
<b>Conclusion (Pass or Fail)</b>	<b>Pass</b>	<b>Pass</b>		
<b>Leak Detector Manufacturer</b>	Red Jacket	Red Jacket		
<b>Line PSI</b>	30 PSI	28 PSI		
<b>Leak Detector Result</b> (Pass or Fail)	<b>Pass</b>	<b>Pass</b>		

**Comments:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_