

# TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd  
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd

Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 01

Product : REGULAR

Date generated 03/04/2024

Effective Dates : 01/31/24 to 02/29/24

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
1/31/2024	4,999.00	0.00	0.00	0.00	4,999.00	4,999.00	0.00	0.00	0.00	
2/1/2024	4,999.00	0.00	0.00	0.00	4,999.00	4,999.00	0.00	0.00	0.00	
2/2/2024	4,999.00	0.00	0.00	0.00	4,999.00	5,000.00	0.00	1.00	1.00	Verif.Stick
2/3/2024	5,000.00	0.00	0.00	0.00	5,000.00	5,000.00	0.00	0.00	1.00	
2/4/2024	5,000.00	0.00	0.00	0.00	5,000.00	5,001.00	0.00	1.00	2.00	Verif.Stick
2/5/2024	5,001.00	0.00	0.00	0.00	5,001.00	5,002.00	0.00	1.00	3.00	Verif.Stick
2/6/2024	5,002.00	0.00	0.00	0.00	5,002.00	5,003.00	0.00	1.00	4.00	Verif.Stick
2/7/2024	5,003.00	0.00	0.00	0.00	5,003.00	5,003.00	0.00	0.00	4.00	
2/8/2024	5,003.00	0.00	0.00	0.00	5,003.00	5,004.00	0.00	1.00	5.00	Verif.Stick
2/9/2024	5,004.00	0.00	0.00	0.00	5,004.00	5,005.00	0.00	1.00	6.00	Verif.Stick
2/10/2024	5,005.00	0.00	0.00	0.00	5,005.00	5,005.00	0.00	0.00	6.00	
2/11/2024	5,005.00	0.00	0.00	0.00	5,005.00	5,006.00	0.00	1.00	7.00	Verif.Stick
2/12/2024	5,006.00	0.00	0.00	0.00	5,006.00	5,007.00	0.00	1.00	8.00	Verif.Stick
2/13/2024	5,007.00	0.00	0.00	0.00	5,007.00	5,007.00	0.00	0.00	8.00	
2/14/2024	5,007.00	0.00	0.00	0.00	5,007.00	5,008.00	0.00	1.00	9.00	Verif.Stick
2/15/2024	5,008.00	0.00	0.00	0.00	5,008.00	5,008.00	0.00	0.00	9.00	
2/16/2024	5,008.00	0.00	0.00	0.00	5,008.00	5,008.00	0.00	0.00	9.00	
2/17/2024	5,008.00	0.00	0.00	0.00	5,008.00	5,009.00	0.00	1.00	10.00	Verif.Stick
2/18/2024	5,009.00	0.00	0.00	0.00	5,009.00	5,009.00	0.00	0.00	10.00	
2/19/2024	5,009.00	0.00	0.00	0.00	5,009.00	5,009.00	0.00	0.00	10.00	
2/20/2024	5,009.00	0.00	0.00	0.00	5,009.00	5,010.00	0.00	1.00	11.00	Verif.Stick
2/21/2024	5,010.00	0.00	0.00	0.00	5,010.00	5,010.00	0.00	0.00	11.00	
2/22/2024	5,010.00	0.00	0.00	0.00	5,010.00	5,010.00	0.00	0.00	11.00	
2/23/2024	5,010.00	0.00	0.00	0.00	5,010.00	5,010.00	0.00	0.00	11.00	
2/24/2024	5,010.00	0.00	0.00	0.00	5,010.00	5,010.00	0.00	0.00	11.00	
2/25/2024	5,010.00	0.00	0.00	0.00	5,010.00	5,011.00	0.00	1.00	12.00	Verif.Stick
2/26/2024	5,011.00	0.00	0.00	0.00	5,011.00	5,011.00	0.00	0.00	12.00	
2/27/2024	5,011.00	0.00	0.00	0.00	5,011.00	5,012.00	0.00	1.00	13.00	Verif.Stick
2/28/2024	5,012.00	0.00	102.00	0.00	4,910.00	4,905.00	0.00	-5.00	8.00	
2/29/2024	4,905.00	0.00	580.00	0.00	4,325.00	4,322.00	0.00	-3.00	5.00	
TOTALS		0.00	682.00	0.00			0.00	5.00	5.00	

Leak Check = ( 682.00 \* 0.01 + 130 ) = 136.8 gall

## Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	136.8 gall	0.0 inches	0.0069 gph	0.0037 gph	PASS	PASS	PASS
Min. Daily Sales :		0.0	Max. Daily Sales :		580.0	Avg. Daily Sales : 22.7	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.  
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496

# TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd  
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd  
Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 02

Product : SUPER

Date generated 03/04/2024

Effective Dates : 01/31/24 to 02/29/24

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
1/31/2024	1,411.00	0.00	0.00	0.00	1,411.00	1,411.00	0.00	0.00	0.00	
2/1/2024	1,411.00	0.00	0.00	0.00	1,411.00	1,410.00	0.00	-1.00	-1.00	
2/2/2024	1,410.00	0.00	0.00	0.00	1,410.00	1,410.00	0.00	0.00	-1.00	
2/3/2024	1,410.00	0.00	0.00	0.00	1,410.00	1,410.00	0.00	0.00	-1.00	
2/4/2024	1,410.00	0.00	0.00	0.00	1,410.00	1,411.00	0.00	1.00	0.00	Verif.Stick
2/5/2024	1,411.00	0.00	0.00	0.00	1,411.00	1,411.00	0.00	0.00	0.00	
2/6/2024	1,411.00	0.00	0.00	0.00	1,411.00	1,411.00	0.00	0.00	0.00	
2/7/2024	1,411.00	0.00	0.00	0.00	1,411.00	1,411.00	0.00	0.00	0.00	
2/8/2024	1,411.00	0.00	0.00	0.00	1,411.00	1,411.00	0.00	0.00	0.00	
2/9/2024	1,411.00	0.00	0.00	0.00	1,411.00	1,411.00	0.00	0.00	0.00	
2/10/2024	1,411.00	0.00	0.00	0.00	1,411.00	1,411.00	0.00	0.00	0.00	
2/11/2024	1,411.00	0.00	0.00	0.00	1,411.00	1,411.00	0.00	0.00	0.00	
2/12/2024	1,411.00	0.00	0.00	0.00	1,411.00	1,411.00	0.00	0.00	0.00	
2/13/2024	1,411.00	0.00	0.00	0.00	1,411.00	1,411.00	0.00	0.00	0.00	
2/14/2024	1,411.00	0.00	0.00	0.00	1,411.00	1,411.00	0.00	0.00	0.00	
2/15/2024	1,411.00	0.00	0.00	0.00	1,411.00	1,411.00	0.00	0.00	0.00	
2/16/2024	1,411.00	0.00	0.00	0.00	1,411.00	1,411.00	0.00	0.00	0.00	
2/17/2024	1,411.00	0.00	0.00	0.00	1,411.00	1,411.00	0.00	0.00	0.00	
2/18/2024	1,411.00	0.00	0.00	0.00	1,411.00	1,411.00	0.00	0.00	0.00	
2/19/2024	1,411.00	0.00	0.00	0.00	1,411.00	1,410.00	0.00	-1.00	-1.00	
2/20/2024	1,410.00	0.00	0.00	0.00	1,410.00	1,410.00	0.00	0.00	-1.00	
2/21/2024	1,410.00	0.00	0.00	0.00	1,410.00	1,410.00	0.00	0.00	-1.00	
2/22/2024	1,410.00	0.00	0.00	0.00	1,410.00	1,410.00	0.00	0.00	-1.00	
2/23/2024	1,410.00	0.00	0.00	0.00	1,410.00	1,410.00	0.00	0.00	-1.00	
2/24/2024	1,410.00	0.00	0.00	0.00	1,410.00	1,410.00	0.00	0.00	-1.00	
2/25/2024	1,410.00	0.00	0.00	0.00	1,410.00	1,410.00	0.00	0.00	-1.00	
2/26/2024	1,410.00	0.00	0.00	0.00	1,410.00	1,410.00	0.00	0.00	-1.00	
2/27/2024	1,410.00	0.00	0.00	0.00	1,410.00	1,410.00	0.00	0.00	-1.00	
2/28/2024	1,410.00	0.00	6.00	0.00	1,404.00	1,374.00	0.00	-30.00	-31.00	
2/29/2024	1,374.00	0.00	66.00	0.00	1,308.00	1,307.00	0.00	-1.00	-32.00	
TOTALS		0.00	72.00	0.00			0.00	-32.00	-32.00	

Leak Check = ( 72.00 \* 0.01 + 130 ) = 130.7 gall

## Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	130.7 gall	0.0 inches	-0.0048 gph	0.0041 gph	PASS	PASS	PASS
Min. Daily Sales :		0.0	Max. Daily Sales :		66.0	Avg. Daily Sales : 2.4	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.  
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496