

Re: Statement of Certification

RE: Proof of Corrosion Protection on Tanks and Product Lines – Foodies Corner #5, 1405 W
Whitestone Blvd, Cedar Park, TX 78613 TCEQ Facility # 55347

To Whom It May Concern:

On November 5, 2020, a corrosion protection investigation was conducted on the underground storage tanks and product lines at Foodies Corner #5. Tank-to-soil potential readings, continuity tests, and current requirement tests indicated that the tanks are single wall FRP. Local tank-to-soil potential readings were all 0 mV for the Regular, Super and Diesel tanks. The tank risers are not continuous with tank bottoms, and the tank diameters are 92". The tank capacities are 8,000-gallon (Regular), 8,000-gallon (Super) and 8,000-gallon (Diesel). According to available records Regular, Super and Diesel tanks were installed in 1988.

The product lines were visually verified at STP as single wall FRP.


The corrosion protection on the tank and product lines has been verified to meet TCEQ requirements, and additional corrosion protection is not required.

Hereby Signed:

Respectfully,



Dr. Gerald D. Hill, PE, CAPM
Consultant, Licensed Professional
Engineer (TX #73967)



Date

