



## LINE AND LEAK DETECTOR TEST DATA FORM

Facility Name: Big Bucket 4 Date: 7/16/2024

Facility Address: 3250 E Palm Valley Blvd  
Round Rock, Tx 78665

Facility Phone: 512-986-0067

Test Contractor: PETRO-TANK SOLUTIONS, LLC  
Address: 803 Summer Park Dr, Ste #150

STAFFORD, TX 77477

Contractor Phone: (281) 242-2687

Tester: Anil Momin

Method: Hasstech ACURITE Pipeline Tester

License # 4865.LTN

Product	REGULAR	SUPER	DIESEL	
Pump Manufacturer	Red Jacket	Red Jacket	Red Jacket	
Isolation Mechanism	Ball Valve	Ball Valve	Ball Valve	
Test Pressure (1 1/2 times working pressure)	50 PSI	50 PSI	50 PSI	
Initial Cylinder Level (ICL)	0.040	0.040	0.075	
Final Cylinder Level (FCL)	0.040	0.040	0.075	
Leak Volume = ICL - FCL	0.000	0.000	0.000	
Time Started	10:30	10:30	11:15	
Time Completed	11:00	11:00	11:45	
Total Test Time (30 min. minimum)	30 MIN	30 MIN	30 MIN	
Conclusion (Pass or Fail)	Pass	Pass	Pass	
Leak Detector Manufacturer	PLLD	PLLD	PLLD	
Line PSI	29 PSI	27 PSI	26 PSI	
Leak Detector Result (Pass or Fail)	Pass	Pass	Pass	

Comments: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_