

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd
Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 01

Product : REGULAR

Date generated 08/03/2024

Effective Dates : 06/29/24 to 07/28/24

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
6/29/2024	1,566.00	0.00	951.00	0.00	615.00	614.00	0.00	-1.00	-1.00	
6/30/2024	614.00	6,802.00	1,061.00	0.00	6,355.00	6,380.00	0.00	25.00	24.00	
7/1/2024	6,380.00	0.00	995.00	0.00	5,385.00	5,378.00	0.00	-7.00	17.00	
7/2/2024	5,378.00	0.00	1,021.00	0.00	4,357.00	4,358.00	0.00	1.00	18.00	
7/3/2024	4,358.00	0.00	939.00	0.00	3,419.00	3,421.00	0.00	2.00	20.00	
7/4/2024	3,421.00	0.00	641.00	0.00	2,780.00	2,766.00	0.00	-14.00	6.00	
7/5/2024	2,766.00	0.00	752.00	0.00	2,014.00	2,015.00	0.00	1.00	7.00	
7/6/2024	2,015.00	0.00	836.00	0.00	1,179.00	1,183.00	0.00	4.00	11.00	
7/7/2024	1,183.00	5,500.00	816.00	0.00	5,867.00	5,891.00	0.00	24.00	35.00	
7/8/2024	5,891.00	0.00	896.00	0.00	4,995.00	4,996.00	0.00	1.00	36.00	
7/9/2024	4,996.00	0.00	977.00	0.00	4,019.00	4,019.00	0.00	0.00	36.00	Verif.Sales
7/10/2024	4,019.00	0.00	1,018.00	0.00	3,001.00	2,995.00	0.00	-6.00	30.00	
7/11/2024	2,995.00	0.00	800.00	0.00	2,195.00	2,189.00	0.00	-6.00	24.00	
7/12/2024	2,189.00	0.00	1,012.00	0.00	1,177.00	1,188.00	0.00	11.00	35.00	
7/13/2024	1,188.00	6,002.00	1,026.00	0.00	6,164.00	6,193.00	0.00	29.00	64.00	
7/14/2024	6,193.00	0.00	944.00	0.00	5,249.00	5,242.00	0.00	-7.00	57.00	
7/15/2024	5,242.00	0.00	1,166.00	0.00	4,076.00	4,074.00	0.00	-2.00	55.00	
7/16/2024	4,074.00	0.00	854.00	0.00	3,220.00	3,215.00	0.00	-5.00	50.00	
7/17/2024	3,215.00	0.00	915.00	0.00	2,300.00	2,298.00	0.00	-2.00	48.00	
7/18/2024	2,298.00	0.00	951.00	0.00	1,347.00	1,351.00	0.00	4.00	52.00	
7/19/2024	1,351.00	5,900.00	987.00	0.00	6,264.00	6,302.00	0.00	38.00	90.00	
7/20/2024	6,302.00	0.00	1,036.00	0.00	5,266.00	5,259.00	0.00	-7.00	83.00	
7/21/2024	5,259.00	0.00	818.00	0.00	4,441.00	4,438.00	0.00	-3.00	80.00	
7/22/2024	4,438.00	0.00	932.00	0.00	3,506.00	3,501.00	0.00	-5.00	75.00	
7/23/2024	3,501.00	0.00	994.00	0.00	2,507.00	2,502.00	0.00	-5.00	70.00	
7/24/2024	2,502.00	0.00	1,036.00	0.00	1,466.00	1,469.00	0.00	3.00	73.00	
7/25/2024	1,469.00	5,500.00	878.00	0.00	6,091.00	6,110.00	0.00	19.00	92.00	
7/26/2024	6,110.00	0.00	890.00	0.00	5,220.00	5,217.00	0.00	-3.00	89.00	
7/27/2024	5,217.00	0.00	806.00	0.00	4,411.00	4,409.00	0.00	-2.00	87.00	
7/28/2024	4,409.00	0.00	955.00	0.00	3,454.00	3,460.00	0.00	6.00	93.00	
TOTALS		29,704.00	27,903.00	0.00			0.00	93.00	93.00	

Leak Check = (27,903.00 * 0.01 + 130) = 409.0 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	409.0 gall	0.0 inches	-0.0478 gph	0.0399 gph	PASS	PASS	PASS
Min. Daily Sales :		641.0	Max. Daily Sales :		1166.0	Avg. Daily Sales : 930.1	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner
6413 Manor Rd
Austin

TX

78723

Owner ID:
Facility ID: 67397
Tank : 02
Product : SUPER

Date generated 08/03/2024

Effective Dates : 06/29/24 to 07/28/24

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
6/29/2024	1,022.00	0.00	116.00	0.00	906.00	907.00	0.00	1.00	1.00	
6/30/2024	907.00	800.00	119.00	0.00	1,588.00	1,587.00	0.00	-1.00	0.00	
7/1/2024	1,587.00	0.00	84.00	0.00	1,503.00	1,504.00	0.00	1.00	1.00	
7/2/2024	1,504.00	0.00	87.00	0.00	1,417.00	1,418.00	0.00	1.00	2.00	
7/3/2024	1,418.00	0.00	94.00	0.00	1,324.00	1,325.00	0.00	1.00	3.00	
7/4/2024	1,325.00	0.00	88.00	0.00	1,237.00	1,238.00	0.00	1.00	4.00	
7/5/2024	1,238.00	0.00	99.00	0.00	1,139.00	1,140.00	0.00	1.00	5.00	
7/6/2024	1,140.00	0.00	96.00	0.00	1,044.00	1,044.00	0.00	0.00	5.00	Verif.Sales
7/7/2024	1,044.00	500.00	87.00	0.00	1,457.00	1,457.00	0.00	0.00	5.00	Verif.Sales
7/8/2024	1,457.00	0.00	73.00	0.00	1,384.00	1,390.00	0.00	6.00	11.00	
7/9/2024	1,390.00	0.00	144.00	0.00	1,246.00	1,248.00	0.00	2.00	13.00	
7/10/2024	1,248.00	0.00	106.00	0.00	1,142.00	1,143.00	0.00	1.00	14.00	
7/11/2024	1,143.00	0.00	130.00	0.00	1,013.00	1,014.00	0.00	1.00	15.00	
7/12/2024	1,014.00	0.00	122.00	0.00	892.00	892.00	0.00	0.00	15.00	Verif.Sales
7/13/2024	892.00	700.00	107.00	0.00	1,485.00	1,488.00	0.00	3.00	18.00	
7/14/2024	1,488.00	0.00	97.00	0.00	1,391.00	1,392.00	0.00	1.00	19.00	
7/15/2024	1,392.00	0.00	81.00	0.00	1,311.00	1,311.00	0.00	0.00	19.00	Verif.Sales
7/16/2024	1,311.00	0.00	107.00	0.00	1,204.00	1,206.00	0.00	2.00	21.00	
7/17/2024	1,206.00	0.00	99.00	0.00	1,107.00	1,107.00	0.00	0.00	21.00	Verif.Sales
7/18/2024	1,107.00	0.00	119.00	0.00	988.00	988.00	0.00	0.00	21.00	Verif.Sales
7/19/2024	988.00	700.00	95.00	0.00	1,593.00	1,592.00	0.00	-1.00	20.00	
7/20/2024	1,592.00	0.00	89.00	0.00	1,503.00	1,505.00	0.00	2.00	22.00	
7/21/2024	1,505.00	0.00	104.00	0.00	1,401.00	1,403.00	0.00	2.00	24.00	
7/22/2024	1,403.00	0.00	108.00	0.00	1,295.00	1,296.00	0.00	1.00	25.00	
7/23/2024	1,296.00	0.00	114.00	0.00	1,182.00	1,187.00	0.00	5.00	30.00	
7/24/2024	1,187.00	0.00	79.00	0.00	1,108.00	1,108.00	0.00	0.00	30.00	Verif.Sales
7/25/2024	1,108.00	1,000.00	126.00	0.00	1,982.00	1,981.00	0.00	-1.00	29.00	
7/26/2024	1,981.00	0.00	101.00	0.00	1,880.00	1,882.00	0.00	2.00	31.00	
7/27/2024	1,882.00	0.00	76.00	0.00	1,806.00	1,806.00	0.00	0.00	31.00	Verif.Sales
7/28/2024	1,806.00	0.00	110.00	0.00	1,696.00	1,698.00	0.00	2.00	33.00	
TOTALS		3,700.00	3,057.00	0.00			0.00	33.00	33.00	

Leak Check = (3,057.00 * 0.01 + 130) = 160.6 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	160.6 gall	0.0 inches	0.0306 gph	0.0048 gph	PASS	PASS	PASS
Min. Daily Sales :		73.0	Max. Daily Sales :		144.0	Avg. Daily Sales : 101.9	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496