

# TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd  
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd  
Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 01

Product : REGULAR

Date generated 12/04/2023

Effective Dates : 11/02/23 to 12/01/23

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
11/2/2023	1,378.00	6,000.00	1,066.00	0.00	6,312.00	6,336.00	0.00	24.00	24.00	
11/3/2023	6,336.00	0.00	952.00	0.00	5,384.00	5,389.00	0.00	5.00	29.00	
11/4/2023	5,389.00	0.00	968.00	0.00	4,421.00	4,417.00	0.00	-4.00	25.00	
11/5/2023	4,417.00	0.00	903.00	0.00	3,514.00	3,505.00	0.00	-9.00	16.00	
11/6/2023	3,505.00	0.00	781.00	0.00	2,724.00	2,717.00	0.00	-7.00	9.00	
11/7/2023	2,717.00	0.00	1,017.00	0.00	1,700.00	1,696.00	0.00	-4.00	5.00	
11/8/2023	1,696.00	0.00	830.00	0.00	866.00	865.00	0.00	-1.00	4.00	
11/9/2023	865.00	6,700.00	798.00	0.00	6,767.00	6,780.00	0.00	13.00	17.00	
11/10/2023	6,780.00	0.00	877.00	0.00	5,903.00	5,893.00	0.00	-10.00	7.00	
11/11/2023	5,893.00	0.00	875.00	0.00	5,018.00	5,018.00	0.00	0.00	7.00	Verif.Sales
11/12/2023	5,018.00	0.00	801.00	0.00	4,217.00	4,208.00	0.00	-9.00	-2.00	
11/13/2023	4,208.00	0.00	831.00	0.00	3,377.00	3,366.00	0.00	-11.00	-13.00	
11/14/2023	3,366.00	0.00	774.00	0.00	2,592.00	2,574.00	0.00	-18.00	-31.00	
11/15/2023	2,574.00	0.00	925.00	0.00	1,649.00	1,641.00	0.00	-8.00	-39.00	
11/16/2023	1,641.00	0.00	985.00	0.00	656.00	652.00	0.00	-4.00	-43.00	
11/17/2023	652.00	0.00	321.00	0.00	331.00	331.00	0.00	0.00	-43.00	Verif.Sales
11/18/2023	331.00	6,802.00	1,026.00	0.00	6,107.00	6,117.00	0.00	10.00	-33.00	
11/19/2023	6,117.00	0.00	781.00	0.00	5,336.00	5,334.00	0.00	-2.00	-35.00	
11/20/2023	5,334.00	0.00	902.00	0.00	4,432.00	4,428.00	0.00	-4.00	-39.00	
11/21/2023	4,428.00	0.00	1,045.00	0.00	3,383.00	3,371.00	0.00	-12.00	-51.00	
11/22/2023	3,371.00	0.00	919.00	0.00	2,452.00	2,441.00	0.00	-11.00	-62.00	
11/23/2023	2,441.00	0.00	748.00	0.00	1,693.00	1,684.00	0.00	-9.00	-71.00	
11/24/2023	1,684.00	0.00	621.00	0.00	1,063.00	1,057.00	0.00	-6.00	-77.00	
11/25/2023	1,057.00	6,501.00	590.00	0.00	6,968.00	7,007.00	0.00	39.00	-38.00	
11/26/2023	7,007.00	0.00	554.00	0.00	6,453.00	6,443.00	0.00	-10.00	-48.00	
11/27/2023	6,443.00	0.00	868.00	0.00	5,575.00	5,563.00	0.00	-12.00	-60.00	
11/28/2023	5,563.00	0.00	805.00	0.00	4,758.00	4,748.00	0.00	-10.00	-70.00	
11/29/2023	4,748.00	0.00	800.00	0.00	3,948.00	3,939.00	0.00	-9.00	-79.00	
11/30/2023	3,939.00	0.00	973.00	0.00	2,966.00	2,954.00	0.00	-12.00	-91.00	
12/1/2023	2,954.00	0.00	1,194.00	0.00	1,760.00	1,752.00	0.00	-8.00	-99.00	
TOTALS		26,003.00	25,530.00	0.00			0.00	-99.00	-99.00	

Leak Check = ( 25,530.00 \* 0.01 + 130 ) = 385.3 gall

## Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	385.3 gall	0.0 inches	-0.0587 gph	0.0523 gph	PASS	PASS	PASS
Min. Daily Sales :		321.0	Max. Daily Sales :		1194.0	Avg. Daily Sales : 851.0	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.  
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496

# TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd  
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd

Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 02

Product : SUPER

Date generated 12/04/2023

Effective Dates : 11/02/23 to 12/01/23

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
11/2/2023	1,056.00	500.00	148.00	0.00	1,408.00	1,410.00	0.00	2.00	2.00	
11/3/2023	1,410.00	0.00	185.00	0.00	1,225.00	1,225.00	0.00	0.00	2.00	Verif.Sales
11/4/2023	1,225.00	0.00	105.00	0.00	1,120.00	1,119.00	0.00	-1.00	1.00	
11/5/2023	1,119.00	0.00	89.00	0.00	1,030.00	1,030.00	0.00	0.00	1.00	Verif.Sales
11/6/2023	1,030.00	0.00	99.00	0.00	931.00	930.00	0.00	-1.00	0.00	
11/7/2023	930.00	0.00	131.00	0.00	799.00	799.00	0.00	0.00	0.00	Verif.Sales
11/8/2023	799.00	0.00	112.00	0.00	687.00	686.00	0.00	-1.00	-1.00	
11/9/2023	686.00	1,000.00	101.00	0.00	1,585.00	1,588.00	0.00	3.00	2.00	
11/10/2023	1,588.00	0.00	160.00	0.00	1,428.00	1,427.00	0.00	-1.00	1.00	
11/11/2023	1,427.00	0.00	131.00	0.00	1,296.00	1,300.00	0.00	4.00	5.00	
11/12/2023	1,300.00	0.00	165.00	0.00	1,135.00	1,134.00	0.00	-1.00	4.00	
11/13/2023	1,134.00	0.00	120.00	0.00	1,014.00	1,013.00	0.00	-1.00	3.00	
11/14/2023	1,013.00	0.00	132.00	0.00	881.00	881.00	0.00	0.00	3.00	Verif.Sales
11/15/2023	881.00	0.00	132.00	0.00	749.00	747.00	0.00	-2.00	1.00	
11/16/2023	747.00	0.00	92.00	0.00	655.00	654.00	0.00	-1.00	0.00	
11/17/2023	654.00	0.00	21.00	0.00	633.00	633.00	0.00	0.00	0.00	Verif.Sales
11/18/2023	633.00	1,000.00	105.00	0.00	1,528.00	1,535.00	0.00	7.00	7.00	
11/19/2023	1,535.00	0.00	130.00	0.00	1,405.00	1,406.00	0.00	1.00	8.00	
11/20/2023	1,406.00	0.00	94.00	0.00	1,312.00	1,312.00	0.00	0.00	8.00	Verif.Sales
11/21/2023	1,312.00	0.00	126.00	0.00	1,186.00	1,185.00	0.00	-1.00	7.00	
11/22/2023	1,185.00	0.00	50.00	0.00	1,135.00	1,134.00	0.00	-1.00	6.00	
11/23/2023	1,134.00	0.00	93.00	0.00	1,041.00	1,040.00	0.00	-1.00	5.00	
11/24/2023	1,040.00	0.00	140.00	0.00	900.00	899.00	0.00	-1.00	4.00	
11/25/2023	899.00	600.00	45.00	0.00	1,454.00	1,455.00	0.00	1.00	5.00	
11/26/2023	1,455.00	0.00	131.00	0.00	1,324.00	1,325.00	0.00	1.00	6.00	
11/27/2023	1,325.00	0.00	110.00	0.00	1,215.00	1,213.00	0.00	-2.00	4.00	
11/28/2023	1,213.00	0.00	106.00	0.00	1,107.00	1,106.00	0.00	-1.00	3.00	
11/29/2023	1,106.00	0.00	73.00	0.00	1,033.00	1,032.00	0.00	-1.00	2.00	
11/30/2023	1,032.00	0.00	154.00	0.00	878.00	877.00	0.00	-1.00	1.00	
12/1/2023	877.00	0.00	117.00	0.00	760.00	759.00	0.00	-1.00	0.00	
TOTALS		3,100.00	3,397.00	0.00			0.00	0.00	0.00	

Leak Check = ( 3,397.00 \* 0.01 + 130 ) = 164.0 gall

## Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	164.0 gall	0.0 inches	0.0014 gph	0.0090 gph	PASS	PASS	PASS
Min. Daily Sales :		21.0	Max. Daily Sales :		185.0	Avg. Daily Sales : 113.2	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.  
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496