

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd

Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 01

Product : REGULAR

Date generated 02/04/2024

Effective Dates : 01/01/24 to 01/30/24

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
1/1/2024	6,983.00	0.00	609.00	0.00	6,374.00	6,366.00	0.00	-8.00	-8.00	
1/2/2024	6,366.00	0.00	890.00	0.00	5,476.00	5,462.00	0.00	-14.00	-22.00	
1/3/2024	5,462.00	0.00	970.00	0.00	4,492.00	4,482.00	0.00	-10.00	-32.00	
1/4/2024	4,482.00	0.00	882.00	0.00	3,600.00	3,588.00	0.00	-12.00	-44.00	
1/5/2024	3,588.00	0.00	1,001.00	0.00	2,587.00	2,576.00	0.00	-11.00	-55.00	
1/6/2024	2,576.00	0.00	884.00	0.00	1,692.00	1,687.00	0.00	-5.00	-60.00	
1/7/2024	1,687.00	0.00	882.00	0.00	805.00	802.00	0.00	-3.00	-63.00	
1/8/2024	802.00	6,000.00	960.00	0.00	5,842.00	5,856.00	0.00	14.00	-49.00	
1/9/2024	5,856.00	0.00	888.00	0.00	4,968.00	4,963.00	0.00	-5.00	-54.00	
1/10/2024	4,963.00	0.00	881.00	0.00	4,082.00	4,075.00	0.00	-7.00	-61.00	
1/11/2024	4,075.00	0.00	1,063.00	0.00	3,012.00	2,998.00	0.00	-14.00	-75.00	
1/12/2024	2,998.00	0.00	1,092.00	0.00	1,906.00	1,896.00	0.00	-10.00	-85.00	
1/13/2024	1,896.00	0.00	1,048.00	0.00	848.00	845.00	0.00	-3.00	-88.00	
1/14/2024	845.00	6,700.00	598.00	0.00	6,947.00	6,954.00	0.00	7.00	-81.00	
1/15/2024	6,954.00	0.00	449.00	0.00	6,505.00	6,513.00	0.00	8.00	-73.00	
1/16/2024	6,513.00	0.00	703.00	0.00	5,810.00	5,803.00	0.00	-7.00	-80.00	
1/17/2024	5,803.00	0.00	941.00	0.00	4,862.00	4,847.00	0.00	-15.00	-95.00	
1/18/2024	4,847.00	0.00	932.00	0.00	3,915.00	3,904.00	0.00	-11.00	-106.00	
1/19/2024	3,904.00	0.00	1,077.00	0.00	2,827.00	2,819.00	0.00	-8.00	-114.00	
1/20/2024	2,819.00	0.00	878.00	0.00	1,941.00	1,925.00	0.00	-16.00	-130.00	
1/21/2024	1,925.00	0.00	901.00	0.00	1,024.00	1,020.00	0.00	-4.00	-134.00	
1/22/2024	1,020.00	0.00	687.00	0.00	333.00	331.00	0.00	-2.00	-136.00	
1/23/2024	331.00	6,500.00	981.00	0.00	5,850.00	5,836.00	0.00	-14.00	-150.00	
1/24/2024	5,836.00	0.00	848.00	0.00	4,988.00	4,979.00	0.00	-9.00	-159.00	
1/25/2024	4,979.00	0.00	0.00	0.00	4,979.00	4,981.00	0.00	2.00	-157.00	Verif.Stick
1/26/2024	4,981.00	0.00	0.00	0.00	4,981.00	4,982.00	0.00	1.00	-156.00	Verif.Stick
1/27/2024	4,982.00	0.00	0.00	0.00	4,982.00	4,983.00	0.00	1.00	-155.00	Verif.Stick
1/28/2024	4,983.00	0.00	0.00	0.00	4,983.00	4,985.00	0.00	2.00	-153.00	Verif.Stick
1/29/2024	4,985.00	0.00	0.00	0.00	4,985.00	4,985.00	0.00	0.00	-153.00	
1/30/2024	4,985.00	0.00	0.00	0.00	4,985.00	4,999.00	0.00	14.00	-139.00	Verif.Stick
TOTALS		19,200.00	21,045.00	0.00			0.00	-139.00	-139.00	

Leak Check = (21,045.00 * 0.01 + 130) = 340.5 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago	
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result	
0.1000	340.5 gall	0.0 inches	-0.0225 gph	0.0732 gph	PASS	PASS	PASS	
Min. Daily Sales :		0.0	Max. Daily Sales :		1092.0	Avg. Daily Sales :		701.5

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner
6413 Manor Rd
Austin

TX

78723

Owner ID:
Facility ID: 67397
Tank : 02
Product : SUPER

Date generated 02/04/2024

Effective Dates : 01/01/24 to 01/30/24

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
1/1/2024	1,674.00	0.00	160.00	0.00	1,514.00	1,517.00	0.00	3.00	3.00	
1/2/2024	1,517.00	0.00	102.00	0.00	1,415.00	1,415.00	0.00	0.00	3.00	Verif.Sales
1/3/2024	1,415.00	0.00	145.00	0.00	1,270.00	1,269.00	0.00	-1.00	2.00	
1/4/2024	1,269.00	0.00	68.00	0.00	1,201.00	1,199.00	0.00	-2.00	0.00	
1/5/2024	1,199.00	0.00	117.00	0.00	1,082.00	1,082.00	0.00	0.00	0.00	Verif.Sales
1/6/2024	1,082.00	0.00	169.00	0.00	913.00	912.00	0.00	-1.00	-1.00	
1/7/2024	912.00	0.00	175.00	0.00	737.00	735.00	0.00	-2.00	-3.00	
1/8/2024	735.00	1,000.00	92.00	0.00	1,643.00	1,649.00	0.00	6.00	3.00	
1/9/2024	1,649.00	0.00	149.00	0.00	1,500.00	1,502.00	0.00	2.00	5.00	
1/10/2024	1,502.00	0.00	129.00	0.00	1,373.00	1,372.00	0.00	-1.00	4.00	
1/11/2024	1,372.00	0.00	130.00	0.00	1,242.00	1,245.00	0.00	3.00	7.00	
1/12/2024	1,245.00	0.00	77.00	0.00	1,168.00	1,168.00	0.00	0.00	7.00	Verif.Sales
1/13/2024	1,168.00	0.00	297.00	0.00	871.00	869.00	0.00	-2.00	5.00	
1/14/2024	869.00	1,000.00	77.00	0.00	1,792.00	1,798.00	0.00	6.00	11.00	
1/15/2024	1,798.00	0.00	99.00	0.00	1,699.00	1,703.00	0.00	4.00	15.00	
1/16/2024	1,703.00	0.00	128.00	0.00	1,575.00	1,576.00	0.00	1.00	16.00	
1/17/2024	1,576.00	0.00	134.00	0.00	1,442.00	1,440.00	0.00	-2.00	14.00	
1/18/2024	1,440.00	0.00	153.00	0.00	1,287.00	1,287.00	0.00	0.00	14.00	Verif.Sales
1/19/2024	1,287.00	0.00	115.00	0.00	1,172.00	1,170.00	0.00	-2.00	12.00	
1/20/2024	1,170.00	0.00	143.00	0.00	1,027.00	1,026.00	0.00	-1.00	11.00	
1/21/2024	1,026.00	0.00	143.00	0.00	883.00	882.00	0.00	-1.00	10.00	
1/22/2024	882.00	0.00	81.00	0.00	801.00	800.00	0.00	-1.00	9.00	
1/23/2024	800.00	800.00	127.00	0.00	1,473.00	1,473.00	0.00	0.00	9.00	Verif.Sales
1/24/2024	1,473.00	0.00	75.00	0.00	1,398.00	1,398.00	0.00	0.00	9.00	Verif.Sales
1/25/2024	1,398.00	0.00	0.00	0.00	1,398.00	1,398.00	0.00	0.00	9.00	
1/26/2024	1,398.00	0.00	0.00	0.00	1,398.00	1,398.00	0.00	0.00	9.00	
1/27/2024	1,398.00	0.00	0.00	0.00	1,398.00	1,399.00	0.00	1.00	10.00	Verif.Stick
1/28/2024	1,399.00	0.00	0.00	0.00	1,399.00	1,399.00	0.00	0.00	10.00	
1/29/2024	1,399.00	0.00	0.00	0.00	1,399.00	1,399.00	0.00	0.00	10.00	
1/30/2024	1,399.00	0.00	0.00	0.00	1,399.00	1,411.00	0.00	12.00	22.00	Verif.Stick
TOTALS		2,800.00	3,085.00	0.00			0.00	22.00	22.00	

Leak Check = (3,085.00 * 0.01 + 130) = 160.9 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	160.9 gall	0.0 inches	0.0015 gph	0.0161 gph	PASS	PASS	PASS
Min. Daily Sales :		0.0	Max. Daily Sales :		297.0	Avg. Daily Sales : 102.8	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496