

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd
Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 01

Product : REGULAR

Date generated 03/07/2023

Effective Dates : 02/05/23 to 03/06/23

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
2/5/2023	1,687.00	0.00	1,068.00	0.00	619.00	621.00	0.00	2.00	2.00	
2/6/2023	621.00	6,014.00	900.00	0.00	5,735.00	5,742.00	0.00	7.00	9.00	
2/7/2023	5,742.00	0.00	806.00	0.00	4,936.00	4,935.00	0.00	-1.00	8.00	
2/8/2023	4,935.00	0.00	1,036.00	0.00	3,899.00	3,896.00	0.00	-3.00	5.00	
2/9/2023	3,896.00	0.00	1,073.00	0.00	2,823.00	2,817.00	0.00	-6.00	-1.00	
2/10/2023	2,817.00	0.00	1,233.00	0.00	1,584.00	1,585.00	0.00	1.00	0.00	
2/11/2023	1,585.00	6,501.00	904.00	0.00	7,182.00	7,186.00	0.00	4.00	4.00	
2/12/2023	7,186.00	0.00	1,055.00	0.00	6,131.00	6,133.00	0.00	2.00	6.00	
2/13/2023	6,133.00	0.00	1,081.00	0.00	5,052.00	5,049.00	0.00	-3.00	3.00	
2/14/2023	5,049.00	0.00	1,077.00	0.00	3,972.00	3,970.00	0.00	-2.00	1.00	
2/15/2023	3,970.00	0.00	919.00	0.00	3,051.00	3,047.00	0.00	-4.00	-3.00	
2/16/2023	3,047.00	0.00	988.00	0.00	2,059.00	2,058.00	0.00	-1.00	-4.00	
2/17/2023	2,058.00	0.00	923.00	0.00	1,135.00	1,137.00	0.00	2.00	-2.00	
2/18/2023	1,137.00	6,300.00	806.00	0.00	6,631.00	6,645.00	0.00	14.00	12.00	
2/19/2023	6,645.00	0.00	890.00	0.00	5,755.00	5,757.00	0.00	2.00	14.00	
2/20/2023	5,757.00	0.00	854.00	0.00	4,903.00	4,889.00	0.00	-14.00	0.00	
2/21/2023	4,889.00	0.00	887.00	0.00	4,002.00	3,989.00	0.00	-13.00	-13.00	
2/22/2023	3,989.00	0.00	1,051.00	0.00	2,938.00	2,934.00	0.00	-4.00	-17.00	
2/23/2023	2,934.00	0.00	849.00	0.00	2,085.00	2,086.00	0.00	1.00	-16.00	
2/24/2023	2,086.00	0.00	1,076.00	0.00	1,010.00	1,013.00	0.00	3.00	-13.00	
2/25/2023	1,013.00	6,000.00	886.00	0.00	6,127.00	6,142.00	0.00	15.00	2.00	
2/26/2023	6,142.00	0.00	959.00	0.00	5,183.00	5,184.00	0.00	1.00	3.00	
2/27/2023	5,184.00	0.00	846.00	0.00	4,338.00	4,340.00	0.00	2.00	5.00	
2/28/2023	4,340.00	0.00	990.00	0.00	3,350.00	3,348.00	0.00	-2.00	3.00	
3/1/2023	3,348.00	0.00	1,113.00	0.00	2,235.00	2,233.00	0.00	-2.00	1.00	
3/2/2023	2,233.00	0.00	854.00	0.00	1,379.00	1,384.00	0.00	5.00	6.00	
3/3/2023	1,384.00	0.00	1,058.00	0.00	326.00	332.00	0.00	6.00	12.00	
3/4/2023	332.00	6,501.00	1,002.00	0.00	5,831.00	5,840.00	0.00	9.00	21.00	
3/5/2023	5,840.00	0.00	1,063.00	0.00	4,777.00	4,776.00	0.00	-1.00	20.00	
3/6/2023	4,776.00	0.00	835.00	0.00	3,941.00	3,942.00	0.00	1.00	21.00	
TOTALS		31,316.00	29,082.00	0.00			0.00	21.00	21.00	

Leak Check = (29,082.00 * 0.01 + 130) = 420.8 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	420.8 gall	0.0 inches	-0.0091 gph	0.0271 gph	PASS	PASS	PASS
Min. Daily Sales :		806.0	Max. Daily Sales :		1233.0	Avg. Daily Sales : 969.4	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd

Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 02

Product : SUPER

Date generated 03/07/2023

Effective Dates : 02/05/23 to 03/06/23

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
2/5/2023	756.00	0.00	185.00	0.00	571.00	570.00	0.00	-1.00	-1.00	
2/6/2023	570.00	1,004.00	98.00	0.00	1,476.00	1,480.00	0.00	4.00	3.00	
2/7/2023	1,480.00	0.00	148.00	0.00	1,332.00	1,333.00	0.00	1.00	4.00	
2/8/2023	1,333.00	0.00	175.00	0.00	1,158.00	1,158.00	0.00	0.00	4.00	Verif.Sales
2/9/2023	1,158.00	0.00	229.00	0.00	929.00	928.00	0.00	-1.00	3.00	
2/10/2023	928.00	0.00	148.00	0.00	780.00	780.00	0.00	0.00	3.00	Verif.Sales
2/11/2023	780.00	1,000.00	132.00	0.00	1,648.00	1,646.00	0.00	-2.00	1.00	
2/12/2023	1,646.00	0.00	133.00	0.00	1,513.00	1,520.00	0.00	7.00	8.00	
2/13/2023	1,520.00	0.00	163.00	0.00	1,357.00	1,358.00	0.00	1.00	9.00	
2/14/2023	1,358.00	0.00	119.00	0.00	1,239.00	1,239.00	0.00	0.00	9.00	Verif.Sales
2/15/2023	1,239.00	0.00	134.00	0.00	1,105.00	1,104.00	0.00	-1.00	8.00	
2/16/2023	1,104.00	0.00	143.00	0.00	961.00	960.00	0.00	-1.00	7.00	
2/17/2023	960.00	0.00	120.00	0.00	840.00	840.00	0.00	0.00	7.00	Verif.Sales
2/18/2023	840.00	1,000.00	115.00	0.00	1,725.00	1,725.00	0.00	0.00	7.00	Verif.Sales
2/19/2023	1,725.00	0.00	136.00	0.00	1,589.00	1,593.00	0.00	4.00	11.00	
2/20/2023	1,593.00	0.00	124.00	0.00	1,469.00	1,471.00	0.00	2.00	13.00	
2/21/2023	1,471.00	0.00	113.00	0.00	1,358.00	1,358.00	0.00	0.00	13.00	Verif.Sales
2/22/2023	1,358.00	0.00	131.00	0.00	1,227.00	1,228.00	0.00	1.00	14.00	
2/23/2023	1,228.00	0.00	115.00	0.00	1,113.00	1,113.00	0.00	0.00	14.00	Verif.Sales
2/24/2023	1,113.00	0.00	130.00	0.00	983.00	983.00	0.00	0.00	14.00	Verif.Sales
2/25/2023	983.00	500.00	122.00	0.00	1,361.00	1,363.00	0.00	2.00	16.00	
2/26/2023	1,363.00	0.00	152.00	0.00	1,211.00	1,213.00	0.00	2.00	18.00	
2/27/2023	1,213.00	0.00	115.00	0.00	1,098.00	1,098.00	0.00	0.00	18.00	Verif.Sales
2/28/2023	1,098.00	0.00	129.00	0.00	969.00	969.00	0.00	0.00	18.00	Verif.Sales
3/1/2023	969.00	0.00	102.00	0.00	867.00	868.00	0.00	1.00	19.00	
3/2/2023	868.00	0.00	133.00	0.00	735.00	735.00	0.00	0.00	19.00	Verif.Sales
3/3/2023	735.00	0.00	117.00	0.00	618.00	618.00	0.00	0.00	19.00	Verif.Sales
3/4/2023	618.00	1,000.00	148.00	0.00	1,470.00	1,476.00	0.00	6.00	25.00	
3/5/2023	1,476.00	0.00	177.00	0.00	1,299.00	1,301.00	0.00	2.00	27.00	
3/6/2023	1,301.00	0.00	170.00	0.00	1,131.00	1,132.00	0.00	1.00	28.00	
TOTALS		4,504.00	4,156.00	0.00			0.00	28.00	28.00	

Leak Check = (4,156.00 * 0.01 + 130) = 171.6 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	171.6 gall	0.0 inches	0.0208 gph	0.0061 gph	PASS	PASS	PASS
Min. Daily Sales :		98.0	Max. Daily Sales :		229.0	Avg. Daily Sales : 138.5	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496