

## FUEL INVENTORY CONTROL REPORT

FACILITY NAME: Kool CornerMONTH/YEAR: JUNE | 2023FACILITY ID #: 67397TANK SIZE: 8000FUEL TYPE: REGULAR

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
6-May		756	6000	906	5850		5859	9	9
7-May		5859	0	850	5009		5008	-1	8
8-May		5008	0	901	4107		4108	1	9
9-May		4108	0	907	3201		3198	-3	6
10-May		3198	0	1002	2196		2195	-1	5
11-May		2195	0	894	1301		1308	7	12
12-May		1308	6500	1299	6509		6487	-22	-10
13-May		6487	0	884	5603		5595	-8	-18
14-May		5595	0	834	4761		4755	-6	-24
15-May		4755	0	1258	3497		3496	-1	-25
16-May		3496	0	1056	2440		2437	-3	-28
17-May		2437	0	1008	1429		1434	5	-23
18-May		1434	6000	1308	6126		6145	19	-4
19-May		6145	0	1144	5001		4991	-10	-14
20-May		4991	0	853	4138		4140	2	-12
21-May		4140	0	759	3381		3377	-4	-16
22-May		3377	0	931	2446		2444	-2	-18
23-May		2444	0	1058	1386		1392	6	-12
24-May		1392	4996	951	5437		5466	29	17
25-May		5466	0	983	4483		4484	1	18
26-May		4484	0	1018	3466		3465	-1	17
27-May		3465	0	842	2623		2621	-2	15
28-May		2621	0	846	1775		1778	3	18
29-May		1778	0	875	903		910	7	25
30-May		910	6500	890	6520		6541	21	46
31-May		6541	0	979	5562		5555	-7	39
1-Jun		5555	0	836	4719		4716	-3	36
2-Jun		4716	0	960	3756		3755	-1	35
3-Jun		3755	0	1015	2740		2737	-3	32
4-Jun		2737	0	864	1873		1875	2	34

TOTAL SALES: 28911TOTAL OVER/SHORT: 34LEAK TEST: 419.11WATER CHECK (INCHES): 0PASS / FAIL: PASS

**NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.**

## FUEL INVENTORY CONTROL REPORT

FACILITY NAME: Kool Corner MONTH/YEAR: JUNE | 2023

FACILITY ID #: 67397 TANK SIZE: 8000 FUEL TYPE: SUPER

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
6-May		1091	700	123	1668		1668	0	0
7-May		1668	0	120	1548		1550	2	2
8-May		1550	0	150	1400		1401	1	3
9-May		1401	0	109	1292		1292	0	3
10-May		1292	0	104	1188		1188	0	3
11-May		1188	0	86	1102		1103	1	4
12-May		1103	700	129	1674		1719	45	49
13-May		1719	0	88	1631		1633	2	51
14-May		1633	0	118	1515		1516	1	52
15-May		1516	0	76	1440		1441	1	53
16-May		1441	0	129	1312		1313	1	54
17-May		1313	0	100	1213		1214	1	55
18-May		1214	300	104	1410		1409	-1	54
19-May		1409	0	92	1317		1318	1	55
20-May		1318	0	112	1206		1206	0	55
21-May		1206	0	109	1097		1097	0	55
22-May		1097	0	88	1009		1009	0	55
23-May		1009	0	102	907		907	0	55
24-May		907	300	111	1096		1101	5	60
25-May		1101	0	169	932		933	1	61
26-May		933	0	144	789		789	0	61
27-May		789	0	145	644		645	1	62
28-May		645	0	119	526		527	1	63
29-May		527	0	148	379		379	0	63
30-May		379	2000	62	2317		2320	3	66
31-May		2320	0	108	2212		2213	1	67
1-Jun		2213	0	102	2111		2111	0	67
2-Jun		2111	0	167	1944		1946	2	69
3-Jun		1946	0	130	1816		1816	0	69
4-Jun		1816	0	132	1684		1686	2	71

TOTAL SALES: 3476

TOTAL OVER/SHORT: 71

LEAK TEST: 164.76

WATER CHECK (INCHES): 0

PASS / FAIL: PASS

**NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.**