

**FUEL INVENTORY CONTROL REPORT**

FACILITY NAME: Kool Corner MONTH/YEAR: MAY 2024

FACILITY ID #: 67397 TANK SIZE: 8000 FUEL TYPE: REGULAR

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
30-Apr		6562	0	1090	5472		5463	-9	-9
1-May		5463	0	997	4466		4463	-3	-12
2-May		4463	0	924	3539		3535	-4	-16
3-May		3535	0	1147	2388		2383	-5	-21
4-May		2383	0	1106	1277		1291	14	-7
5-May		1291	0	954	337		332	-5	-12
6-May		332	6503	918	5917		5922	5	-7
7-May		5922	0	937	4985		4981	-4	-11
8-May		4981	0	1176	3805		3802	-3	-14
9-May		3802	0	1134	2668		2663	-5	-19
10-May		2663	0	1117	1546		1537	-9	-28
11-May		1537	0	924	613		631	18	-10
12-May		631	6202	315	6518		6530	12	2
13-May		6530	0	908	5622		5620	-2	0
14-May		5620	0	908	4712		4711	-1	-1
15-May		4711	0	968	3743		3741	-2	-3
16-May		3741	0	995	2746		2742	-4	-7
17-May		2742	0	1285	1457		1462	5	-2
18-May		1462	0	1012	450		454	4	2
19-May		454	6300	1060	5694		5699	5	7
20-May		5699	0	968	4731		4734	3	10
21-May		4734	0	886	3848		3841	-7	3
22-May		3841	0	1015	2826		2822	-4	-1
23-May		2822	0	933	1889		1891	2	1
24-May		1891	0	1095	796		805	9	10
25-May		805	6504	845	6464		6477	13	23
26-May		6477	0	827	5650		5645	-5	18
27-May		5645	0	820	4825		4820	-5	13
28-May		4820	0	762	4058		4045	-13	0
29-May		4045	0	885	3160		3154	-6	-6

TOTAL SALES: 28911 TOTAL OVER/SHORT: -6

LEAK TEST: 419.11 WATER CHECK (INCHES): 0 PASS / FAIL: PASS

NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.

## FUEL INVENTORY CONTROL REPORT

FACILITY NAME: Kool Corner MONTH/YEAR: MAY | 2024

FACILITY ID #: 67397 TANK SIZE: 8000 FUEL TYPE: SUPER

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
30-Apr		2041	0	114	1927		1928	1	1
1-May		1928	0	125	1803		1803	0	1
2-May		1803	0	149	1654		1655	1	2
3-May		1655	0	150	1505		1506	1	3
4-May		1506	0	126	1380		1380	0	3
5-May		1380	0	100	1280		1281	1	4
6-May		1281	500	135	1646		1645	-1	3
7-May		1645	0	102	1543		1545	2	5
8-May		1545	0	150	1395		1395	0	5
9-May		1395	0	79	1316		1318	2	7
10-May		1318	0	157	1161		1161	0	7
11-May		1161	0	192	969		969	0	7
12-May		969	500	41	1428		1426	-2	5
13-May		1426	0	152	1274		1276	2	7
14-May		1276	0	151	1125		1126	1	8
15-May		1126	0	113	1013		1014	1	9
16-May		1014	0	168	846		853	7	16
17-May		853	0	130	723		716	-7	9
18-May		716	0	146	570		571	1	10
19-May		571	1000	130	1441		1443	2	12
20-May		1443	0	111	1332		1333	1	13
21-May		1333	0	137	1196		1198	2	15
22-May		1198	0	109	1089		1090	1	16
23-May		1090	0	131	959		959	0	16
24-May		959	0	136	823		828	5	21
25-May		828	1006	83	1751		1745	-6	15
26-May		1745	0	184	1561		1562	1	16
27-May		1562	0	68	1494		1494	0	16
28-May		1494	0	114	1380		1381	1	17
29-May		1381	0	85	1296		1305	9	26

TOTAL SALES: 3768

TOTAL OVER/SHORT: 26

LEAK TEST: 167.68

WATER CHECK (INCHES): 0

PASS / FAIL: PASS

**NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.**