

**FUEL INVENTORY CONTROL REPORT**

FACILITY NAME: Kool Corner MONTH/YEAR: DECEMBER 2024

FACILITY ID #: 67397 TANK SIZE: 8000 FUEL TYPE: REGULAR

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
26-Nov		3962	0	878	3084		3074	-10	-10
27-Nov		3074	0	865	2209		2205	-4	-14
28-Nov		2205	0	580	1625		1624	-1	-15
29-Nov		1624	0	659	965		964	-1	-16
30-Nov		964	6500	722	6742		6771	29	13
1-Dec		6771	0	618	6153		6159	6	19
2-Dec		6159	0	855	5304		5300	-4	15
3-Dec		5300	0	790	4510		4505	-5	10
4-Dec		4505	0	965	3540		3531	-9	1
5-Dec		3531	0	853	2678		2670	-8	-7
6-Dec		2670	0	1088	1582		1581	-1	-8
7-Dec		1581	0	757	824		822	-2	-10
8-Dec		822	6501	828	6495		6521	26	16
9-Dec		6521	0	1030	5491		5492	1	17
10-Dec		5492	0	800	4692		4690	-2	15
11-Dec		4690	0	1043	3647		3640	-7	8
12-Dec		3640	0	941	2699		2691	-8	0
13-Dec		2691	0	864	1827		1824	-3	-3
14-Dec		1824	0	844	980		997	17	14
15-Dec		997	6500	678	6819		6813	-6	8
16-Dec		6813	0	785	6028		6024	-4	4
17-Dec		6024	0	840	5184		5178	-6	-2
18-Dec		5178	0	915	4263		4258	-5	-7
19-Dec		4258	0	805	3453		3445	-8	-15
20-Dec		3445	0	778	2667		2660	-7	-22
21-Dec		2660	0	823	1837		1833	-4	-26
22-Dec		1833	0	944	889		894	5	-21
23-Dec		894	6601	603	6892		6921	29	8
24-Dec		6921	0	768	6153		6144	-9	-1
25-Dec		6144	0	419	5725		5720	-5	-6

TOTAL SALES: 24338 TOTAL OVER/SHORT: -6

LEAK TEST: 373.38 WATER CHECK (INCHES): 0 PASS / FAIL: PASS

NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.

## FUEL INVENTORY CONTROL REPORT

FACILITY NAME: Kool CornerMONTH/YEAR: DECEMBER | 2024FACILITY ID #: 67397TANK SIZE: 8000FUEL TYPE: SUPER

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
26-Nov		1142	0	106	1036		1035	-1	-1
27-Nov		1035	0	94	941		940	-1	-2
28-Nov		940	0	168	772		770	-2	-4
29-Nov		770	0	142	628		627	-1	-5
30-Nov		627	1000	55	1572		1580	8	3
1-Dec		1580	0	94	1486		1487	1	4
2-Dec		1487	0	126	1361		1360	-1	3
3-Dec		1360	0	177	1183		1182	-1	2
4-Dec		1182	0	141	1041		1039	-2	0
5-Dec		1039	0	176	863		864	1	1
6-Dec		864	0	145	719		718	-1	0
7-Dec		718	0	134	584		590	6	6
8-Dec		590	1502	114	1978		1986	8	14
9-Dec		1986	0	116	1870		1872	2	16
10-Dec		1872	0	146	1726		1726	0	16
11-Dec		1726	0	158	1568		1568	0	16
12-Dec		1568	0	162	1406		1405	-1	15
13-Dec		1405	0	139	1266		1266	0	15
14-Dec		1266	0	110	1156		1160	4	19
15-Dec		1160	800	64	1896		1897	1	20
16-Dec		1897	0	120	1777		1779	2	22
17-Dec		1779	0	106	1673		1673	0	22
18-Dec		1673	0	76	1597		1598	1	23
19-Dec		1598	0	145	1453		1453	0	23
20-Dec		1453	0	106	1347		1350	3	26
21-Dec		1350	0	143	1207		1203	-4	22
22-Dec		1203	0	186	1017		1016	-1	21
23-Dec		1016	1200	112	2104		2100	-4	17
24-Dec		2100	0	155	1945		1946	1	18
25-Dec		1946	0	30	1916		1915	-1	17

TOTAL SALES: 3746TOTAL OVER/SHORT: 17LEAK TEST: 167.46WATER CHECK (INCHES): 0PASS / FAIL: PASS

**NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.**