

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd

Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 01

Product : REGULAR

Date generated 07/05/2023

Effective Dates : 06/05/23 to 07/04/23

Date	Beq.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
6/5/2023	1,875.00	0.00	909.00	0.00	966.00	972.00	0.00	6.00	6.00	
6/6/2023	972.00	4,000.00	803.00	0.00	4,169.00	4,180.00	0.00	11.00	17.00	
6/7/2023	4,180.00	0.00	849.00	0.00	3,331.00	3,331.00	0.00	0.00	17.00	Verif.Sales
6/8/2023	3,331.00	0.00	836.00	0.00	2,495.00	2,495.00	0.00	0.00	17.00	Verif.Sales
6/9/2023	2,495.00	0.00	826.00	0.00	1,669.00	1,672.00	0.00	3.00	20.00	
6/10/2023	1,672.00	5,600.00	784.00	0.00	6,488.00	6,505.00	0.00	17.00	37.00	
6/11/2023	6,505.00	0.00	886.00	0.00	5,619.00	5,608.00	0.00	-11.00	26.00	
6/12/2023	5,608.00	0.00	669.00	0.00	4,939.00	4,935.00	0.00	-4.00	22.00	
6/13/2023	4,935.00	0.00	811.00	0.00	4,124.00	4,123.00	0.00	-1.00	21.00	
6/14/2023	4,123.00	0.00	802.00	0.00	3,321.00	3,316.00	0.00	-5.00	16.00	
6/15/2023	3,316.00	0.00	938.00	0.00	2,378.00	2,377.00	0.00	-1.00	15.00	
6/16/2023	2,377.00	0.00	883.00	0.00	1,494.00	1,500.00	0.00	6.00	21.00	
6/17/2023	1,500.00	6,201.00	967.00	0.00	6,734.00	6,751.00	0.00	17.00	38.00	
6/18/2023	6,751.00	0.00	838.00	0.00	5,913.00	5,905.00	0.00	-8.00	30.00	
6/19/2023	5,905.00	0.00	720.00	0.00	5,185.00	5,183.00	0.00	-2.00	28.00	
6/20/2023	5,183.00	0.00	799.00	0.00	4,384.00	4,381.00	0.00	-3.00	25.00	
6/21/2023	4,381.00	0.00	863.00	0.00	3,518.00	3,508.00	0.00	-10.00	15.00	
6/22/2023	3,508.00	0.00	890.00	0.00	2,618.00	2,622.00	0.00	4.00	19.00	
6/23/2023	2,622.00	0.00	1,194.00	0.00	1,428.00	1,436.00	0.00	8.00	27.00	
6/24/2023	1,436.00	4,501.00	1,085.00	0.00	4,852.00	4,868.00	0.00	16.00	43.00	
6/25/2023	4,868.00	2,000.00	994.00	0.00	5,874.00	5,886.00	0.00	12.00	55.00	
6/26/2023	5,886.00	0.00	893.00	0.00	4,993.00	4,989.00	0.00	-4.00	51.00	
6/27/2023	4,989.00	0.00	833.00	0.00	4,156.00	4,157.00	0.00	1.00	52.00	
6/28/2023	4,157.00	0.00	1,064.00	0.00	3,093.00	3,087.00	0.00	-6.00	46.00	
6/29/2023	3,087.00	0.00	1,257.00	0.00	1,830.00	1,833.00	0.00	3.00	49.00	
6/30/2023	1,833.00	0.00	1,293.00	0.00	540.00	550.00	0.00	10.00	59.00	
7/1/2023	550.00	6,002.00	1,022.00	0.00	5,530.00	5,542.00	0.00	12.00	71.00	
7/2/2023	5,542.00	0.00	935.00	0.00	4,607.00	4,605.00	0.00	-2.00	69.00	
7/3/2023	4,605.00	0.00	1,144.00	0.00	3,461.00	3,457.00	0.00	-4.00	65.00	
7/4/2023	3,457.00	0.00	964.00	0.00	2,493.00	2,491.00	0.00	-2.00	63.00	
TOTALS		28,304.00	27,751.00	0.00			0.00	63.00	63.00	

Leak Check = (27,751.00 * 0.01 + 130) = 407.5 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	407.5 gall	0.0 inches	-0.0246 gph	0.0325 gph	PASS	PASS	PASS
Min. Daily Sales :		669.0	Max. Daily Sales :		1293.0	Avg. Daily Sales : 925.0	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner
6413 Manor Rd
Austin

TX

78723

Owner ID:
Facility ID: 67397
Tank : 02
Product : SUPER

Date generated 07/05/2023

Effective Dates : 06/05/23 to 07/04/23

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
6/5/2023	1,686.00	0.00	101.00	0.00	1,585.00	1,586.00	0.00	1.00	1.00	
6/6/2023	1,586.00	0.00	144.00	0.00	1,442.00	1,443.00	0.00	1.00	2.00	
6/7/2023	1,443.00	0.00	106.00	0.00	1,337.00	1,342.00	0.00	5.00	7.00	
6/8/2023	1,342.00	0.00	130.00	0.00	1,212.00	1,213.00	0.00	1.00	8.00	
6/9/2023	1,213.00	0.00	118.00	0.00	1,095.00	1,098.00	0.00	3.00	11.00	
6/10/2023	1,098.00	500.00	180.00	0.00	1,418.00	1,418.00	0.00	0.00	11.00	Verif.Sales
6/11/2023	1,418.00	0.00	130.00	0.00	1,288.00	1,288.00	0.00	0.00	11.00	Verif.Sales
6/12/2023	1,288.00	0.00	78.00	0.00	1,210.00	1,211.00	0.00	1.00	12.00	
6/13/2023	1,211.00	0.00	75.00	0.00	1,136.00	1,136.00	0.00	0.00	12.00	Verif.Sales
6/14/2023	1,136.00	0.00	105.00	0.00	1,031.00	1,032.00	0.00	1.00	13.00	
6/15/2023	1,032.00	0.00	95.00	0.00	937.00	937.00	0.00	0.00	13.00	Verif.Sales
6/16/2023	937.00	0.00	152.00	0.00	785.00	786.00	0.00	1.00	14.00	
6/17/2023	786.00	1,500.00	95.00	0.00	2,191.00	2,207.00	0.00	16.00	30.00	
6/18/2023	2,207.00	0.00	86.00	0.00	2,121.00	2,120.00	0.00	-1.00	29.00	
6/19/2023	2,120.00	0.00	107.00	0.00	2,013.00	2,014.00	0.00	1.00	30.00	
6/20/2023	2,014.00	0.00	59.00	0.00	1,955.00	1,955.00	0.00	0.00	30.00	Verif.Sales
6/21/2023	1,955.00	0.00	114.00	0.00	1,841.00	1,842.00	0.00	1.00	31.00	
6/22/2023	1,842.00	0.00	51.00	0.00	1,791.00	1,792.00	0.00	1.00	32.00	
6/23/2023	1,792.00	0.00	88.00	0.00	1,704.00	1,705.00	0.00	1.00	33.00	
6/24/2023	1,705.00	0.00	205.00	0.00	1,500.00	1,503.00	0.00	3.00	36.00	
6/25/2023	1,503.00	0.00	139.00	0.00	1,364.00	1,365.00	0.00	1.00	37.00	
6/26/2023	1,365.00	0.00	127.00	0.00	1,238.00	1,239.00	0.00	1.00	38.00	
6/27/2023	1,239.00	0.00	95.00	0.00	1,144.00	1,145.00	0.00	1.00	39.00	
6/28/2023	1,145.00	0.00	93.00	0.00	1,052.00	1,053.00	0.00	1.00	40.00	
6/29/2023	1,053.00	0.00	150.00	0.00	903.00	905.00	0.00	2.00	42.00	
6/30/2023	905.00	0.00	185.00	0.00	720.00	721.00	0.00	1.00	43.00	
7/1/2023	721.00	500.00	102.00	0.00	1,119.00	1,119.00	0.00	0.00	43.00	Verif.Sales
7/2/2023	1,119.00	0.00	135.00	0.00	984.00	984.00	0.00	0.00	43.00	Verif.Sales
7/3/2023	984.00	0.00	101.00	0.00	883.00	884.00	0.00	1.00	44.00	
7/4/2023	884.00	0.00	120.00	0.00	764.00	765.00	0.00	1.00	45.00	
TOTALS		2,500.00	3,466.00	0.00			0.00	45.00	45.00	

Leak Check = (3,466.00 * 0.01 + 130) = 164.7 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	164.7 gall	0.0 inches	0.0445 gph	0.0060 gph	PASS	PASS	PASS
Min. Daily Sales :		51.0	Max. Daily Sales :		205.0	Avg. Daily Sales : 115.5	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496