

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner
6413 Manor Rd
Austin

TX 78723

Owner ID:
Facility ID: 67397
Tank : 01
Product : REGULAR

Effective Dates : 11/26/24 to 12/25/24

Date generated 12/31/2024

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
11/26/2024	3,962.00	0.00	878.00	0.00	3,084.00	3,074.00	0.00	-10.00	-10.00	
11/27/2024	3,074.00	0.00	865.00	0.00	2,209.00	2,205.00	0.00	-4.00	-14.00	
11/28/2024	2,205.00	0.00	580.00	0.00	1,625.00	1,624.00	0.00	-1.00	-15.00	
11/29/2024	1,624.00	0.00	659.00	0.00	965.00	964.00	0.00	-1.00	-16.00	
11/30/2024	964.00	6,500.00	722.00	0.00	6,742.00	6,771.00	0.00	29.00	13.00	
12/1/2024	6,771.00	0.00	618.00	0.00	6,153.00	6,159.00	0.00	6.00	19.00	
12/2/2024	6,159.00	0.00	855.00	0.00	5,304.00	5,300.00	0.00	-4.00	15.00	
12/3/2024	5,300.00	0.00	790.00	0.00	4,510.00	4,505.00	0.00	-5.00	10.00	
12/4/2024	4,505.00	0.00	965.00	0.00	3,540.00	3,531.00	0.00	-9.00	1.00	
12/5/2024	3,531.00	0.00	853.00	0.00	2,678.00	2,670.00	0.00	-8.00	-7.00	
12/6/2024	2,670.00	0.00	1,088.00	0.00	1,582.00	1,581.00	0.00	-1.00	-8.00	
12/7/2024	1,581.00	0.00	757.00	0.00	824.00	822.00	0.00	-2.00	-10.00	
12/8/2024	822.00	6,501.00	828.00	0.00	6,495.00	6,521.00	0.00	26.00	16.00	
12/9/2024	6,521.00	0.00	1,030.00	0.00	5,491.00	5,492.00	0.00	1.00	17.00	
12/10/2024	5,492.00	0.00	800.00	0.00	4,692.00	4,690.00	0.00	-2.00	15.00	
12/11/2024	4,690.00	0.00	1,043.00	0.00	3,647.00	3,640.00	0.00	-7.00	8.00	
12/12/2024	3,640.00	0.00	941.00	0.00	2,699.00	2,691.00	0.00	-8.00	0.00	
12/13/2024	2,691.00	0.00	864.00	0.00	1,827.00	1,824.00	0.00	-3.00	-3.00	
12/14/2024	1,824.00	0.00	844.00	0.00	980.00	997.00	0.00	17.00	14.00	
12/15/2024	997.00	6,500.00	678.00	0.00	6,819.00	6,813.00	0.00	-6.00	8.00	
12/16/2024	6,813.00	0.00	785.00	0.00	6,028.00	6,024.00	0.00	-4.00	4.00	
12/17/2024	6,024.00	0.00	840.00	0.00	5,184.00	5,178.00	0.00	-6.00	-2.00	
12/18/2024	5,178.00	0.00	915.00	0.00	4,263.00	4,258.00	0.00	-5.00	-7.00	
12/19/2024	4,258.00	0.00	805.00	0.00	3,453.00	3,445.00	0.00	-8.00	-15.00	
12/20/2024	3,445.00	0.00	778.00	0.00	2,667.00	2,660.00	0.00	-7.00	-22.00	
12/21/2024	2,660.00	0.00	823.00	0.00	1,837.00	1,833.00	0.00	-4.00	-26.00	
12/22/2024	1,833.00	0.00	944.00	0.00	889.00	894.00	0.00	5.00	-21.00	
12/23/2024	894.00	6,601.00	603.00	0.00	6,892.00	6,921.00	0.00	29.00	8.00	
12/24/2024	6,921.00	0.00	768.00	0.00	6,153.00	6,144.00	0.00	-9.00	-1.00	
12/25/2024	6,144.00	0.00	419.00	0.00	5,725.00	5,720.00	0.00	-5.00	-6.00	
TOTALS		26,102.00	24,338.00	0.00			0.00	-6.00	-6.00	

Leak Check = (24,338.00 * 0.01 + 130) = 373.4 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	373.4 gall	0.0 inches	-0.0014 gph	0.0573 gph	PASS	PASS	PASS
Min. Daily Sales :		419.0	Max. Daily Sales :	1088.0	Avg. Daily Sales :	811.3	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd
Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 02

Product : SUPER

Date generated 12/31/2024

Effective Dates : 11/26/24 to 12/25/24

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
11/26/2024	1,142.00	0.00	106.00	0.00	1,036.00	1,035.00	0.00	-1.00	-1.00	
11/27/2024	1,035.00	0.00	94.00	0.00	941.00	940.00	0.00	-1.00	-2.00	
11/28/2024	940.00	0.00	168.00	0.00	772.00	770.00	0.00	-2.00	-4.00	
11/29/2024	770.00	0.00	142.00	0.00	628.00	627.00	0.00	-1.00	-5.00	
11/30/2024	627.00	1,000.00	55.00	0.00	1,572.00	1,580.00	0.00	8.00	3.00	
12/1/2024	1,580.00	0.00	94.00	0.00	1,486.00	1,487.00	0.00	1.00	4.00	
12/2/2024	1,487.00	0.00	126.00	0.00	1,361.00	1,360.00	0.00	-1.00	3.00	
12/3/2024	1,360.00	0.00	177.00	0.00	1,183.00	1,182.00	0.00	-1.00	2.00	
12/4/2024	1,182.00	0.00	141.00	0.00	1,041.00	1,039.00	0.00	-2.00	0.00	
12/5/2024	1,039.00	0.00	176.00	0.00	863.00	864.00	0.00	1.00	1.00	
12/6/2024	864.00	0.00	145.00	0.00	719.00	718.00	0.00	-1.00	0.00	
12/7/2024	718.00	0.00	134.00	0.00	584.00	590.00	0.00	6.00	6.00	
12/8/2024	590.00	1,502.00	114.00	0.00	1,978.00	1,986.00	0.00	8.00	14.00	
12/9/2024	1,986.00	0.00	116.00	0.00	1,870.00	1,872.00	0.00	2.00	16.00	
12/10/2024	1,872.00	0.00	146.00	0.00	1,726.00	1,726.00	0.00	0.00	16.00	Verif.Sales
12/11/2024	1,726.00	0.00	158.00	0.00	1,568.00	1,568.00	0.00	0.00	16.00	Verif.Sales
12/12/2024	1,568.00	0.00	162.00	0.00	1,406.00	1,405.00	0.00	-1.00	15.00	
12/13/2024	1,405.00	0.00	139.00	0.00	1,266.00	1,266.00	0.00	0.00	15.00	Verif.Sales
12/14/2024	1,266.00	0.00	110.00	0.00	1,156.00	1,160.00	0.00	4.00	19.00	
12/15/2024	1,160.00	800.00	64.00	0.00	1,896.00	1,897.00	0.00	1.00	20.00	
12/16/2024	1,897.00	0.00	120.00	0.00	1,777.00	1,779.00	0.00	2.00	22.00	
12/17/2024	1,779.00	0.00	106.00	0.00	1,673.00	1,673.00	0.00	0.00	22.00	Verif.Sales
12/18/2024	1,673.00	0.00	76.00	0.00	1,597.00	1,598.00	0.00	1.00	23.00	
12/19/2024	1,598.00	0.00	145.00	0.00	1,453.00	1,453.00	0.00	0.00	23.00	Verif.Sales
12/20/2024	1,453.00	0.00	106.00	0.00	1,347.00	1,350.00	0.00	3.00	26.00	
12/21/2024	1,350.00	0.00	143.00	0.00	1,207.00	1,203.00	0.00	-4.00	22.00	
12/22/2024	1,203.00	0.00	186.00	0.00	1,017.00	1,016.00	0.00	-1.00	21.00	
12/23/2024	1,016.00	1,200.00	112.00	0.00	2,104.00	2,100.00	0.00	-4.00	17.00	
12/24/2024	2,100.00	0.00	155.00	0.00	1,945.00	1,946.00	0.00	1.00	18.00	
12/25/2024	1,946.00	0.00	30.00	0.00	1,916.00	1,915.00	0.00	-1.00	17.00	
TOTALS		4,502.00	3,746.00	0.00			0.00	17.00	17.00	

Leak Check = (3,746.00 * 0.01 + 130) = 167.5 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	167.5 gall	0.0 inches	-0.0037 gph	0.0143 gph	PASS	PASS	PASS
Min. Daily Sales :		30.0	Max. Daily Sales :		186.0	Avg. Daily Sales : 124.9	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496