



LINE AND LEAK DETECTOR TEST DATA FORM

Facility Name: Shell Food Mart

Date: 10/5/2024

Facility Address: 3502 Culebra Rd
San Antonio, TX 78228

Facility Phone: _____

Test Contractor: PETRO-TANK SOLUTIONS, LLC
Address: 803 Summer Park Dr Ste#150
Stafford, TX 77477

Tester: Anil Momin

Contractor Phone: (281) 242-2687

License # 4865.LTN

Product	REGULAR	SUPER		
Pump Manufacturer	Red Jacket	Red Jacket		
Isolation Mechanism	Isolation Plug	Isolation Plug		
Test Pressure (1 1/2 times working pressure)	50 PSI	50 PSI		
Initial Cylinder Level (ICL)	0.040	0.040		
Final Cylinder Level (FCL)	0.040	0.040		
Leak Volume = ICL - FCL	0.000	0.000		
Time Started	10:30	11:15		
Time Completed	11:00	11:45		
Total Test Time (30 min. minimum)	30 MINS	30 MINS		
Conclusion (Pass or Fail)	Pass	Pass		
Leak Detector Manufacturer	Red Jacket	Red Jacket		
Line PSI	28 PSI	27 PSI		
Leak Detector Result (Pass or Fail)	Pass	Pass		

Comments: _____

