



## LINE AND LEAK DETECTOR TEST DATA FORM

Facility Name: Foodies Corner 5 Date: 7/13/2024

Facility Address: 1405 W Whitestone Blvd  
Cedar Park, TX 78613

Facility Phone: \_\_\_\_\_

Test Contractor: PETRO-TANK SOLUTIONS, LLC  
Address: 803 Summer Park Dr, Ste #150

STAFFORD, TX 77477

Contractor Phone: (281) 242-2687

Tester: Anil Momin

Method: Hasstech ACURITE Pipeline Tester

License # 4865.LTN

Product	REGULAR	SUPER	DIESEL	
Pump Manufacturer	Red Jacket	Red Jacket	Red Jacket	
Isolation Mechanism	Ball Valve	Ball Valve	Ball Valve	
Test Pressure (1 1/2 times working pressure)	50 PSI	50 PSI	50 PSI	
Initial Cylinder Level (ICL)	0.040	0.040	0.085	
Final Cylinder Level (FCL)	0.040	0.040	0.085	
Leak Volume = ICL - FCL	0.000	0.000	0.000	
Time Started	3:00	3:00	3:45	
Time Completed	3:30	3:30	4:15	
Total Test Time (30 min. minimum)	30 MIN	30 MIN	30 MIN	
Conclusion (Pass or Fail)	Pass	Pass	Pass	
Leak Detector Manufacturer	Red Jacket	Red Jacket	Red Jacket	
Line PSI	30 PSI	29 PSI	27 PSI	
Leak Detector Result (Pass or Fail)	Pass	Pass	Pass	

Comments: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_