

# MONTHLY INSPECTION REPORT

## PETRO-TANK SOLUTIONS

803 SUMMER PARK DR, STE #150

STAFFORD, TX 77477

O: 281-242-2687

E: OFFICE.PETROTANKSOLUTIONS@GMAIL.COM



Facility Name: Hills Country Food Mart

Facility Address: 302 N Water St, Burnet, TX 78611

TCEQ Facility ID: 10966

Technician: fieldtech1

Weather: Clear

Time: 08:44 PM

Date Inspected: 09/19/2024

[10 day hour by hour Colombo weather](#)


NOT APPLICABLE

REQUIRES IMMEDIATE ATTENTION

CHECKED AND OKAY

COMMENTS

1 Hanging hardware leaking?



☐

☒

☐

see attached.

2 Hanging hardware free of cracks and holes?

☐

☐

☒

3 Octane stickers on?

☐

☐

☒

4 Ethanol sticker on?

☐

☐

☒

5 No Smoking/Stop Engine stickers on?

☐

☐

☒

6 TDLR Weights & Measurements stickers on?

☐

☐

☒

7 Any sign of leaks under the dispensers?

☐

☒

☐

8 Any liquid or debris under dispenser sumps?

☐

☒

☐

9 Are Spill buckets free of liquid or debris?

☐

☐

☒

10 Spill buckets interior & exterior damaged or cracked?

☐

☒

☐

11 Grey Fill Cap in working condition?

☐

☐

☒

12 Fill Adapter threaded tight and not loose?

☐

☐

☒

13 Orange Vapor cap in working condition?

☐

☐

☒

14 Vapor adapter in working condition?

☐

☐

☒

15 STP Sumps free of liquid and debris?

☐

☒

☐

16 STP Sumps free of holes and cracks?

☐

☒

☐

17 Are all the lids properly painted?

☐

☒

☐

18 Are the vent caps in good condition?

☐

☒

☐

GENERAL COMMENTS:

---