

# TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd  
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd  
Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 01

Product : REGULAR

Effective Dates : 10/03/23 to 11/01/23

Date generated 11/07/2023

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
10/3/2023	2,639.00	0.00	865.00	0.00	1,774.00	1,774.00	0.00	0.00	0.00	Verif.Sales
10/4/2023	1,774.00	0.00	986.00	0.00	788.00	793.00	0.00	5.00	5.00	
10/5/2023	793.00	6,801.00	1,125.00	0.00	6,469.00	6,496.00	0.00	27.00	32.00	
10/6/2023	6,496.00	0.00	824.00	0.00	5,672.00	5,673.00	0.00	1.00	33.00	
10/7/2023	5,673.00	0.00	906.00	0.00	4,767.00	4,766.00	0.00	-1.00	32.00	
10/8/2023	4,766.00	0.00	804.00	0.00	3,962.00	3,962.00	0.00	0.00	32.00	Verif.Sales
10/9/2023	3,962.00	0.00	755.00	0.00	3,207.00	3,200.00	0.00	-7.00	25.00	
10/10/2023	3,200.00	0.00	684.00	0.00	2,516.00	2,510.00	0.00	-6.00	19.00	
10/11/2023	2,510.00	0.00	970.00	0.00	1,540.00	1,541.00	0.00	1.00	20.00	
10/12/2023	1,541.00	0.00	922.00	0.00	619.00	619.00	0.00	0.00	20.00	Verif.Sales
10/13/2023	619.00	6,700.00	860.00	0.00	6,459.00	6,483.00	0.00	24.00	44.00	
10/14/2023	6,483.00	0.00	909.00	0.00	5,574.00	5,572.00	0.00	-2.00	42.00	
10/15/2023	5,572.00	0.00	908.00	0.00	4,664.00	4,633.00	0.00	-31.00	11.00	
10/16/2023	4,633.00	0.00	1,068.00	0.00	3,565.00	3,583.00	0.00	18.00	29.00	
10/17/2023	3,583.00	0.00	1,038.00	0.00	2,545.00	2,535.00	0.00	-10.00	19.00	
10/18/2023	2,535.00	0.00	838.00	0.00	1,697.00	1,690.00	0.00	-7.00	12.00	
10/19/2023	1,690.00	0.00	798.00	0.00	892.00	900.00	0.00	8.00	20.00	
10/20/2023	900.00	0.00	571.00	0.00	329.00	331.00	0.00	2.00	22.00	
10/21/2023	331.00	6,700.00	1,096.00	0.00	5,935.00	5,952.00	0.00	17.00	39.00	
10/22/2023	5,952.00	0.00	1,013.00	0.00	4,939.00	4,940.00	0.00	1.00	40.00	
10/23/2023	4,940.00	0.00	987.00	0.00	3,953.00	3,950.00	0.00	-3.00	37.00	
10/24/2023	3,950.00	0.00	903.00	0.00	3,047.00	3,040.00	0.00	-7.00	30.00	
10/25/2023	3,040.00	0.00	1,037.00	0.00	2,003.00	2,000.00	0.00	-3.00	27.00	
10/26/2023	2,000.00	0.00	732.00	0.00	1,268.00	1,269.00	0.00	1.00	28.00	
10/27/2023	1,269.00	6,503.00	1,199.00	0.00	6,573.00	6,508.00	0.00	-65.00	-37.00	
10/28/2023	6,508.00	0.00	938.00	0.00	5,570.00	5,567.00	0.00	-3.00	-40.00	
10/29/2023	5,567.00	0.00	971.00	0.00	4,596.00	4,590.00	0.00	-6.00	-46.00	
10/30/2023	4,590.00	0.00	1,257.00	0.00	3,333.00	3,321.00	0.00	-12.00	-58.00	
10/31/2023	3,321.00	0.00	941.00	0.00	2,380.00	2,369.00	0.00	-11.00	-69.00	
11/1/2023	2,369.00	0.00	985.00	0.00	1,384.00	1,378.00	0.00	-6.00	-75.00	
TOTALS		26,704.00	27,890.00	0.00			0.00	-75.00	-75.00	

Leak Check = ( 27,890.00 \* 0.01 + 130 ) = 408.9 gall

## Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	408.9 gall	0.0 inches	0.0495 gph	0.0789 gph	PASS	PASS	PASS
Min. Daily Sales :		571.0	Max. Daily Sales :		1257.0	Avg. Daily Sales : 929.7	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.  
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496

# TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd  
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd

Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 02

Product : SUPER

Date generated 11/07/2023

Effective Dates : 10/03/23 to 11/01/23

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
10/3/2023	1,316.00	0.00	90.00	0.00	1,226.00	1,225.00	0.00	-1.00	-1.00	
10/4/2023	1,225.00	0.00	137.00	0.00	1,088.00	1,089.00	0.00	1.00	0.00	
10/5/2023	1,089.00	520.00	122.00	0.00	1,487.00	1,487.00	0.00	0.00	0.00	Verif.Sales
10/6/2023	1,487.00	0.00	172.00	0.00	1,315.00	1,315.00	0.00	0.00	0.00	Verif.Sales
10/7/2023	1,315.00	0.00	139.00	0.00	1,176.00	1,177.00	0.00	1.00	1.00	
10/8/2023	1,177.00	0.00	180.00	0.00	997.00	997.00	0.00	0.00	1.00	Verif.Sales
10/9/2023	997.00	0.00	169.00	0.00	828.00	827.00	0.00	-1.00	0.00	
10/10/2023	827.00	0.00	141.00	0.00	686.00	686.00	0.00	0.00	0.00	Verif.Sales
10/11/2023	686.00	0.00	105.00	0.00	581.00	581.00	0.00	0.00	0.00	Verif.Sales
10/12/2023	581.00	0.00	97.00	0.00	484.00	484.00	0.00	0.00	0.00	Verif.Sales
10/13/2023	484.00	1,500.00	133.00	0.00	1,851.00	1,851.00	0.00	0.00	0.00	Verif.Sales
10/14/2023	1,851.00	0.00	176.00	0.00	1,675.00	1,675.00	0.00	0.00	0.00	Verif.Sales
10/15/2023	1,675.00	0.00	136.00	0.00	1,539.00	1,539.00	0.00	0.00	0.00	Verif.Sales
10/16/2023	1,539.00	0.00	108.00	0.00	1,431.00	1,431.00	0.00	0.00	0.00	Verif.Sales
10/17/2023	1,431.00	0.00	145.00	0.00	1,286.00	1,285.00	0.00	-1.00	-1.00	
10/18/2023	1,285.00	0.00	152.00	0.00	1,133.00	1,130.00	0.00	-3.00	-4.00	
10/19/2023	1,130.00	0.00	113.00	0.00	1,017.00	1,019.00	0.00	2.00	-2.00	
10/20/2023	1,019.00	0.00	48.00	0.00	971.00	971.00	0.00	0.00	-2.00	Verif.Sales
10/21/2023	971.00	600.00	147.00	0.00	1,424.00	1,427.00	0.00	3.00	1.00	
10/22/2023	1,427.00	0.00	151.00	0.00	1,276.00	1,276.00	0.00	0.00	1.00	Verif.Sales
10/23/2023	1,276.00	0.00	88.00	0.00	1,188.00	1,188.00	0.00	0.00	1.00	Verif.Sales
10/24/2023	1,188.00	0.00	126.00	0.00	1,062.00	1,061.00	0.00	-1.00	0.00	
10/25/2023	1,061.00	0.00	143.00	0.00	918.00	918.00	0.00	0.00	0.00	Verif.Sales
10/26/2023	918.00	0.00	117.00	0.00	801.00	800.00	0.00	-1.00	-1.00	
10/27/2023	800.00	1,000.00	132.00	0.00	1,668.00	1,760.00	0.00	92.00	91.00	Verif.Del.Over.
10/28/2023	1,760.00	0.00	128.00	0.00	1,632.00	1,632.00	0.00	0.00	91.00	Verif.Sales
10/29/2023	1,632.00	0.00	95.00	0.00	1,537.00	1,536.00	0.00	-1.00	90.00	
10/30/2023	1,536.00	0.00	199.00	0.00	1,337.00	1,337.00	0.00	0.00	90.00	Verif.Sales
10/31/2023	1,337.00	0.00	140.00	0.00	1,197.00	1,195.00	0.00	-2.00	88.00	
11/1/2023	1,195.00	0.00	138.00	0.00	1,057.00	1,056.00	0.00	-1.00	87.00	
TOTALS		3,620.00	3,967.00	0.00			0.00	87.00	87.00	

Leak Check = ( 3,967.00 \* 0.01 + 130 ) = 169.7 gall

## Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	169.7 gall	0.0 inches	-0.0186 gph	0.0101 gph	PASS	PASS	PASS
Min. Daily Sales :		48.0	Max. Daily Sales :		199.0	Avg. Daily Sales : 132.2	

General comments :