

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd

Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 01

Product : REGULAR

Date generated 10/06/2023

Effective Dates : 09/03/23 to 10/02/23

| Date | Beg.Inv. | Delivery | Sales | Adjust | Total | Stick | Water | Daily O/S | Cumul. O/S | Comments |
|-----------|----------|-----------|-----------|--------|----------|----------|-------|--------------|---------------|--------------------|
| 9/3/2023 | 1,571.00 | 6,501.00 | 815.00 | 0.00 | 7,257.00 | 7,018.00 | 0.00 | -239.00 | -239.00 | Verif.Del.Shortage |
| 9/4/2023 | 7,018.00 | 0.00 | 952.00 | 0.00 | 6,066.00 | 6,057.00 | 0.00 | -9.00 | -248.00 | |
| 9/5/2023 | 6,057.00 | 0.00 | 1,040.00 | 0.00 | 5,017.00 | 5,009.00 | 0.00 | -8.00 | -256.00 | |
| 9/6/2023 | 5,009.00 | 0.00 | 774.00 | 0.00 | 4,235.00 | 4,232.00 | 0.00 | -3.00 | -259.00 | |
| 9/7/2023 | 4,232.00 | 0.00 | 993.00 | 0.00 | 3,239.00 | 3,227.00 | 0.00 | -12.00 | -271.00 | |
| 9/8/2023 | 3,227.00 | 0.00 | 1,151.00 | 0.00 | 2,076.00 | 2,079.00 | 0.00 | 3.00 | -268.00 | |
| 9/9/2023 | 2,079.00 | 0.00 | 712.00 | 0.00 | 1,367.00 | 1,370.00 | 0.00 | 3.00 | -265.00 | |
| 9/10/2023 | 1,370.00 | 6,000.00 | 871.00 | 0.00 | 6,499.00 | 6,527.00 | 0.00 | 28.00 | -237.00 | |
| 9/11/2023 | 6,527.00 | 0.00 | 916.00 | 0.00 | 5,611.00 | 5,608.00 | 0.00 | -3.00 | -240.00 | |
| 9/12/2023 | 5,608.00 | 0.00 | 1,116.00 | 0.00 | 4,492.00 | 4,489.00 | 0.00 | -3.00 | -243.00 | |
| 9/13/2023 | 4,489.00 | 0.00 | 1,078.00 | 0.00 | 3,411.00 | 3,404.00 | 0.00 | -7.00 | -250.00 | |
| 9/14/2023 | 3,404.00 | 0.00 | 1,045.00 | 0.00 | 2,359.00 | 2,354.00 | 0.00 | -5.00 | -255.00 | |
| 9/15/2023 | 2,354.00 | 0.00 | 1,188.00 | 0.00 | 1,166.00 | 1,170.00 | 0.00 | 4.00 | -251.00 | |
| 9/16/2023 | 1,170.00 | 6,500.00 | 1,078.00 | 0.00 | 6,592.00 | 6,619.00 | 0.00 | 27.00 | -224.00 | |
| 9/17/2023 | 6,619.00 | 0.00 | 1,081.00 | 0.00 | 5,538.00 | 5,540.00 | 0.00 | 2.00 | -222.00 | |
| 9/18/2023 | 5,540.00 | 0.00 | 962.00 | 0.00 | 4,578.00 | 4,576.00 | 0.00 | -2.00 | -224.00 | |
| 9/19/2023 | 4,576.00 | 0.00 | 1,286.00 | 0.00 | 3,290.00 | 3,284.00 | 0.00 | -6.00 | -230.00 | |
| 9/20/2023 | 3,284.00 | 0.00 | 1,129.00 | 0.00 | 2,155.00 | 2,150.00 | 0.00 | -5.00 | -235.00 | |
| 9/21/2023 | 2,150.00 | 0.00 | 1,105.00 | 0.00 | 1,045.00 | 1,050.00 | 0.00 | 5.00 | -230.00 | |
| 9/22/2023 | 1,050.00 | 6,002.00 | 1,187.00 | 0.00 | 5,865.00 | 5,875.00 | 0.00 | 10.00 | -220.00 | |
| 9/23/2023 | 5,875.00 | 0.00 | 1,148.00 | 0.00 | 4,727.00 | 4,724.00 | 0.00 | -3.00 | -223.00 | |
| 9/24/2023 | 4,724.00 | 0.00 | 979.00 | 0.00 | 3,745.00 | 3,741.00 | 0.00 | -4.00 | -227.00 | |
| 9/25/2023 | 3,741.00 | 0.00 | 1,158.00 | 0.00 | 2,583.00 | 2,569.00 | 0.00 | -14.00 | -241.00 | |
| 9/26/2023 | 2,569.00 | 0.00 | 1,064.00 | 0.00 | 1,505.00 | 1,516.00 | 0.00 | 11.00 | -230.00 | |
| 9/27/2023 | 1,516.00 | 0.00 | 1,005.00 | 0.00 | 511.00 | 516.00 | 0.00 | 5.00 | -225.00 | |
| 9/28/2023 | 516.00 | 6,800.00 | 800.00 | 0.00 | 6,516.00 | 6,542.00 | 0.00 | 26.00 | -199.00 | |
| 9/29/2023 | 6,542.00 | 0.00 | 1,276.00 | 0.00 | 5,266.00 | 5,261.00 | 0.00 | -5.00 | -204.00 | |
| 9/30/2023 | 5,261.00 | 0.00 | 961.00 | 0.00 | 4,300.00 | 4,298.00 | 0.00 | -2.00 | -206.00 | |
| 10/1/2023 | 4,298.00 | 0.00 | 806.00 | 0.00 | 3,492.00 | 3,487.00 | 0.00 | -5.00 | -211.00 | |
| 10/2/2023 | 3,487.00 | 0.00 | 836.00 | 0.00 | 2,651.00 | 2,639.00 | 0.00 | -12.00 | -223.00 | |
| TOTALS | | 31,803.00 | 30,512.00 | 0.00 | | | 0.00 | -223.00 | -223.00 | |

Leak Check = (30,512.00 * 0.01 + 130) = 435.1 gall

Quantitative methods

| Leak Threshold | Leak Check | Water Level incr/decr | This month | | | Last month | Two months ago |
|-------------------|---------------|--------------------------|----------------------|----------------------|-------------|-------------|----------------|
| | | | Calculated Leak Rate | Min.Detec. Leak Rate | Test Result | Test Result | Test Result |
| 0.1000 | 435.1 gall | 0.0 inches | -0.0085 gph | 0.0603 gph | PASS | PASS | PASS |

Min. Daily Sales : 712.0

Max. Daily Sales : 1286.0

Avg. Daily Sales : 1017.1

General comments :

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd

Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 02

Product : SUPER

Date generated 10/06/2023

Effective Dates : 09/03/23 to 10/02/23

| Date | Beg.Inv. | Delivery | Sales | Adjust | Total | Stick | Water | Daily O/S | Cumul. O/S | Comments |
|-----------|----------|----------|----------|--------|----------|----------|-------|--------------|---------------|-------------|
| 9/3/2023 | 1,033.00 | 700.00 | 84.00 | 0.00 | 1,649.00 | 1,655.00 | 0.00 | 6.00 | 6.00 | |
| 9/4/2023 | 1,655.00 | 0.00 | 22.00 | 0.00 | 1,633.00 | 1,636.00 | 0.00 | 3.00 | 9.00 | |
| 9/5/2023 | 1,636.00 | 0.00 | 39.00 | 0.00 | 1,597.00 | 1,618.00 | 0.00 | 21.00 | 30.00 | |
| 9/6/2023 | 1,618.00 | 0.00 | 64.00 | 0.00 | 1,554.00 | 1,554.00 | 0.00 | 0.00 | 30.00 | Verif.Sales |
| 9/7/2023 | 1,554.00 | 0.00 | 109.00 | 0.00 | 1,445.00 | 1,446.00 | 0.00 | 1.00 | 31.00 | |
| 9/8/2023 | 1,446.00 | 0.00 | 178.00 | 0.00 | 1,268.00 | 1,270.00 | 0.00 | 2.00 | 33.00 | |
| 9/9/2023 | 1,270.00 | 0.00 | 125.00 | 0.00 | 1,145.00 | 1,146.00 | 0.00 | 1.00 | 34.00 | |
| 9/10/2023 | 1,146.00 | 500.00 | 92.00 | 0.00 | 1,554.00 | 1,554.00 | 0.00 | 0.00 | 34.00 | Verif.Sales |
| 9/11/2023 | 1,554.00 | 0.00 | 100.00 | 0.00 | 1,454.00 | 1,455.00 | 0.00 | 1.00 | 35.00 | |
| 9/12/2023 | 1,455.00 | 0.00 | 155.00 | 0.00 | 1,300.00 | 1,301.00 | 0.00 | 1.00 | 36.00 | |
| 9/13/2023 | 1,301.00 | 0.00 | 101.00 | 0.00 | 1,200.00 | 1,200.00 | 0.00 | 0.00 | 36.00 | Verif.Sales |
| 9/14/2023 | 1,200.00 | 0.00 | 130.00 | 0.00 | 1,070.00 | 1,070.00 | 0.00 | 0.00 | 36.00 | Verif.Sales |
| 9/15/2023 | 1,070.00 | 0.00 | 112.00 | 0.00 | 958.00 | 958.00 | 0.00 | 0.00 | 36.00 | Verif.Sales |
| 9/16/2023 | 958.00 | 1,000.00 | 138.00 | 0.00 | 1,820.00 | 1,822.00 | 0.00 | 2.00 | 38.00 | |
| 9/17/2023 | 1,822.00 | 0.00 | 182.00 | 0.00 | 1,640.00 | 1,643.00 | 0.00 | 3.00 | 41.00 | |
| 9/18/2023 | 1,643.00 | 0.00 | 112.00 | 0.00 | 1,531.00 | 1,532.00 | 0.00 | 1.00 | 42.00 | |
| 9/19/2023 | 1,532.00 | 0.00 | 184.00 | 0.00 | 1,348.00 | 1,348.00 | 0.00 | 0.00 | 42.00 | Verif.Sales |
| 9/20/2023 | 1,348.00 | 0.00 | 161.00 | 0.00 | 1,187.00 | 1,187.00 | 0.00 | 0.00 | 42.00 | Verif.Sales |
| 9/21/2023 | 1,187.00 | 0.00 | 163.00 | 0.00 | 1,024.00 | 1,024.00 | 0.00 | 0.00 | 42.00 | Verif.Sales |
| 9/22/2023 | 1,024.00 | 600.00 | 118.00 | 0.00 | 1,506.00 | 1,506.00 | 0.00 | 0.00 | 42.00 | Verif.Sales |
| 9/23/2023 | 1,506.00 | 0.00 | 190.00 | 0.00 | 1,316.00 | 1,317.00 | 0.00 | 1.00 | 43.00 | |
| 9/24/2023 | 1,317.00 | 0.00 | 192.00 | 0.00 | 1,125.00 | 1,126.00 | 0.00 | 1.00 | 44.00 | |
| 9/25/2023 | 1,126.00 | 0.00 | 85.00 | 0.00 | 1,041.00 | 1,041.00 | 0.00 | 0.00 | 44.00 | Verif.Sales |
| 9/26/2023 | 1,041.00 | 0.00 | 175.00 | 0.00 | 866.00 | 867.00 | 0.00 | 1.00 | 45.00 | |
| 9/27/2023 | 867.00 | 0.00 | 86.00 | 0.00 | 781.00 | 781.00 | 0.00 | 0.00 | 45.00 | Verif.Sales |
| 9/28/2023 | 781.00 | 1,200.00 | 96.00 | 0.00 | 1,885.00 | 1,877.00 | 0.00 | -8.00 | 37.00 | |
| 9/29/2023 | 1,877.00 | 0.00 | 118.00 | 0.00 | 1,759.00 | 1,759.00 | 0.00 | 0.00 | 37.00 | Verif.Sales |
| 9/30/2023 | 1,759.00 | 0.00 | 170.00 | 0.00 | 1,589.00 | 1,590.00 | 0.00 | 1.00 | 38.00 | |
| 10/1/2023 | 1,590.00 | 0.00 | 133.00 | 0.00 | 1,457.00 | 1,457.00 | 0.00 | 0.00 | 38.00 | Verif.Sales |
| 10/2/2023 | 1,457.00 | 0.00 | 142.00 | 0.00 | 1,315.00 | 1,316.00 | 0.00 | 1.00 | 39.00 | |
| TOTALS | | 4,000.00 | 3,756.00 | 0.00 | | | 0.00 | 39.00 | 39.00 | |

Leak Check = (3,756.00 * 0.01 + 130) = 167.6 gall

Quantitative methods

| Leak Threshold | Leak Check | Water Level incr/decr | This month | | | Last month | Two months ago |
|--------------------|------------|-----------------------|----------------------|----------------------|-------------|--------------------------|----------------|
| | | | Calculated Leak Rate | Min.Detec. Leak Rate | Test Result | Test Result | Test Result |
| 0.1000 | 167.6 gall | 0.0 inches | -0.0011 gph | 0.0193 gph | PASS | PASS | PASS |
| Min. Daily Sales : | | 22.0 | Max. Daily Sales : | | 192.0 | Avg. Daily Sales : 125.2 | |

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496