

FUEL INVENTORY CONTROL REPORT

FACILITY NAME: Kool Corner MONTH/YEAR: JULY 2024

FACILITY ID #: 67397 TANK SIZE: 8000 FUEL TYPE: REGULAR

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
29-Jun		1566	0	951	615		614	-1	-1
30-Jun		614	6802	1061	6355		6380	25	24
1-Jul		6380	0	995	5385		5378	-7	17
2-Jul		5378	0	1021	4357		4358	1	18
3-Jul		4358	0	939	3419		3421	2	20
4-Jul		3421	0	641	2780		2766	-14	6
5-Jul		2766	0	752	2014		2015	1	7
6-Jul		2015	0	836	1179		1183	4	11
7-Jul		1183	5500	816	5867		5891	24	35
8-Jul		5891	0	896	4995		4996	1	36
9-Jul		4996	0	977	4019		4019	0	36
10-Jul		4019	0	1018	3001		2995	-6	30
11-Jul		2995	0	800	2195		2189	-6	24
12-Jul		2189	0	1012	1177		1188	11	35
13-Jul		1188	6002	1026	6164		6193	29	64
14-Jul		6193	0	944	5249		5242	-7	57
15-Jul		5242	0	1166	4076		4074	-2	55
16-Jul		4074	0	854	3220		3215	-5	50
17-Jul		3215	0	915	2300		2298	-2	48
18-Jul		2298	0	951	1347		1351	4	52
19-Jul		1351	5900	987	6264		6302	38	90
20-Jul		6302	0	1036	5266		5259	-7	83
21-Jul		5259	0	818	4441		4438	-3	80
22-Jul		4438	0	932	3506		3501	-5	75
23-Jul		3501	0	994	2507		2502	-5	70
24-Jul		2502	0	1036	1466		1469	3	73
25-Jul		1469	5500	878	6091		6110	19	92
26-Jul		6110	0	890	5220		5217	-3	89
27-Jul		5217	0	806	4411		4409	-2	87
28-Jul		4409	0	955	3454		3460	6	93

TOTAL SALES: 27903 TOTAL OVER/SHORT: 93

LEAK TEST: 409.03 WATER CHECK (INCHES): 0 PASS / FAIL: PASS

NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.

FUEL INVENTORY CONTROL REPORT

FACILITY NAME: Kool Corner MONTH/YEAR: JULY | 2024

FACILITY ID #: 67397 TANK SIZE: 8000 FUEL TYPE: SUPER

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
29-Jun		1022	0	116	906		907	1	1
30-Jun		907	800	119	1588		1587	-1	0
1-Jul		1587	0	84	1503		1504	1	1
2-Jul		1504	0	87	1417		1418	1	2
3-Jul		1418	0	94	1324		1325	1	3
4-Jul		1325	0	88	1237		1238	1	4
5-Jul		1238	0	99	1139		1140	1	5
6-Jul		1140	0	96	1044		1044	0	5
7-Jul		1044	500	87	1457		1457	0	5
8-Jul		1457	0	73	1384		1390	6	11
9-Jul		1390	0	144	1246		1248	2	13
10-Jul		1248	0	106	1142		1143	1	14
11-Jul		1143	0	130	1013		1014	1	15
12-Jul		1014	0	122	892		892	0	15
13-Jul		892	700	107	1485		1488	3	18
14-Jul		1488	0	97	1391		1392	1	19
15-Jul		1392	0	81	1311		1311	0	19
16-Jul		1311	0	107	1204		1206	2	21
17-Jul		1206	0	99	1107		1107	0	21
18-Jul		1107	0	119	988		988	0	21
19-Jul		988	700	95	1593		1592	-1	20
20-Jul		1592	0	89	1503		1505	2	22
21-Jul		1505	0	104	1401		1403	2	24
22-Jul		1403	0	108	1295		1296	1	25
23-Jul		1296	0	114	1182		1187	5	30
24-Jul		1187	0	79	1108		1108	0	30
25-Jul		1108	1000	126	1982		1981	-1	29
26-Jul		1981	0	101	1880		1882	2	31
27-Jul		1882	0	76	1806		1806	0	31
28-Jul		1806	0	110	1696		1698	2	33

TOTAL SALES: 3057

TOTAL OVER/SHORT: 33

LEAK TEST: 160.57

WATER CHECK (INCHES): 0

PASS / FAIL: PASS

NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.