

FUEL INVENTORY CONTROL REPORT

FACILITY NAME:

Kool Corner

MONTH/YEAR:

JUNE

2024

FACILITY ID #:

67397

TANK SIZE:

8000

FUEL TYPE:

REGULAR

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
30-May		3154	0	944	2210		2209	-1	-1
31-May		2209	0	1034	1175		1181	6	5
1-Jun		1181	6310	1030	6461		6461	0	5
2-Jun		6461	0	958	5503		5491	-12	-7
3-Jun		5491	0	987	4504		4500	-4	-11
4-Jun		4500	0	1000	3500		3495	-5	-16
5-Jun		3495	0	904	2591		2587	-4	-20
6-Jun		2587	0	929	1658		1661	3	-17
7-Jun		1661	0	825	836		842	6	-11
8-Jun		842	6701	627	6916		6953	37	26
9-Jun		6953	0	833	6120		6111	-9	17
10-Jun		6111	0	872	5239		5233	-6	11
11-Jun		5233	0	817	4416		4414	-2	9
12-Jun		4414	0	702	3712		3709	-3	6
13-Jun		3709	0	889	2820		2823	3	9
14-Jun		2823	0	964	1859		1854	-5	4
15-Jun		1854	0	1126	728		736	8	12
16-Jun		736	6509	527	6718		6739	21	33
17-Jun		6739	0	1034	5705		5691	-14	19
18-Jun		5691	0	1016	4675		4668	-7	12
19-Jun		4668	0	864	3804		3799	-5	7
20-Jun		3799	0	983	2816		2810	-6	1
21-Jun		2810	0	1082	1728		1729	1	2
22-Jun		1729	0	1045	684		689	5	7
23-Jun		689	6301	718	6272		6286	14	21
24-Jun		6286	0	981	5305		5295	-10	11
25-Jun		5295	0	926	4369		4364	-5	6
26-Jun		4364	0	889	3475		3470	-5	1
27-Jun		3470	0	913	2557		2554	-3	-2
28-Jun		2554	0	999	1555		1566	11	9

TOTAL SALES:

27418

TOTAL OVER/SHORT:

9

LEAK TEST:

404.18

WATER CHECK (INCHES):

0

PASS / FAIL:

PASS

NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.

FUEL INVENTORY CONTROL REPORT

FACILITY NAME: Kool Corner MONTH/YEAR: JUNE 2024

FACILITY ID #: 67397 TANK SIZE: 8000 FUEL TYPE: SUPER

DATE	OPEN INVENTORY		DELIVERY	DAILY SALES	BOOK INVENTORY	CLOSING INVENTORY		DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
	Inches	Gallons	Gallons	Gallons	Gallons	Inches	Gallons	Gallons	Gallons
30-May		1305	0	105	1200		1201	1	1
31-May		1201	0	160	1041		1042	1	2
1-Jun		1042	600	123	1519		1518	-1	1
2-Jun		1518	0	124	1394		1394	0	1
3-Jun		1394	0	125	1269		1269	0	1
4-Jun		1269	0	90	1179		1180	1	2
5-Jun		1180	0	57	1123		1124	1	3
6-Jun		1124	0	143	981		982	1	4
7-Jun		982	0	104	878		878	0	4
8-Jun		878	500	139	1239		1238	-1	3
9-Jun		1238	0	118	1120		1120	0	3
10-Jun		1120	0	102	1018		1019	1	4
11-Jun		1019	0	79	940		941	1	5
12-Jun		941	0	72	869		869	0	5
13-Jun		869	0	184	685		686	1	6
14-Jun		686	0	102	584		586	2	8
15-Jun		586	0	202	384		385	1	9
16-Jun		385	1500	45	1840		1837	-3	6
17-Jun		1837	0	143	1694		1692	-2	4
18-Jun		1692	0	62	1630		1631	1	5
19-Jun		1631	0	108	1523		1523	0	5
20-Jun		1523	0	183	1340		1342	2	7
21-Jun		1342	0	103	1239		1239	0	7
22-Jun		1239	0	184	1055		1056	1	8
23-Jun		1056	600	51	1605		1603	-2	6
24-Jun		1603	0	97	1506		1506	0	6
25-Jun		1506	0	137	1369		1371	2	8
26-Jun		1371	0	120	1251		1252	1	9
27-Jun		1252	0	118	1134		1135	1	10
28-Jun		1135	0	114	1021		1022	1	11

TOTAL SALES: 3494 TOTAL OVER/SHORT: 11

LEAK TEST: 164.94 WATER CHECK (INCHES): 0 PASS / FAIL: PASS

NOTE: Monthly over/short should not be greater than 1% plus 130 gallons for compliance with state regulations. Notify the TCEQ Regional Office within 24 hours if your over/short exceeds this amount.