

**APPENDIX C-7****AUTOMATIC TANK GAUGE  
OPERATION INSPECTION**

Facility Name: <b>Foodies Corner 5</b>	Owner: <b>Whitestone Business, INC</b>	
Address: <b>1405 W Whitestone Blvd</b>	Address: <b>1405 W Whitestone Blvd</b>	
City, State, Zip Code: <b>Cedar Park, TX 78613</b>	City, State, Zip Code: <b>Cedar Park, TX 78613</b>	
Facility I.D. #: <b>55347</b>	Phone #:	
Testing Company: <b>Petro-Tank Solutions</b>	Phone #:	Date: <b>6/17/2024</b>

This procedure is to determine whether the automatic tank gauge (ATG) is operating properly. See PEI/RP1200 Section 8.2 for the inspection procedure. This procedure is applicable to tank level monitor stems that touch the bottom of the tank when in place.

Tank Number	1A	2A	3A	
Product Stored	<b>Diesel</b>	<b>Regular</b>	<b>Super</b>	
ATG Brand and Model	<b>TLS-350</b>	<b>TLS-350</b>	<b>TLS-350</b>	
1. Tank Volume, gallons	<b>8000</b>	<b>8000</b>	<b>8000</b>	
2. Tank Diameter, inches	<b>92"</b>	<b>92"</b>	<b>92"</b>	
3. After removing the ATG from the tank, it has been inspected and any damaged or missing parts replaced?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
4. Float moves freely on the stem without binding?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
5. Fuel float level agrees with the value programmed into the console?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
6. Water float level agrees with the value programmed into the console?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
7. Inch level from bottom of stem when 90% alarm is triggered.	<b>76 1/2</b>	<b>76 1/2</b>	<b>76 1/2</b>	
8. Inch level at which the overfill alarm activates corresponds with value programmed in the gauge?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
9. Inch level from the bottom when the water float first triggers an alarm.	<b>.25</b>	<b>.25</b>	<b>.25</b>	
10. Inch level at which the water float alarm activates corresponds with value programmed in the gauge?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No

If any answers in Lines 3, 4, 5, or 6 are "No," the system has failed the test.

<b>Test Results</b>	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail	<input type="checkbox"/> Pass <input type="checkbox"/> Fail
---------------------	------------------------------------------------------------------------	------------------------------------------------------------------------	------------------------------------------------------------------------	-------------------------------------------------------------

**Comments:**

Tester's Name (print) Jadell Burns

Tester's Signature

*Jadell B*