

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd
Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 01

Product : REGULAR

Date generated 04/04/2024

Effective Dates : 03/01/24 to 03/30/24

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
3/1/2024	4,322.00	0.00	844.00	0.00	3,478.00	3,471.00	0.00	-7.00	-7.00	
3/2/2024	3,471.00	0.00	896.00	0.00	2,575.00	2,570.00	0.00	-5.00	-12.00	
3/3/2024	2,570.00	0.00	958.00	0.00	1,612.00	1,613.00	0.00	1.00	-11.00	
3/4/2024	1,613.00	0.00	696.00	0.00	917.00	920.00	0.00	3.00	-8.00	
3/5/2024	920.00	6,000.00	855.00	0.00	6,065.00	6,082.00	0.00	17.00	9.00	
3/6/2024	6,082.00	0.00	664.00	0.00	5,418.00	5,410.00	0.00	-8.00	1.00	
3/7/2024	5,410.00	0.00	622.00	0.00	4,788.00	4,786.00	0.00	-2.00	-1.00	
3/8/2024	4,786.00	0.00	1,009.00	0.00	3,777.00	3,772.00	0.00	-5.00	-6.00	
3/9/2024	3,772.00	0.00	838.00	0.00	2,934.00	2,928.00	0.00	-6.00	-12.00	
3/10/2024	2,928.00	0.00	852.00	0.00	2,076.00	2,073.00	0.00	-3.00	-15.00	
3/11/2024	2,073.00	0.00	711.00	0.00	1,362.00	1,365.00	0.00	3.00	-12.00	
3/12/2024	1,365.00	6,501.00	851.00	0.00	7,015.00	7,041.00	0.00	26.00	14.00	
3/13/2024	7,041.00	0.00	748.00	0.00	6,293.00	6,282.00	0.00	-11.00	3.00	
3/14/2024	6,282.00	0.00	674.00	0.00	5,608.00	5,602.00	0.00	-6.00	-3.00	
3/15/2024	5,602.00	0.00	664.00	0.00	4,938.00	4,933.00	0.00	-5.00	-8.00	
3/16/2024	4,933.00	0.00	703.00	0.00	4,230.00	4,228.00	0.00	-2.00	-10.00	
3/17/2024	4,228.00	0.00	815.00	0.00	3,413.00	3,407.00	0.00	-6.00	-16.00	
3/18/2024	3,407.00	0.00	767.00	0.00	2,640.00	2,635.00	0.00	-5.00	-21.00	
3/19/2024	2,635.00	0.00	1,001.00	0.00	1,634.00	1,636.00	0.00	2.00	-19.00	
3/20/2024	1,636.00	0.00	1,057.00	0.00	579.00	583.00	0.00	4.00	-15.00	
3/21/2024	583.00	6,501.00	819.00	0.00	6,265.00	6,267.00	0.00	2.00	-13.00	
3/22/2024	6,267.00	0.00	1,030.00	0.00	5,237.00	5,232.00	0.00	-5.00	-18.00	
3/23/2024	5,232.00	0.00	850.00	0.00	4,382.00	4,380.00	0.00	-2.00	-20.00	
3/24/2024	4,380.00	0.00	875.00	0.00	3,505.00	3,500.00	0.00	-5.00	-25.00	
3/25/2024	3,500.00	0.00	907.00	0.00	2,593.00	2,588.00	0.00	-5.00	-30.00	
3/26/2024	2,588.00	0.00	894.00	0.00	1,694.00	1,695.00	0.00	1.00	-29.00	
3/27/2024	1,695.00	0.00	1,041.00	0.00	654.00	656.00	0.00	2.00	-27.00	
3/28/2024	656.00	6,501.00	1,180.00	0.00	5,977.00	5,984.00	0.00	7.00	-20.00	
3/29/2024	5,984.00	0.00	900.00	0.00	5,084.00	5,087.00	0.00	3.00	-17.00	
3/30/2024	5,087.00	0.00	885.00	0.00	4,202.00	4,198.00	0.00	-4.00	-21.00	
TOTALS		25,503.00	25,606.00	0.00			0.00	-21.00	-21.00	

Leak Check = (25,606.00 * 0.01 + 130) = 386.1 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	386.1 gall	0.0 inches	0.0123 gph	0.0245 gph	PASS	PASS	PASS
Min. Daily Sales :		622.0	Max. Daily Sales :		1180.0	Avg. Daily Sales : 853.5	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd
Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 02

Product : SUPER

Date generated 04/04/2024

Effective Dates : 03/01/24 to 03/30/24

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
3/1/2024	1,307.00	0.00	106.00	0.00	1,201.00	1,201.00	0.00	0.00	0.00	Verif.Sales
3/2/2024	1,201.00	0.00	140.00	0.00	1,061.00	1,061.00	0.00	0.00	0.00	Verif.Sales
3/3/2024	1,061.00	0.00	141.00	0.00	920.00	919.00	0.00	-1.00	-1.00	
3/4/2024	919.00	0.00	77.00	0.00	842.00	842.00	0.00	0.00	-1.00	Verif.Sales
3/5/2024	842.00	1,000.00	105.00	0.00	1,737.00	1,734.00	0.00	-3.00	-4.00	
3/6/2024	1,734.00	0.00	59.00	0.00	1,675.00	1,673.00	0.00	-2.00	-6.00	
3/7/2024	1,673.00	0.00	68.00	0.00	1,605.00	1,605.00	0.00	0.00	-6.00	Verif.Sales
3/8/2024	1,605.00	0.00	135.00	0.00	1,470.00	1,471.00	0.00	1.00	-5.00	
3/9/2024	1,471.00	0.00	114.00	0.00	1,357.00	1,357.00	0.00	0.00	-5.00	Verif.Sales
3/10/2024	1,357.00	0.00	109.00	0.00	1,248.00	1,248.00	0.00	0.00	-5.00	Verif.Sales
3/11/2024	1,248.00	0.00	120.00	0.00	1,128.00	1,128.00	0.00	0.00	-5.00	Verif.Sales
3/12/2024	1,128.00	520.00	120.00	0.00	1,528.00	1,528.00	0.00	0.00	-5.00	Verif.Sales
3/13/2024	1,528.00	0.00	146.00	0.00	1,382.00	1,383.00	0.00	1.00	-4.00	
3/14/2024	1,383.00	0.00	97.00	0.00	1,286.00	1,287.00	0.00	1.00	-3.00	
3/15/2024	1,287.00	0.00	125.00	0.00	1,162.00	1,162.00	0.00	0.00	-3.00	Verif.Sales
3/16/2024	1,162.00	0.00	123.00	0.00	1,039.00	1,039.00	0.00	0.00	-3.00	Verif.Sales
3/17/2024	1,039.00	0.00	212.00	0.00	827.00	827.00	0.00	0.00	-3.00	Verif.Sales
3/18/2024	827.00	0.00	97.00	0.00	730.00	729.00	0.00	-1.00	-4.00	
3/19/2024	729.00	0.00	98.00	0.00	631.00	630.00	0.00	-1.00	-5.00	
3/20/2024	630.00	0.00	92.00	0.00	538.00	537.00	0.00	-1.00	-6.00	
3/21/2024	537.00	1,500.00	97.00	0.00	1,940.00	1,943.00	0.00	3.00	-3.00	
3/22/2024	1,943.00	0.00	172.00	0.00	1,771.00	1,773.00	0.00	2.00	-1.00	
3/23/2024	1,773.00	0.00	111.00	0.00	1,662.00	1,663.00	0.00	1.00	0.00	
3/24/2024	1,663.00	0.00	189.00	0.00	1,474.00	1,475.00	0.00	1.00	1.00	
3/25/2024	1,475.00	0.00	128.00	0.00	1,347.00	1,347.00	0.00	0.00	1.00	Verif.Sales
3/26/2024	1,347.00	0.00	152.00	0.00	1,195.00	1,195.00	0.00	0.00	1.00	Verif.Sales
3/27/2024	1,195.00	0.00	119.00	0.00	1,076.00	1,075.00	0.00	-1.00	0.00	
3/28/2024	1,075.00	1,000.00	171.00	0.00	1,904.00	1,907.00	0.00	3.00	3.00	
3/29/2024	1,907.00	0.00	118.00	0.00	1,789.00	1,793.00	0.00	4.00	7.00	
3/30/2024	1,793.00	0.00	96.00	0.00	1,697.00	1,695.00	0.00	-2.00	5.00	
TOTALS		4,020.00	3,637.00	0.00			0.00	5.00	5.00	

Leak Check = (3,637.00 * 0.01 + 130) = 166.4 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	166.4 gall	0.0 inches	-0.0002 gph	0.0067 gph	PASS	PASS	PASS
Min. Daily Sales :		59.0	Max. Daily Sales :		212.0	Avg. Daily Sales : 121.2	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496