



LINE AND LEAK DETECTOR TEST DATA FORM

Facility Name: All Star Grocery 1 Date: 02/15/2025

Facility Address: 4619 S Congress Ave

Facility Phone: _____

Test Contractor: PETRO-TANK SOLUTIONS, LLC

Address: 6115 FM 762 Rd Suite 500 Tester: Tyler Shaeffer
Richmond, Tx 77469

Contractor Phone: (281) 242-2687 License # 4865.LTN

| Product | Regular | Super | Diesel | |
|---|------------|------------|------------|--|
| Pump Manufacturer | Red Jacket | Red Jacket | Red Jacket | |
| Isolation Mechanism | Ball Valve | | | |
| Test Pressure (1 1/2 times working pressure) | 50 | | | |
| Initial Cylinder Level (ICL) | .095 | | | |
| Final Cylinder Level (FCL) | .095 | | | |
| Leak Volume = ICL - FCL | 0 | | | |
| Time Started | 10:30 | | | |
| Time Completed | 11:00 | | | |
| Total Test Time (30 min. minimum) | 30 | | | |
| Conclusion (Pass or Fail) | Pass | | | |
| Leak Detector Manufacturer | Red Jacket | | | |
| Line PSI | 27 | | | |
| Leak Detector Result (Pass or Fail) | Pass | | | |

Comments: _____
