

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd
Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 01

Product : REGULAR

Date generated 05/06/2023

Effective Dates : 04/06/23 to 05/05/23

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
4/6/2023	1,436.00	0.00	998.00	0.00	438.00	442.00	0.00	4.00	4.00	
4/7/2023	442.00	6,501.00	961.00	0.00	5,982.00	5,992.00	0.00	10.00	14.00	
4/8/2023	5,992.00	0.00	895.00	0.00	5,097.00	5,097.00	0.00	0.00	14.00	Verif.Sales
4/9/2023	5,097.00	0.00	841.00	0.00	4,256.00	4,262.00	0.00	6.00	20.00	
4/10/2023	4,262.00	0.00	725.00	0.00	3,537.00	3,532.00	0.00	-5.00	15.00	
4/11/2023	3,532.00	0.00	989.00	0.00	2,543.00	2,538.00	0.00	-5.00	10.00	
4/12/2023	2,538.00	0.00	1,052.00	0.00	1,486.00	1,488.00	0.00	2.00	12.00	
4/13/2023	1,488.00	3,502.00	1,014.00	0.00	3,976.00	3,974.00	0.00	-2.00	10.00	
4/14/2023	3,974.00	0.00	1,079.00	0.00	2,895.00	2,889.00	0.00	-6.00	4.00	
4/15/2023	2,889.00	0.00	1,096.00	0.00	1,793.00	1,795.00	0.00	2.00	6.00	
4/16/2023	1,795.00	0.00	1,017.00	0.00	778.00	783.00	0.00	5.00	11.00	
4/17/2023	783.00	6,000.00	958.00	0.00	5,825.00	5,840.00	0.00	15.00	26.00	
4/18/2023	5,840.00	0.00	1,092.00	0.00	4,748.00	4,746.00	0.00	-2.00	24.00	
4/19/2023	4,746.00	0.00	1,194.00	0.00	3,552.00	3,543.00	0.00	-9.00	15.00	
4/20/2023	3,543.00	0.00	1,278.00	0.00	2,265.00	2,269.00	0.00	4.00	19.00	
4/21/2023	2,269.00	0.00	1,051.00	0.00	1,218.00	1,223.00	0.00	5.00	24.00	
4/22/2023	1,223.00	0.00	896.00	0.00	327.00	332.00	0.00	5.00	29.00	
4/23/2023	332.00	6,901.00	886.00	0.00	6,347.00	6,358.00	0.00	11.00	40.00	
4/24/2023	6,358.00	0.00	908.00	0.00	5,450.00	5,447.00	0.00	-3.00	37.00	
4/25/2023	5,447.00	0.00	986.00	0.00	4,461.00	4,460.00	0.00	-1.00	36.00	
4/26/2023	4,460.00	0.00	822.00	0.00	3,638.00	3,635.00	0.00	-3.00	33.00	
4/27/2023	3,635.00	0.00	1,077.00	0.00	2,558.00	2,554.00	0.00	-4.00	29.00	
4/28/2023	2,554.00	0.00	1,016.00	0.00	1,538.00	1,543.00	0.00	5.00	34.00	
4/29/2023	1,543.00	6,000.00	893.00	0.00	6,650.00	6,675.00	0.00	25.00	59.00	
4/30/2023	6,675.00	0.00	828.00	0.00	5,847.00	5,841.00	0.00	-6.00	53.00	
5/1/2023	5,841.00	0.00	1,058.00	0.00	4,783.00	4,779.00	0.00	-4.00	49.00	
5/2/2023	4,779.00	0.00	1,074.00	0.00	3,705.00	3,702.00	0.00	-3.00	46.00	
5/3/2023	3,702.00	0.00	831.00	0.00	2,871.00	2,862.00	0.00	-9.00	37.00	
5/4/2023	2,862.00	0.00	1,000.00	0.00	1,862.00	1,870.00	0.00	8.00	45.00	
5/5/2023	1,870.00	0.00	1,123.00	0.00	747.00	756.00	0.00	9.00	54.00	
TOTALS		28,904.00	29,638.00	0.00			0.00	54.00	54.00	

Leak Check = (29,638.00 * 0.01 + 130) = 426.4 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	426.4 gall	0.0 inches	-0.0279 gph	0.0277 gph	PASS	PASS	PASS
Min. Daily Sales :		725.0	Max. Daily Sales :		1278.0	Avg. Daily Sales : 987.9	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd

Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 02

Product : SUPER

Date generated 05/06/2023

Effective Dates : 04/06/23 to 05/05/23

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
4/6/2023	1,553.00	0.00	128.00	0.00	1,425.00	1,425.00	0.00	0.00	0.00	Verif.Sales
4/7/2023	1,425.00	0.00	167.00	0.00	1,258.00	1,257.00	0.00	-1.00	-1.00	
4/8/2023	1,257.00	0.00	112.00	0.00	1,145.00	1,145.00	0.00	0.00	-1.00	Verif.Sales
4/9/2023	1,145.00	0.00	125.00	0.00	1,020.00	1,020.00	0.00	0.00	-1.00	Verif.Sales
4/10/2023	1,020.00	0.00	101.00	0.00	919.00	918.00	0.00	-1.00	-2.00	
4/11/2023	918.00	0.00	184.00	0.00	734.00	733.00	0.00	-1.00	-3.00	
4/12/2023	733.00	0.00	131.00	0.00	602.00	602.00	0.00	0.00	-3.00	Verif.Sales
4/13/2023	602.00	2,000.00	116.00	0.00	2,486.00	2,494.00	0.00	8.00	5.00	
4/14/2023	2,494.00	0.00	131.00	0.00	2,363.00	2,361.00	0.00	-2.00	3.00	
4/15/2023	2,361.00	0.00	151.00	0.00	2,210.00	2,211.00	0.00	1.00	4.00	
4/16/2023	2,211.00	0.00	155.00	0.00	2,056.00	2,056.00	0.00	0.00	4.00	Verif.Sales
4/17/2023	2,056.00	0.00	120.00	0.00	1,936.00	1,936.00	0.00	0.00	4.00	Verif.Sales
4/18/2023	1,936.00	0.00	104.00	0.00	1,832.00	1,832.00	0.00	0.00	4.00	Verif.Sales
4/19/2023	1,832.00	0.00	126.00	0.00	1,706.00	1,707.00	0.00	1.00	5.00	
4/20/2023	1,707.00	0.00	167.00	0.00	1,540.00	1,541.00	0.00	1.00	6.00	
4/21/2023	1,541.00	0.00	173.00	0.00	1,368.00	1,369.00	0.00	1.00	7.00	
4/22/2023	1,369.00	0.00	164.00	0.00	1,205.00	1,204.00	0.00	-1.00	6.00	
4/23/2023	1,204.00	0.00	117.00	0.00	1,087.00	1,087.00	0.00	0.00	6.00	Verif.Sales
4/24/2023	1,087.00	0.00	178.00	0.00	909.00	908.00	0.00	-1.00	5.00	
4/25/2023	908.00	0.00	98.00	0.00	810.00	809.00	0.00	-1.00	4.00	
4/26/2023	809.00	0.00	125.00	0.00	684.00	685.00	0.00	1.00	5.00	
4/27/2023	685.00	0.00	89.00	0.00	596.00	596.00	0.00	0.00	5.00	Verif.Sales
4/28/2023	596.00	0.00	172.00	0.00	424.00	424.00	0.00	0.00	5.00	Verif.Sales
4/29/2023	424.00	1,500.00	108.00	0.00	1,816.00	1,816.00	0.00	0.00	5.00	Verif.Sales
4/30/2023	1,816.00	0.00	119.00	0.00	1,697.00	1,699.00	0.00	2.00	7.00	
5/1/2023	1,699.00	0.00	140.00	0.00	1,559.00	1,561.00	0.00	2.00	9.00	
5/2/2023	1,561.00	0.00	65.00	0.00	1,496.00	1,496.00	0.00	0.00	9.00	Verif.Sales
5/3/2023	1,496.00	0.00	137.00	0.00	1,359.00	1,361.00	0.00	2.00	11.00	
5/4/2023	1,361.00	0.00	124.00	0.00	1,237.00	1,237.00	0.00	0.00	11.00	Verif.Sales
5/5/2023	1,237.00	0.00	148.00	0.00	1,089.00	1,091.00	0.00	2.00	13.00	
TOTALS		3,500.00	3,975.00	0.00			0.00	13.00	13.00	

Leak Check = (3,975.00 * 0.01 + 130) = 169.8 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	169.8 gall	0.0 inches	0.0112 gph	0.0074 gph	PASS	PASS	PASS
Min. Daily Sales :		65.0	Max. Daily Sales :		184.0	Avg. Daily Sales : 132.5	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496