

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner
6413 Manor Rd
Austin

TX

78723

Owner ID:
Facility ID: 67397
Tank : 01
Product : REGULAR

Date generated 12/03/2024

Effective Dates : 10/27/24 to 11/25/24

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
10/27/2024	3,141.00	0.00	1,089.00	0.00	2,052.00	2,047.00	0.00	-5.00	-5.00	
10/28/2024	2,047.00	0.00	862.00	0.00	1,185.00	1,188.00	0.00	3.00	-2.00	
10/29/2024	1,188.00	6,501.00	898.00	0.00	6,791.00	6,817.00	0.00	26.00	24.00	
10/30/2024	6,817.00	0.00	981.00	0.00	5,836.00	5,826.00	0.00	-10.00	14.00	
10/31/2024	5,826.00	0.00	1,043.00	0.00	4,783.00	4,776.00	0.00	-7.00	7.00	
11/1/2024	4,776.00	0.00	882.00	0.00	3,894.00	3,885.00	0.00	-9.00	-2.00	
11/2/2024	3,885.00	0.00	692.00	0.00	3,193.00	3,185.00	0.00	-8.00	-10.00	
11/3/2024	3,185.00	0.00	777.00	0.00	2,408.00	2,400.00	0.00	-8.00	-18.00	
11/4/2024	2,400.00	0.00	0.00	0.00	2,400.00	2,400.00	0.00	0.00	-18.00	
11/5/2024	2,400.00	0.00	1,770.00	0.00	630.00	633.00	0.00	3.00	-15.00	
11/6/2024	633.00	7,000.00	953.00	0.00	6,680.00	6,704.00	0.00	24.00	9.00	
11/7/2024	6,704.00	0.00	884.00	0.00	5,820.00	5,850.00	0.00	30.00	39.00	
11/8/2024	5,850.00	0.00	998.00	0.00	4,852.00	4,823.00	0.00	-29.00	10.00	
11/9/2024	4,823.00	0.00	962.00	0.00	3,861.00	3,849.00	0.00	-12.00	-2.00	
11/10/2024	3,849.00	0.00	930.00	0.00	2,919.00	2,910.00	0.00	-9.00	-11.00	
11/11/2024	2,910.00	0.00	820.00	0.00	2,090.00	2,086.00	0.00	-4.00	-15.00	
11/12/2024	2,086.00	0.00	901.00	0.00	1,185.00	1,188.00	0.00	3.00	-12.00	
11/13/2024	1,188.00	0.00	858.00	0.00	330.00	332.00	0.00	2.00	-10.00	
11/14/2024	332.00	6,950.00	545.00	0.00	6,737.00	6,757.00	0.00	20.00	10.00	
11/15/2024	6,757.00	0.00	854.00	0.00	5,903.00	5,899.00	0.00	-4.00	6.00	
11/16/2024	5,899.00	0.00	908.00	0.00	4,991.00	4,984.00	0.00	-7.00	-1.00	
11/17/2024	4,984.00	0.00	833.00	0.00	4,151.00	4,143.00	0.00	-8.00	-9.00	
11/18/2024	4,143.00	0.00	770.00	0.00	3,373.00	3,364.00	0.00	-9.00	-18.00	
11/19/2024	3,364.00	0.00	790.00	0.00	2,574.00	2,567.00	0.00	-7.00	-25.00	
11/20/2024	2,567.00	0.00	828.00	0.00	1,739.00	1,736.00	0.00	-3.00	-28.00	
11/21/2024	1,736.00	0.00	784.00	0.00	952.00	953.00	0.00	1.00	-27.00	
11/22/2024	953.00	6,700.00	959.00	0.00	6,694.00	6,723.00	0.00	29.00	2.00	
11/23/2024	6,723.00	0.00	925.00	0.00	5,798.00	5,794.00	0.00	-4.00	-2.00	
11/24/2024	5,794.00	0.00	876.00	0.00	4,918.00	4,912.00	0.00	-6.00	-8.00	
11/25/2024	4,912.00	0.00	945.00	0.00	3,967.00	3,962.00	0.00	-5.00	-13.00	
TOTALS		27,151.00	26,317.00	0.00			0.00	-13.00	-13.00	

Leak Check = (26,317.00 * 0.01 + 130) = 393.2 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	393.2 gall	0.0 inches	-0.0111 gph	0.0564 gph	PASS	PASS	PASS

Min. Daily Sales : 0.0 Max. Daily Sales : 1770.0 Avg. Daily Sales : 877.2

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner
6413 Manor Rd
Austin

TX

78723

Owner ID:
Facility ID: 67397
Tank : 02
Product : SUPER

Date generated 12/03/2024

Effective Dates : 10/27/24 to 11/25/24

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
10/27/2024	1,118.00	0.00	204.00	0.00	914.00	915.00	0.00	1.00	1.00	
10/28/2024	915.00	0.00	145.00	0.00	770.00	769.00	0.00	-1.00	0.00	
10/29/2024	769.00	1,000.00	176.00	0.00	1,593.00	1,591.00	0.00	-2.00	-2.00	
10/30/2024	1,591.00	0.00	112.00	0.00	1,479.00	1,478.00	0.00	-1.00	-3.00	
10/31/2024	1,478.00	0.00	122.00	0.00	1,356.00	1,355.00	0.00	-1.00	-4.00	
11/1/2024	1,355.00	0.00	159.00	0.00	1,196.00	1,196.00	0.00	0.00	-4.00	Verif.Sales
11/2/2024	1,196.00	0.00	159.00	0.00	1,037.00	1,037.00	0.00	0.00	-4.00	Verif.Sales
11/3/2024	1,037.00	0.00	123.00	0.00	914.00	913.00	0.00	-1.00	-5.00	
11/4/2024	913.00	0.00	0.00	0.00	913.00	913.00	0.00	0.00	-5.00	
11/5/2024	913.00	0.00	316.00	0.00	597.00	612.00	0.00	15.00	10.00	
11/6/2024	612.00	950.00	126.00	0.00	1,436.00	1,439.00	0.00	3.00	13.00	
11/7/2024	1,439.00	0.00	127.00	0.00	1,312.00	1,312.00	0.00	0.00	13.00	Verif.Sales
11/8/2024	1,312.00	0.00	139.00	0.00	1,173.00	1,177.00	0.00	4.00	17.00	
11/9/2024	1,177.00	0.00	152.00	0.00	1,025.00	1,025.00	0.00	0.00	17.00	Verif.Sales
11/10/2024	1,025.00	0.00	111.00	0.00	914.00	917.00	0.00	3.00	20.00	
11/11/2024	917.00	0.00	123.00	0.00	794.00	793.00	0.00	-1.00	19.00	
11/12/2024	793.00	0.00	147.00	0.00	646.00	646.00	0.00	0.00	19.00	Verif.Sales
11/13/2024	646.00	0.00	98.00	0.00	548.00	547.00	0.00	-1.00	18.00	
11/14/2024	547.00	1,500.00	121.00	0.00	1,926.00	1,927.00	0.00	1.00	19.00	
11/15/2024	1,927.00	0.00	91.00	0.00	1,836.00	1,837.00	0.00	1.00	20.00	
11/16/2024	1,837.00	0.00	106.00	0.00	1,731.00	1,730.00	0.00	-1.00	19.00	
11/17/2024	1,730.00	0.00	111.00	0.00	1,619.00	1,619.00	0.00	0.00	19.00	Verif.Sales
11/18/2024	1,619.00	0.00	132.00	0.00	1,487.00	1,492.00	0.00	5.00	24.00	
11/19/2024	1,492.00	0.00	141.00	0.00	1,351.00	1,352.00	0.00	1.00	25.00	
11/20/2024	1,352.00	0.00	174.00	0.00	1,178.00	1,177.00	0.00	-1.00	24.00	
11/21/2024	1,177.00	0.00	162.00	0.00	1,015.00	1,014.00	0.00	-1.00	23.00	
11/22/2024	1,014.00	700.00	113.00	0.00	1,601.00	1,603.00	0.00	2.00	25.00	
11/23/2024	1,603.00	0.00	203.00	0.00	1,400.00	1,400.00	0.00	0.00	25.00	Verif.Sales
11/24/2024	1,400.00	0.00	148.00	0.00	1,252.00	1,251.00	0.00	-1.00	24.00	
11/25/2024	1,251.00	0.00	109.00	0.00	1,142.00	1,142.00	0.00	0.00	24.00	Verif.Sales
TOTALS		4,150.00	4,150.00	0.00			0.00	24.00	24.00	

Leak Check = (4,150.00 * 0.01 + 130) = 171.5 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago	
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result	
0.1000	171.5 gall	0.0 inches	0.0006 gph	0.0152 gph	PASS	PASS	PASS	
Min. Daily Sales :		0.0	Max. Daily Sales :		316.0	Avg. Daily Sales :		138.3

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496