

# TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd  
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd

Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 01

Product : REGULAR

Date generated 08/07/2023

Effective Dates : 07/05/23 to 08/03/23

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
7/5/2023	2,491.00	0.00	898.00	0.00	1,593.00	1,599.00	0.00	6.00	6.00	
7/6/2023	1,599.00	5,501.00	1,053.00	0.00	6,047.00	6,060.00	0.00	13.00	19.00	
7/7/2023	6,060.00	0.00	898.00	0.00	5,162.00	5,156.00	0.00	-6.00	13.00	
7/8/2023	5,156.00	0.00	1,097.00	0.00	4,059.00	4,057.00	0.00	-2.00	11.00	
7/9/2023	4,057.00	0.00	1,065.00	0.00	2,992.00	2,970.00	0.00	-22.00	-11.00	
7/10/2023	2,970.00	0.00	1,109.00	0.00	1,861.00	1,878.00	0.00	17.00	6.00	
7/11/2023	1,878.00	0.00	897.00	0.00	981.00	987.00	0.00	6.00	12.00	
7/12/2023	987.00	5,600.00	1,036.00	0.00	5,551.00	5,562.00	0.00	11.00	23.00	
7/13/2023	5,562.00	0.00	843.00	0.00	4,719.00	4,714.00	0.00	-5.00	18.00	
7/14/2023	4,714.00	0.00	1,042.00	0.00	3,672.00	3,668.00	0.00	-4.00	14.00	
7/15/2023	3,668.00	0.00	1,011.00	0.00	2,657.00	2,652.00	0.00	-5.00	9.00	
7/16/2023	2,652.00	0.00	787.00	0.00	1,865.00	1,867.00	0.00	2.00	11.00	
7/17/2023	1,867.00	0.00	972.00	0.00	895.00	903.00	0.00	8.00	19.00	
7/18/2023	903.00	6,500.00	912.00	0.00	6,491.00	6,515.00	0.00	24.00	43.00	
7/19/2023	6,515.00	0.00	992.00	0.00	5,523.00	5,511.00	0.00	-12.00	31.00	
7/20/2023	5,511.00	0.00	924.00	0.00	4,587.00	4,582.00	0.00	-5.00	26.00	
7/21/2023	4,582.00	0.00	1,010.00	0.00	3,572.00	3,567.00	0.00	-5.00	21.00	
7/22/2023	3,567.00	0.00	869.00	0.00	2,698.00	2,695.00	0.00	-3.00	18.00	
7/23/2023	2,695.00	0.00	1,070.00	0.00	1,625.00	1,629.00	0.00	4.00	22.00	
7/24/2023	1,629.00	0.00	1,044.00	0.00	585.00	592.00	0.00	7.00	29.00	
7/25/2023	592.00	6,801.00	758.00	0.00	6,635.00	6,635.00	0.00	0.00	29.00	Verif.Sales
7/26/2023	6,635.00	0.00	807.00	0.00	5,828.00	5,855.00	0.00	27.00	56.00	
7/27/2023	5,855.00	0.00	984.00	0.00	4,871.00	4,867.00	0.00	-4.00	52.00	
7/28/2023	4,867.00	0.00	1,014.00	0.00	3,853.00	3,845.00	0.00	-8.00	44.00	
7/29/2023	3,845.00	0.00	1,064.00	0.00	2,781.00	2,781.00	0.00	0.00	44.00	Verif.Sales
7/30/2023	2,781.00	0.00	1,181.00	0.00	1,600.00	1,604.00	0.00	4.00	48.00	
7/31/2023	1,604.00	0.00	1,057.00	0.00	547.00	552.00	0.00	5.00	53.00	
8/1/2023	552.00	6,801.00	950.00	0.00	6,403.00	6,443.00	0.00	40.00	93.00	
8/2/2023	6,443.00	0.00	885.00	0.00	5,558.00	5,557.00	0.00	-1.00	92.00	
8/3/2023	5,557.00	0.00	952.00	0.00	4,605.00	4,603.00	0.00	-2.00	90.00	
TOTALS		31,203.00	29,181.00	0.00			0.00	90.00	90.00	

Leak Check = ( 29,181.00 \* 0.01 + 130 ) = 421.8 gall

## Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	421.8 gall	0.0 inches	-0.0417 gph	0.0418 gph	PASS	PASS	PASS
Min. Daily Sales :		758.0	Max. Daily Sales :		1181.0	Avg. Daily Sales : 972.7	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.  
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496

# TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd  
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd

Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 02

Product : SUPER

Date generated 08/07/2023

Effective Dates : 07/05/23 to 08/03/23

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
7/5/2023	765.00	0.00	83.00	0.00	682.00	683.00	0.00	1.00	1.00	
7/6/2023	683.00	1,000.00	113.00	0.00	1,570.00	1,570.00	0.00	0.00	1.00	Verif.Sales
7/7/2023	1,570.00	0.00	104.00	0.00	1,466.00	1,467.00	0.00	1.00	2.00	
7/8/2023	1,467.00	0.00	180.00	0.00	1,287.00	1,288.00	0.00	1.00	3.00	
7/9/2023	1,288.00	0.00	183.00	0.00	1,105.00	1,107.00	0.00	2.00	5.00	
7/10/2023	1,107.00	0.00	76.00	0.00	1,031.00	1,031.00	0.00	0.00	5.00	Verif.Sales
7/11/2023	1,031.00	0.00	165.00	0.00	866.00	867.00	0.00	1.00	6.00	
7/12/2023	867.00	500.00	119.00	0.00	1,248.00	1,248.00	0.00	0.00	6.00	Verif.Sales
7/13/2023	1,248.00	0.00	116.00	0.00	1,132.00	1,133.00	0.00	1.00	7.00	
7/14/2023	1,133.00	0.00	123.00	0.00	1,010.00	1,011.00	0.00	1.00	8.00	
7/15/2023	1,011.00	0.00	128.00	0.00	883.00	884.00	0.00	1.00	9.00	
7/16/2023	884.00	0.00	129.00	0.00	755.00	755.00	0.00	0.00	9.00	Verif.Sales
7/17/2023	755.00	0.00	103.00	0.00	652.00	653.00	0.00	1.00	10.00	
7/18/2023	653.00	1,000.00	83.00	0.00	1,570.00	1,568.00	0.00	-2.00	8.00	
7/19/2023	1,568.00	0.00	125.00	0.00	1,443.00	1,443.00	0.00	0.00	8.00	Verif.Sales
7/20/2023	1,443.00	0.00	79.00	0.00	1,364.00	1,365.00	0.00	1.00	9.00	
7/21/2023	1,365.00	0.00	62.00	0.00	1,303.00	1,303.00	0.00	0.00	9.00	Verif.Sales
7/22/2023	1,303.00	0.00	128.00	0.00	1,175.00	1,176.00	0.00	1.00	10.00	
7/23/2023	1,176.00	0.00	122.00	0.00	1,054.00	1,054.00	0.00	0.00	10.00	Verif.Sales
7/24/2023	1,054.00	0.00	140.00	0.00	914.00	915.00	0.00	1.00	11.00	
7/25/2023	915.00	500.00	136.00	0.00	1,279.00	1,276.00	0.00	-3.00	8.00	
7/26/2023	1,276.00	0.00	97.00	0.00	1,179.00	1,181.00	0.00	2.00	10.00	
7/27/2023	1,181.00	0.00	97.00	0.00	1,084.00	1,085.00	0.00	1.00	11.00	
7/28/2023	1,085.00	0.00	171.00	0.00	914.00	915.00	0.00	1.00	12.00	
7/29/2023	915.00	0.00	155.00	0.00	760.00	760.00	0.00	0.00	12.00	Verif.Sales
7/30/2023	760.00	0.00	115.00	0.00	645.00	647.00	0.00	2.00	14.00	
7/31/2023	647.00	0.00	117.00	0.00	530.00	530.00	0.00	0.00	14.00	Verif.Sales
8/1/2023	530.00	1,200.00	111.00	0.00	1,619.00	1,626.00	0.00	7.00	21.00	
8/2/2023	1,626.00	0.00	105.00	0.00	1,521.00	1,522.00	0.00	1.00	22.00	
8/3/2023	1,522.00	0.00	94.00	0.00	1,428.00	1,430.00	0.00	2.00	24.00	
TOTALS		4,200.00	3,559.00	0.00			0.00	24.00	24.00	

Leak Check = ( 3,559.00 \* 0.01 + 130 ) = 165.6 gall

## Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	165.6 gall	0.0 inches	0.0094 gph	0.0060 gph	PASS	PASS	PASS
Min. Daily Sales :		62.0	Max. Daily Sales :		183.0	Avg. Daily Sales : 118.6	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.  
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496