

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd
Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 01

Product : REGULAR

Date generated 09/05/2023

Effective Dates : 08/04/23 to 09/02/23

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
8/4/2023	4,603.00	0.00	1,023.00	0.00	3,580.00	3,578.00	0.00	-2.00	-2.00	
8/5/2023	3,578.00	0.00	965.00	0.00	2,613.00	2,608.00	0.00	-5.00	-7.00	
8/6/2023	2,608.00	0.00	918.00	0.00	1,690.00	1,694.00	0.00	4.00	-3.00	
8/7/2023	1,694.00	0.00	985.00	0.00	709.00	715.00	0.00	6.00	3.00	
8/8/2023	715.00	6,801.00	860.00	0.00	6,656.00	6,681.00	0.00	25.00	28.00	
8/9/2023	6,681.00	0.00	861.00	0.00	5,820.00	5,811.00	0.00	-9.00	19.00	
8/10/2023	5,811.00	0.00	787.00	0.00	5,024.00	5,020.00	0.00	-4.00	15.00	
8/11/2023	5,020.00	0.00	974.00	0.00	4,046.00	4,041.00	0.00	-5.00	10.00	
8/12/2023	4,041.00	0.00	950.00	0.00	3,091.00	3,082.00	0.00	-9.00	1.00	
8/13/2023	3,082.00	0.00	778.00	0.00	2,304.00	2,303.00	0.00	-1.00	0.00	
8/14/2023	2,303.00	0.00	992.00	0.00	1,311.00	1,316.00	0.00	5.00	5.00	
8/15/2023	1,316.00	5,500.00	994.00	0.00	5,822.00	5,831.00	0.00	9.00	14.00	
8/16/2023	5,831.00	0.00	994.00	0.00	4,837.00	4,847.00	0.00	10.00	24.00	
8/17/2023	4,847.00	0.00	1,021.00	0.00	3,826.00	3,823.00	0.00	-3.00	21.00	
8/18/2023	3,823.00	0.00	1,034.00	0.00	2,789.00	2,784.00	0.00	-5.00	16.00	
8/19/2023	2,784.00	0.00	1,170.00	0.00	1,614.00	1,617.00	0.00	3.00	19.00	
8/20/2023	1,617.00	0.00	1,040.00	0.00	577.00	583.00	0.00	6.00	25.00	
8/21/2023	583.00	6,991.00	829.00	0.00	6,745.00	6,824.00	0.00	79.00	104.00	
8/22/2023	6,824.00	0.00	972.00	0.00	5,852.00	5,844.00	0.00	-8.00	96.00	
8/23/2023	5,844.00	0.00	911.00	0.00	4,933.00	4,928.00	0.00	-5.00	91.00	
8/24/2023	4,928.00	0.00	1,009.00	0.00	3,919.00	3,915.00	0.00	-4.00	87.00	
8/25/2023	3,915.00	0.00	960.00	0.00	2,955.00	2,949.00	0.00	-6.00	81.00	
8/26/2023	2,949.00	0.00	1,031.00	0.00	1,918.00	1,902.00	0.00	-16.00	65.00	
8/27/2023	1,902.00	0.00	986.00	0.00	916.00	937.00	0.00	21.00	86.00	
8/28/2023	937.00	6,501.00	1,014.00	0.00	6,424.00	6,444.00	0.00	20.00	106.00	
8/29/2023	6,444.00	0.00	1,001.00	0.00	5,443.00	5,438.00	0.00	-5.00	101.00	
8/30/2023	5,438.00	0.00	839.00	0.00	4,599.00	4,596.00	0.00	-3.00	98.00	
8/31/2023	4,596.00	0.00	1,128.00	0.00	3,468.00	3,453.00	0.00	-15.00	83.00	
9/1/2023	3,453.00	0.00	1,132.00	0.00	2,321.00	2,326.00	0.00	5.00	88.00	
9/2/2023	2,326.00	0.00	758.00	0.00	1,568.00	1,571.00	0.00	3.00	91.00	
TOTALS		25,793.00	28,916.00	0.00			0.00	91.00	91.00	

Leak Check = (28,916.00 * 0.01 + 130) = 419.2 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	419.2 gall	0.0 inches	-0.0625 gph	0.0526 gph	PASS	PASS	PASS
Min. Daily Sales :		758.0	Max. Daily Sales :		1170.0	Avg. Daily Sales : 963.9	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496

TANKNETICS (Version V.2.1) SIR EVALUATION for:

Client:

Kool Corner

6413 Manor Rd
Austin

TX 78723

Site id: Kool Corner

6413 Manor Rd
Austin

TX

78723

Owner ID:

Facility ID: 67397

Tank : 02

Product : SUPER

Date generated 09/05/2023

Effective Dates : 08/04/23 to 09/02/23

Date	Beg.Inv.	Delivery	Sales	Adjust	Total	Stick	Water	Daily O/S	Cumul. O/S	Comments
8/4/2023	1,430.00	0.00	119.00	0.00	1,311.00	1,312.00	0.00	1.00	1.00	
8/5/2023	1,312.00	0.00	150.00	0.00	1,162.00	1,164.00	0.00	2.00	3.00	
8/6/2023	1,164.00	0.00	215.00	0.00	949.00	950.00	0.00	1.00	4.00	
8/7/2023	950.00	0.00	152.00	0.00	798.00	798.00	0.00	0.00	4.00	Verif.Sales
8/8/2023	798.00	1,000.00	86.00	0.00	1,712.00	1,708.00	0.00	-4.00	0.00	
8/9/2023	1,708.00	0.00	93.00	0.00	1,615.00	1,615.00	0.00	0.00	0.00	Verif.Sales
8/10/2023	1,615.00	0.00	137.00	0.00	1,478.00	1,479.00	0.00	1.00	1.00	
8/11/2023	1,479.00	0.00	124.00	0.00	1,355.00	1,356.00	0.00	1.00	2.00	
8/12/2023	1,356.00	0.00	190.00	0.00	1,166.00	1,168.00	0.00	2.00	4.00	
8/13/2023	1,168.00	0.00	109.00	0.00	1,059.00	1,060.00	0.00	1.00	5.00	
8/14/2023	1,060.00	0.00	95.00	0.00	965.00	965.00	0.00	0.00	5.00	Verif.Sales
8/15/2023	965.00	700.00	161.00	0.00	1,504.00	1,504.00	0.00	0.00	5.00	Verif.Sales
8/16/2023	1,504.00	0.00	92.00	0.00	1,412.00	1,412.00	0.00	0.00	5.00	Verif.Sales
8/17/2023	1,412.00	0.00	117.00	0.00	1,295.00	1,296.00	0.00	1.00	6.00	
8/18/2023	1,296.00	0.00	170.00	0.00	1,126.00	1,127.00	0.00	1.00	7.00	
8/19/2023	1,127.00	0.00	180.00	0.00	947.00	936.00	0.00	-11.00	-4.00	
8/20/2023	936.00	0.00	176.00	0.00	760.00	773.00	0.00	13.00	9.00	
8/21/2023	773.00	1,000.00	207.00	0.00	1,566.00	1,575.00	0.00	9.00	18.00	
8/22/2023	1,575.00	0.00	133.00	0.00	1,442.00	1,442.00	0.00	0.00	18.00	Verif.Sales
8/23/2023	1,442.00	0.00	97.00	0.00	1,345.00	1,345.00	0.00	0.00	18.00	Verif.Sales
8/24/2023	1,345.00	0.00	108.00	0.00	1,237.00	1,239.00	0.00	2.00	20.00	
8/25/2023	1,239.00	0.00	172.00	0.00	1,067.00	1,068.00	0.00	1.00	21.00	
8/26/2023	1,068.00	0.00	116.00	0.00	952.00	952.00	0.00	0.00	21.00	Verif.Sales
8/27/2023	952.00	0.00	148.00	0.00	804.00	806.00	0.00	2.00	23.00	
8/28/2023	806.00	1,000.00	163.00	0.00	1,643.00	1,642.00	0.00	-1.00	22.00	
8/29/2023	1,642.00	0.00	111.00	0.00	1,531.00	1,532.00	0.00	1.00	23.00	
8/30/2023	1,532.00	0.00	126.00	0.00	1,406.00	1,406.00	0.00	0.00	23.00	Verif.Sales
8/31/2023	1,406.00	0.00	101.00	0.00	1,305.00	1,306.00	0.00	1.00	24.00	
9/1/2023	1,306.00	0.00	187.00	0.00	1,119.00	1,120.00	0.00	1.00	25.00	
9/2/2023	1,120.00	0.00	88.00	0.00	1,032.00	1,033.00	0.00	1.00	26.00	
TOTALS		3,700.00	4,123.00	0.00			0.00	26.00	26.00	

Leak Check = (4,123.00 * 0.01 + 130) = 171.2 gall

Quantitative methods

Leak Threshold	Leak Check	Water Level incr/decr	This month			Last month	Two months ago
			Calculated Leak Rate	Min.Detec. Leak Rate	Test Result	Test Result	Test Result
0.1000	171.2 gall	0.0 inches	0.0061 gph	0.0073 gph	PASS	PASS	PASS
Min. Daily Sales :		86.0	Max. Daily Sales :		215.0	Avg. Daily Sales : 137.4	

General comments :

Contact : AMTS- 281-242-2687 for compliance questions, report analysis and authenticity.
Environmental Solutions Group Post Office Box 18467 Sugar Land Tx 77496